

## Compassion Road Academy (515) – Sampled 11/11/2016

All results <15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Sample ID	Sample Description	Lead Result	Units	Action
515-210-SK-01	Faculty lounge sink, room 210	0.2	µg/L	
515-211-DF-02	Drinking fountain, hallway 211, across from room 213	<0.1*	µg/L	
515-111-SK-03	Faculty lounge sink, room 111	<0.1	µg/L	
515-108-DF-04	Drinking fountain, hallway 108, across from room 110, left bubbler	<0.1	µg/L	
515-108-DF-05	Drinking fountain, hallway 108, across from room 110, right bubbler	<0.1	µg/L	

\*Result less than 0.1 ppb which is the lowest level that can be reported by the lab.