

## Academy of Urban Learning (681) – Sampled 11/4/2016

All results <15 ppb – No further action at this time.

### Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Sample ID	Sample Description	Lead Result	Units	Action
681-110-DF-01	Drinking fountain, hallway 110, next to room 118	2.8	µg/L	
681-118-SK-02	Classroom sink, room 118	5.5	µg/L	
681-101-DF-03	Drinking fountain, hallway 101, next to restroom 101B, left bubbler	<0.1*	µg/L	
681-101-DF-04	Drinking fountain, hallway 101, next to restroom 101B, right bubbler	0.1	µg/L	
681-105-SK-05	Classroom sink, room 105	0.8	µg/L	
681-106-SK-06	Classroom sink, room 106	1.2	µg/L	
681-104-SK-07	Classroom sink, room 107	0.9	µg/L	
681-103-SK-08	Classroom sink, room 103	0.3	µg/L	
681-102-SK-09	Classroom sink, room 102	0.4	µg/L	

\*Result less than 0.1 ppb which is the lowest level that can be reported by the lab.