

## Emily Griffith Campus (860)

All results <15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

### Phase I Sampled on 10/12-13/2016

Sample ID	Sample Description	Lead Result	Units	Action
860-112-DF-01	Drinking fountain, lobby 112, next to stairs and DDES, left bubbler	<0.1* <sup>1</sup>	µg/L	
860-112-DF-02	Drinking fountain, lobby 112, next to stairs and DDES, right bubbler	<0.1	µg/L	
860-113-DF-03	Drinking fountain, all purpose room 113, DDES, left bubbler	<0.1	µg/L	
860-113-DF-04	Drinking fountain, all purpose room 113, DDES, right bubbler	<0.1	µg/L	
860-105-DF-05	Drinking fountain, hallway 105, next to room 106, left bubbler	<0.1	µg/L	
860-105-DF-06	Drinking fountain, hallway 105, next to room 106, right bubbler	<0.1	µg/L	
860-108-SK-07	Kitchen kettle filler, under hood on west wall, close to room 108B	0.7	µg/L	
860-108-SK-08	Kitchen sink, west wall, baking area	<0.1	µg/L	
860-108-SK-09	Kitchen sink, food prep island	0.4	µg/L	
860-108-SK-10	Kitchen sink, food prep area, left of window	0.4	µg/L	
860-108-SK-11	Kitchen sprayer, food prep area, right of window	0.3	µg/L	
860-108-SK-12	Kitchen sink, food prep area, right of window	0.3	µg/L	
860-214-DF-13	Drinking fountain, hallway 214, next to room 227, left bubbler	<0.1	µg/L	
860-214-DF-14	Drinking fountain, hallway 214, next to room 227, right bubbler	<0.1	µg/L	
860-217-DF-15	Drinking fountain, room 217	<0.1	µg/L	
860-216-DF-16	Drinking fountain, room 216	<0.1	µg/L	
860-212-DF-17	Drinking fountain, room 212	<0.1	µg/L	
860-201-DF-18	Drinking fountain, hallway 201, next to room 201B, left bubbler	<0.1	µg/L	
860-201-DF-19	Drinking fountain, hallway 201, next to room 201B, right bubbler	<0.1	µg/L	
860-215A-SK-20	Nurse sink, room 215A	0.1	µg/L	
860-322-DF-21	Drinking fountain, hallway 322, next to room 322C, far left bubbler	<0.1	µg/L	
860-322-DF-22	Drinking fountain, hallway 322, next to room 322C, center left bubbler	<0.1	µg/L	
860-322-DF-23	Drinking fountain, hallway 322, next to room 322D, center right bubbler	<0.1	µg/L	
860-322-DF-24	Drinking fountain, hallway 322, next to room 322D, far right bubbler	<0.1	µg/L	
860-301-DF-25	Drinking fountain, hallway 301, across from room 303, left bubbler	0.2	µg/L	
860-301-DF-26	Drinking fountain, hallway 301, across from room 303, right bubbler	0.3	µg/L	
860-301-DF-27	Drinking fountain, hallway 340, across from room 303, left bubbler	<0.1	µg/L	
860-301-DF-28	Drinking fountain, hallway 340, across from room 303, right bubbler	<0.1	µg/L	
860-412-DF-29	Drinking fountain, hallway 412, next to room 413, left bubbler	<0.1	µg/L	
860-412-DF-30	Drinking fountain, hallway 412, next to room 413, right bubbler	<0.1	µg/L	
860-401-DF-31	Drinking fountain, hallway 401, across from room 403, left bubbler	<0.1	µg/L	
860-401-DF-32	Drinking fountain, hallway 401, across from room 403, right bubbler	<0.1	µg/L	
860-401-DF-33	Drinking fountain, hallway 401, across from room 428, left bubbler	<0.1	µg/L	

<b>860-401-DF-34</b>	Drinking fountain, hallway 401, across from room 428, right bubbler	<0.1	µg/L
<b>860-501-DF-35</b>	Drinking fountain, hallway 501, next to room 501D, left bubbler	0.3	µg/L
<b>860-501-DF-36</b>	Drinking fountain, hallway 501, next to room 501D, right bubbler	0.3	µg/L
<b>860-518-DF-37</b>	Drinking fountain, hallway 518, next to room 522, left bubbler	<0.1	µg/L
<b>860-518-DF-38</b>	Drinking fountain, hallway 518, next to room 522, right bubbler	<0.1	µg/L
<b>860-632-DF-39</b>	Drinking fountain, hallway 632, next to room 632D, left bubbler	<0.1	µg/L
<b>860-632-DF-40</b>	Drinking fountain, hallway 632, next to room 632D, right bubbler	<0.1	µg/L
<b>860-601-DF-41</b>	Drinking fountain, hallway 601, across from room 604, left bubbler	0.3	µg/L
<b>860-601-DF-42</b>	Drinking fountain, hallway 601, across from room 604, right bubbler	0.4	µg/L
<b>860-1411-DF-43</b>	Drinking fountain, hallway 1411, next to room 1411B, left bubbler	<0.1	µg/L
<b>860-1411-DF-44</b>	Drinking fountain, hallway 1411, next to room 1411B, right bubbler	<0.1	µg/L
<b>860-1407-DF-45</b>	Drinking fountain, 14er cafeteria 1407, left bubbler, north wall	<0.1	µg/L
<b>860-1407-DF-46</b>	Bottle fill, 14er cafeteria 1407, north wall	<0.1	µg/L
<b>860-1407-DF-47</b>	Drinking fountain, 14er cafeteria 1407, right bubbler, north wall	<0.1	µg/L
<b>860-1407-DF-48</b>	Water source at drink fountain, 14er cafeteria 1407, south wall	<0.1	µg/L
<b>860-1408-SK-49</b>	Kitchen prep sink, room 1408, southeast corner	<0.1	µg/L
<b>860-1408-SK-50</b>	Kitchen kettle fill, center of kitchen, room 1408	0.6	µg/L
<b>860-1408-SK-51</b>	Kitchen prep sink, room 1408, northeast corner	<0.1	µg/L
<b>860-1408-SK-52</b>	Kitchen prep sink, room 1408, southwest corner	0.2	µg/L
<b>860-S1-104-DF-53</b>	Drinking fountain, hallway S1-104, across from room S1-105, left bubbler	<0.1	µg/L
<b>860-S1-104-DF-54</b>	Drinking fountain, hallway S1-104, across from room S1-105, right bubbler	<0.1	µg/L
<b>860-220-DF-55</b>	Drinking fountain, room 220	<1.0*2	µg/L
<b>860-701-DF-56</b>	Drinking fountain, hallway 701, next to room 701C, left bubbler	<1.0	µg/L
<b>860-701-DF-57</b>	Drinking fountain, hallway 701, next to room 701C, right bubbler	<1.0	µg/L
<b>860-704-DF-58</b>	Bottle fill, hallway 704, next to 708 admin break room	<1.0	µg/L
<b>860-704-DF-59</b>	Drinking fountain, hallway 704, next to 708 admin break room	<1.0	µg/L
<b>860-801-DF-60</b>	Drinking fountain, hallway 801, next to room 801C, left bubbler	<1.0	µg/L
<b>860-801-DF-61</b>	Drinking fountain, hallway 801, next to room 801C, right bubbler	<1.0	µg/L
<b>860-804-DF-62</b>	Bottle fill, hallway 804, next to 808 admin break room	<1.0	µg/L
<b>860-804-DF-63</b>	Drinking fountain, hallway 804, next to 808 admin break room	<1.0	µg/L
<b>860-901-DF-64</b>	Drinking fountain, hallway 901, next to room 901C, left bubbler	<1.0	µg/L
<b>860-901-DF-65</b>	Drinking fountain, hallway 901, next to room 901C, right bubbler	<1.0	µg/L
<b>860-904-DF-66</b>	Bottle fill, hallway 904, next to 908 admin break room	<1.0	µg/L
<b>860-904-DF-67</b>	Drinking fountain, hallway 904, next to 908 admin break room	<1.0	µg/L
<b>860-1001-DF-68</b>	Drinking fountain, hallway 1001, next to room 1001C, left bubbler	<1.0	µg/L
<b>860-1001-DF-69</b>	Drinking fountain, hallway 1001, next to room 1001C, right bubbler	<1.0	µg/L
<b>860-1004-DF-70</b>	Bottle fill, hallway 1004, next to 1008 admin break room	<1.0	µg/L
<b>860-1004-DF-71</b>	Drinking fountain, hallway 1004, next to 1008 admin break room	<1.0	µg/L
<b>860-1101-DF-72</b>	Drinking fountain, hallway 1101, next to room 1101C, left bubbler	<1.0	µg/L
<b>860-1101-DF-73</b>	Drinking fountain, hallway 1101, next to room 1101C, right bubbler	<1.0	µg/L
<b>860-1104-DF-74</b>	Bottle fill, hallway 1104, next to 1108 admin break room	<1.0	µg/L
<b>860-1104-DF-75</b>	Drinking fountain, hallway 1104, next to 1108 admin break room	<1.0	µg/L
<b>860-1201-DF-76</b>	Drinking fountain, hallway 1201, next to room 1201C, left bubbler	<1.0	µg/L

<b>860-1201-DF-77</b>	Drinking fountain, hallway 1201, next to room 1201C, right bubbler	<1.0	µg/L
<b>860-1204-DF-78</b>	Bottle fill, hallway 1204, next to 1208 admin break room	<1.0	µg/L
<b>860-1204-DF-79</b>	Drinking fountain, hallway 1204, next to 1208 admin break room	<1.0	µg/L

#### Phase II.A Sampled on 5/3/2017

<b>860-217-SK-80</b>	Classroom sink, room 217	<1.0	µg/L
<b>860-216-SK-81</b>	Classroom sink, room 216	<1.0	µg/L
<b>860-212-SK-82</b>	Classroom sink, room 212	<1.0	µg/L
<b>860-209-SK-83</b>	Conference room sink, room 209	<1.0	µg/L
<b>860-227-SK-84</b>	Classroom sink, room 227, left sink	<1.0	µg/L
<b>860-227-SK-85</b>	Classroom sink, room 227, right sink	<1.0	µg/L
<b>860-226-SK-86</b>	Classroom sink, room 226	2.0	µg/L
<b>860-224-SK-87</b>	Classroom sink, room 224	<1.0	µg/L
<b>860-223-SK-88</b>	Classroom sink, room 223	<1.0	µg/L
<b>860-220-SK-89</b>	Classroom sink, room 220	<1.0	µg/L
<b>860-221-SK-90</b>	Classroom sink, room 221	<1.0	µg/L
<b>860-222-SK-91</b>	Classroom sink, room 222	<1.0	µg/L
<b>860-336-SK-92</b>	Classroom sink, room 336	<1.0	µg/L
<b>860-335-SK-93</b>	Classroom sink, room 335	<1.0	µg/L
<b>860-334-SK-94</b>	Classroom sink, room 334	<1.0	µg/L
<b>860-332-SK-95</b>	Classroom sink, room 332, right sink	<1.0	µg/L
<b>860-332-SK-96</b>	Classroom sink, room 332, left sink	<1.0	µg/L
<b>860-308-SK-97</b>	Faculty lounge sink, room 308	<1.0	µg/L
<b>860-313-SK-98</b>	Workroom sink, room 313	<1.0	µg/L

#### Phase II.B Sampled on 10/13 & 20/2017

<b>860-107C-SK-100</b>	Coffee bar sink, room 107C	9.9	µg/L
<b>860-S1-103-SK-101</b>	Classroom sink, room S1-103	<0.1	µg/L
<b>860-S1-105-SK-102</b>	Classroom sink, room S1-105	<0.1	µg/L
<b>860-S1-106-SK-103</b>	Classroom sink, room S1-106, left sink	<0.1	µg/L
<b>860-S1-106-SK-104</b>	Classroom sink, room S1-106, center sink	<0.1	µg/L
<b>860-S1-106-SK-105</b>	Classroom sink, room S1-106, right sink	<0.1	µg/L
<b>860-S1-108-SK-106</b>	Classroom sink, room S1-108	0.5	µg/L
<b>860-405-SK-107</b>	Lobby sink, room 405	<0.1	µg/L
<b>860-413-SK-108</b>	Classroom sink, room 413, left sink	<0.1	µg/L
<b>860-413-SK-109</b>	Classroom sink, room 413, right sink	<0.1	µg/L
<b>860-427A-SK-110</b>	Admin workroom sink, room 427A	<0.1	µg/L
<b>860-514-SK-111</b>	Classroom sink, room 514	<0.1	µg/L
<b>860-513A-SK-112</b>	Prep room sink, room 513A	0.2	µg/L

<b>860-513-SK-113</b>	Classroom sink, room 513	0.1	µg/L
<b>860-512-SK-114</b>	Classroom sink, room 512	0.2	µg/L
<b>860-507-SK-115</b>	Classroom sink, room 507	0.2	µg/L
<b>860-507A-SK-116</b>	Classroom sink, room 507A, center island	0.4	µg/L
<b>860-507A-SK-117</b>	Classroom sink, room 507A, north wall	0.3	µg/L
<b>860-507A-SK-118</b>	Classroom sink, room 507A, east wall	0.2	µg/L
<b>860-507B-SK-119</b>	Prep room sink, room 507B	0.6	µg/L
<b>860-506B-SK-120</b>	Admin workroom sink, room 506B	0.2	µg/L
<b>860-502-SK-121</b>	Classroom sink, room 502	<0.1	µg/L
<b>860-520B-SK-122</b>	Admin workroom sink, room 520B	<0.1	µg/L
<b>860-642-SK-123</b>	Admin workroom sink, room 642	<0.1	µg/L
<b>860-622-SK-124</b>	Admin workroom sink, room 622	0.1	µg/L
<b>860-633-SK-125</b>	Admin workroom sink, room 633	<0.1	µg/L
<b>860-604A-SK-126</b>	Admin workroom sink, room 604A	0.3	µg/L
<b>860-658-SK-127</b>	Admin workroom sink, room 658	<0.1	µg/L
<b>860-732-SK-129</b>	Admin breakroom sink, room 732	<0.1	µg/L
<b>860-708-SK-130</b>	Admin breakroom sink, room 708	<0.1	µg/L
<b>860-832-SK-131</b>	Admin breakroom sink, room 832	<0.1	µg/L
<b>860-808-SK-132</b>	Admin breakroom sink, room 808	<0.1	µg/L
<b>860-932-SK-133</b>	Admin breakroom sink, room 932	<0.1	µg/L
<b>860-908-SK-134</b>	Admin breakroom sink, room 908	<0.1	µg/L
<b>860-1032-SK-135</b>	Admin breakroom sink, room 1032	<0.1	µg/L
<b>860-1008-SK-136</b>	Admin breakroom sink, room 1008	<0.1	µg/L
<b>860-1132-SK-137</b>	Admin breakroom sink, room 1132	<0.1	µg/L
<b>860-1108-SK-138</b>	Admin breakroom sink, room 1108	<0.1	µg/L
<b>860-1232-SK-139</b>	Admin breakroom sink, room 1232	<0.1	µg/L
<b>860-1208-SK-140</b>	Admin breakroom sink, room 1208	<0.1	µg/L
<b>860-S1-109-SK-141</b>	Classroom sink, room S1-109	<1.0	µg/L
<b>860-S1-110-SK-142</b>	Classroom sink, room S1-110	<1.0	µg/L
<b>860-425-SK-143</b>	Classroom sink, room 425	<1.0	µg/L
<b>860-510-SK-144</b>	Classroom sink, room 510	<1.0	µg/L
<b>860-509-SK-145</b>	Classroom sink, room 509, far left sink	<1.0	µg/L
<b>860-509-SK-146</b>	Classroom sink, room 509, center left sink	<1.0	µg/L
<b>860-509-SK-147</b>	Classroom sink, room 509, center right sink	<1.0	µg/L
<b>860-509-SK-148</b>	Classroom sink, room 509, far right sink	<1.0	µg/L
<b>860-505-SK-149</b>	Classroom sink, room 505	<1.0	µg/L

\*1. Result less than 0.1 ppb is the lowest level that can be reported by the external lab.

\*2. Result less than 1.0 ppb is the lowest level that can be reported by the lab.