

## Yuma St. – Enterprise Management (895) – Sampled 11/11/2016

All results <15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Sample ID	Sample Description	Lead Result	Units	Action
895-207-SK-01	Lounge sink, second floor, room 207	4.1	µg/L	
895-111-SK-02	Lounge sink, first floor, room 111	0.3	µg/L	
895-111-DF-03	Drinking fountain, lounge 111	0.4	µg/L	
895-103A-DF-04	Drinking fountain, hallway 103A	14.1	µg/L	