

South Acoma (973) – Sampled 11/9/2016

All results <15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Sample ID	Sample Description	Lead Result	Units	Action
973-112D-SK-01	Breakroom sink, room 112D	<1.0*	µg/L	
973-112-DF-02	Drinking fountain, hallway 112, next to restrooms, left bubbler	<1.0	µg/L	
973-112-DF-03	Drinking fountain, hallway 112, next to restrooms, right bubbler	<1.0	µg/L	
973-218-SK-04	Breakroom sink, room 218	<1.0	µg/L	

*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.