

Sandoval Campus Building #3 – Gym (983) – Sampled 11/20/2016

All results <15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Sample ID	Sample Description	Lead Result	Units	Action
983-110-DF-01	Drinking fountain, girls locker room 110, left bubbler	<1.0	µg/L	
983-110-DF-02	Drinking fountain, girls locker room 110, right bubbler	<1.0	µg/L	
983-110-BF-03	Bottle fill, girls locker room 110	<1.0	µg/L	
983-108-DF-04	Drinking fountain, hallway 108, across from room 110, left bubbler	<1.0	µg/L	
983-108-DF-05	Drinking fountain, hallway 108, across from room 110, right bubbler	<1.0	µg/L	
983-108-DF-06	Drinking fountain, hallway 108, across from room 108C, left bubbler	<1.0	µg/L	
983-108-DF-07	Drinking fountain, hallway 108, across from room 108C, right bubbler	<1.0	µg/L	
983-108-BF-08	Bottle fill, hallway 108, across from room 108C	<1.0	µg/L	
983-105-DF-09	Drinking fountain, boys locker room 105, left bubbler	<1.0	µg/L	
983-105-DF-10	Drinking fountain, boys locker room 105, right bubbler	<1.0	µg/L	
983-105-BF-11	Bottle fill, boys locker room 105	<1.0	µg/L	
983-103-DF-12	Drinking fountain, hallway 103, across from room 105, left bubbler	<1.0	µg/L	
983-103-DF-13	Drinking fountain, hallway 103, across from room 105, right bubbler	<1.0	µg/L	

*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.