

DSST College View at Colorado Heights Campus (984)

All results <15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 11/4/2016				
Sample ID	Sample Description	Lead Result	Units	Action
984-326-DF-01	Drinking fountain, hallway 326, across from room 341, left bubbler	0.1	µg/L	
984-326-DF-02	Drinking fountain, hallway 326, across from room 341, right bubbler	0.1	µg/L	
984-327-DF-03	Drinking fountain, hallway 327, next to room 328 and ST-E, left bubbler	<0.1*	µg/L	
984-327-DF-04	Drinking fountain, hallway 327, next to room 328 and ST-E, right bubbler	<0.1	µg/L	
984-300-DF-05	Drinking fountain, hallway 300, next to room 303, left bubbler	<0.1	µg/L	
984-300-DF-06	Drinking fountain, hallway 300, next to room 303, right bubbler	<0.1	µg/L	
984-200-DF-07	Drinking fountain, hallway 200, next to room 202, left bubbler	<0.1	µg/L	
984-200-DF-08	Drinking fountain, hallway 200, next to room 202, right bubbler	0.1	µg/L	
984-STE-DF-09	Drinking fountain, second floor stair E, next to hallway 227, left bubbler	<0.1	µg/L	
984-STE-DF-10	Drinking fountain, second floor stair E, next to hallway 227, right bubbler	<0.1	µg/L	
984-231-DF-11	Drinking fountain, hallway 241, across from room 241, left bubbler	0.1	µg/L	
984-231-DF-12	Drinking fountain, hallway 241, across from room 241, right bubbler	0.1	µg/L	
984-240G-SK-13	Lounge sink, room 240G	0.2	µg/L	
984-240G-DF-14	Bottle filler, room 240G	<0.1	µg/L	
984-100-DF-15	Drinking fountain, hallway 100, next to room 102, left bubbler	<0.1	µg/L	
984-100-DF-16	Drinking fountain, hallway 100, next to room 102, right bubbler	0.2	µg/L	
984-101K-SK-17	Nurse sink, room 101K	0.8	µg/L	
984-101-SK-18	Office lounge sink, room 101	1.1	µg/L	
984-101-DF-19	Bottle filler, room 101	<0.1	µg/L	
Phase II Sampled on 10/4/2017				
984-301-SK-20	Art room sink, room 301, west wall, left sink	0.7	µg/L	
984-301-SK-21	Art room sink, room 301, west wall, center left sink	0.4	µg/L	
984-301-SK-22	Art room sink, room 301, west wall, center right sink	0.4	µg/L	
984-301-SK-23	Art room sink, room 301, west wall, right sink	1.4	µg/L	
984-313-SK-24	Classroom sink, room 313	1.1	µg/L	
984-303-SK-25	Classroom sink, room 303	1	µg/L	
984-343-SK-26	Science lab sink, room 343, north wall, left sink	<1.0	µg/L	
984-343-SK-27	Science lab sink, room 343, north wall, right sink	<1.0	µg/L	
984-343-SK-28	Science lab sink, room 343, east wall, left sink	0.5	µg/L	
984-343-SK-29	Science lab sink, room 343, east wall, right sink	0.9	µg/L	
984-343-SK-30	Science lab sink, room 343, south wall, left sink	0.9	µg/L	
984-343-SK-31	Science lab sink, room 343, south wall, center sink	1.2	µg/L	

984-343-SK-32	Science lab sink, room 343, south wall, right sink	1.1	µg/L
984-343-SK-33	Science lab sink, room 343, demonstration sink	1.4	µg/L
984-339-SK-34	Science lab sink, room 339, west wall, center sink	0.5	µg/L
984-339-SK-35	Science lab sink, room 339, west wall, right sink	0.5	µg/L
984-339-SK-36	Science lab sink, room 339, east wall, right sink	1.6	µg/L
984-339-SK-37	Science lab sink, room 339, east wall, center sink	1.8	µg/L
984-339-SK-38	Science lab sink, room 339, east wall, left sink	1.9	µg/L
984-235-SK-39	Science lab sink, room 339, demonstration sink	1.5	µg/L
984-235-SK-40	Science lab sink, room 235, east wall, left sink	1.0	µg/L
984-235-SK-41	Science lab sink, room 235, east wall, right sink	1.0	µg/L
984-235-SK-42	Science lab sink, room 235, north wall, right sink	1.0	µg/L
984-235-SK-43	Science lab sink, room 235, north wall, center sink	1.0	µg/L
984-235-SK-44	Science lab sink, room 235, north wall, left sink	1.2	µg/L
984-235-SK-45	Science lab sink, room 235, west wall, right sink	1.1	µg/L
984-235-SK-46	Science lab sink, room 235, west wall, left sink	3.5	µg/L
984-234A-SK-47	Science prep sink, room 234A	1.9	µg/L
984-234-SK-48	Science lab sink, room 234, east wall, right sink	1.6	µg/L
984-234-SK-49	Science lab sink, room 234, east wall, left sink	1.4	µg/L
984-234-SK-50	Science lab sink, room 234, north wall, right sink	1.2	µg/L
984-234-SK-51	Science lab sink, room 234, north wall, center sink	1.0	µg/L
984-234-SK-52	Science lab sink, room 234, north wall, left sink	0.4	µg/L
984-234-SK-53	Science lab sink, room 234, west wall, right sink	1.1	µg/L
984-234-SK-54	Science lab sink, room 234, west wall, left sink	1.1	µg/L
984-234-SK-55	Science lab sink, room 234, demonstration sink	2.4	µg/L
984-241-SK-56	Classroom sink, room 241	<1.0	µg/L
984-242-SK-57	Classroom sink, room 242, left sink	<1.0	µg/L
984-242-SK-58	Classroom sink, room 242, right sink	<1.0	µg/L
984-243-SK-59	Classroom sink, room 243	<1.0	µg/L
984-244-SK-60	Classroom sink, room 244	0.4	µg/L
984-245-SK-61	Classroom sink, room 245	0.2	µg/L
984-202-SK-62	Classroom sink, room 202	1.3	µg/L
984-211-SK-63	Classroom sink, room 211	3.7	µg/L
984-201-SK-64	Science lab sink, room 201, south wall, left sink	1.0	µg/L
984-201-SK-65	Science lab sink, room 201, south wall, center sink	1.4	µg/L
984-201-SK-66	Science lab sink, room 201, south wall, right sink	0.8	µg/L
984-201-SK-67	Science lab sink, room 201, west wall, left sink	2.9	µg/L
984-201-SK-68	Science lab sink, room 201, west wall, center sink	1.5	µg/L
984-201-SK-69	Science lab sink, room 201, west wall, right sink	1.8	µg/L
984-201-SK-70	Science lab sink, room 201, north wall, left sink	1.0	µg/L
984-201-SK-71	Science lab sink, room 201, north wall, center sink	3.0	µg/L
984-201-SK-72	Science lab sink, room 201, north wall, right sink	2.9	µg/L
984-201A-SK-73	Science prep sink, room 201A	0.7	µg/L
984-112-SK-74	Classroom sink, room 112	2.0	µg/L

984-102-SK-75

Classroom sink, room 102

1.0

µg/L

*Result less than 0.1 ppb which is the lowest level that can be reported by the lab.