

Sandoval Campus Bldg. #1 - Commons (985)

All results <15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 11/9/2016				
Sample ID	Sample Description	Lead Result	Units	Action
985-105-SK-01	Food prep sink, kitchen 105, north wall	<1.0*	µg/L	
985-100-DF-02	Drinking fountain, hallway 100, left bubbler	<1.0	µg/L	
985-100-DF-03	Drinking fountain, hallway 100, center bubbler	<1.0	µg/L	
985-100-BF-04	Bottle fill, hallway 100	<1.0	µg/L	
985-100-DF-05	Drinking fountain, hallway 100, right bubbler	<1.0	µg/L	
Phase II Sampled on 10/11/2017				
985-105-SK-06	Kitchen prep sink, room 105, east wall	2.6	µg/L	

*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.