

Abraham Lincoln High School (450)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/29/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
450-04-SK-01	Kitchen prep sink, kitchen 04, near south wall	0.9		µg/L	
450-04-SK-02	Kitchen prep sink, kitchen 04, center of room	5.4		µg/L	
450-04-SK-03	Kettle fill, kitchen 04, near north wall	1.3		µg/L	
450-05-SK-04	Concession sink, cafeteria 05, northeast corner	0.6		µg/L	
450-05-DF-05	Drinking fountain, cafeteria 05, north wall, left bubbler	<0.1*		µg/L	
450-05-DF-06	Bottle fill, cafeteria 05, north wall	<0.1		µg/L	
450-05-DF-07	Drinking fountain, cafeteria 05, north wall, middle bubbler	7.0		µg/L	
450-05-DF-08	Drinking fountain, cafeteria 05, north wall, right bubbler	6.7		µg/L	
450-02-DF-09	Drinking fountain, hallway 02, next to room 08, left bubbler	0.5		µg/L	
450-02-DF-10	Bottle fill, hallway 02, next to room 08	0.9		µg/L	
450-02-DF-11	Drinking fountain, hallway 02, next to room 08, right bubbler	0.8		µg/L	
450-23-DF-12	Drinking fountain, auxiliary gymnasium 23, left bubbler	2.8		µg/L	
450-23-DF-13	Drinking fountain, auxiliary gymnasium 23, right bubbler	0.3		µg/L	
450-20-DF-14	Drinking fountain, boys locker room 20, across from 20C, left bubbler	6.5		µg/L	
450-20-DF-15	Drinking fountain, boys locker room 20, across from 20C, right bubbler	7.5		µg/L	
450-01-DF-16	Drinking fountain, hallway 01, next to room 16	1.2		µg/L	
450-014-DF-17	Drinking fountain, hallway 014, next to room 006	6.5		µg/L	
450-101-DF-18	Drinking fountain, hallway 101, across from room 117	5.1		µg/L	
450-101-DF-19	Drinking fountain, hallway 101, next to room 108, left bubbler	0.9		µg/L	
450-101-DF-20	Drinking fountain, hallway 101, next to room 108, right bubbler	1.0		µg/L	
450-112-SK-21	Classroom sink, room 112	6.6		µg/L	
450-102D-SK-22	Admin office sink, room 102D	1.4		µg/L	
450-100-DF-23	Drinking fountain, hallway 100, outside of gymnasium 131A, left bubbler	2.2		µg/L	

450-100-DF-24	Drinking fountain, hallway 100, outside of gymnasium 131A, right bubbler	2.4		µg/L	
450-131B-DF-25	Drinking fountain, gymnasium 131B, northeast corner	1.1		µg/L	
450-132-DF-26	Drinking fountain, auxiliary gymnasium 132, south wall	8.0		µg/L	
450-133-DF-27	Drinking fountain, swim pool 133, southwest corner	5.9		µg/L	
450-135E-SK-28	Admin lounge sink, room 135E	2.0		µg/L	
450-100-DF-29	Drinking fountain, hallway 100, next to room 136, left bubbler	1.6		µg/L	
450-100-DF-30	Drinking fountain, hallway 100, next to room 136, right bubbler	1.0		µg/L	
450-136A-SK-31	PTA kitchen sink, room 136A	29.0	4.0	µg/L	Faucet replaced June 2018
450-234-DF-32	Drinking fountain, hallway 239, next to room 207	2.8		µg/L	
450-239-DF-33	Drinking fountain, hallway 239, across from room 218, left bubbler	0.8		µg/L	
450-239-DF-34	Drinking fountain, hallway 239, across from room 218, right bubbler	1.2		µg/L	
450-239-DF-35	Drinking fountain, hallway 239, across from room 233, left bubbler	3.4		µg/L	
450-239-DF-36	Drinking fountain, hallway 239, across from room 233, right bubbler	2.1		µg/L	
450-239-DF-37	Drinking fountain, hallway 239, next to room 224, left bubbler	1.7		µg/L	
450-239-DF-38	Drinking fountain, hallway 239, next to room 224, right bubbler	2.6		µg/L	
450-340-DF-39	Drinking fountain, hallway 340, across from room 323, left bubbler	2.3		µg/L	
450-340-DF-40	Drinking fountain, hallway 340, across from room 323, right bubbler	1.3		µg/L	
450-323A-SK-41	Staff workroom sink, room 323A	5.5		µg/L	
450-340-DF-42	Drinking fountain, hallway 340, across from room 317	3.5		µg/L	
450-340-DF-43	Drinking fountain, hallway 340, across from room 316, left bubbler	1.8		µg/L	
450-340-DF-44	Drinking fountain, hallway 340, across from room 316, right bubbler	0.9		µg/L	
Phase II Sampled on 10/26/2017					
450-327-SK-45	Science lab sink, room 327, right sink	8.0		µg/L	
450-327-SK-46	Science lab sink, room 327, center sink	11.0		µg/L	
450-327-SK-47	Science lab sink, room 327, left sink	6.0		µg/L	
450-327-SK-48	Science lab sink, room 327, first island, right sink	19.0		µg/L	Science Lab Notice
450-327-SK-49	Science lab sink, room 327, first island, left sink	15.0		µg/L	Science Lab Notice

450-327-SK-50	Science lab sink, room 327, second island, right sink	28.0	µg/L	Science Lab Notice
450-327-SK-51	Science lab sink, room 327, second island, left sink	15.0	µg/L	Science Lab Notice
450-326-SK-52	Science lab sink, room 326, demonstration sink	28.0	µg/L	Science Lab Notice
450-326-SK-53	Science lab sink, room 326, east wall	14.0	µg/L	
450-325-SK-54	Science lab sink, room 325, demonstration sink	15.0	µg/L	Science Lab Notice
450-325-SK-55	Science lab sink, room 325, east wall	19.0	µg/L	Science Lab Notice
450-328-SK-56	Science lab sink, room 328, demonstration sink	<1.0	µg/L	
450-328-SK-57	Science lab sink, room 328, west wall, far left sink	<1.0	µg/L	
450-328-SK-58	Science lab sink, room 328, west wall, center left sink	<1.0	µg/L	
450-328-SK-59	Science lab sink, room 328, west wall, center sink	<1.0	µg/L	
450-328-SK-60	Science lab sink, room 328, west wall, center right sink	<1.0	µg/L	
450-328-SK-61	Science lab sink, room 328, west wall, far right sink	<1.0	µg/L	
450-328-SK-62	Science lab sink, room 328, east wall, left sink	<1.0	µg/L	
450-328-SK-63	Science lab sink, room 328, east wall, center sink	<1.0	µg/L	
450-328-SK-64	Science lab sink, room 328, east wall, right sink	<1.0	µg/L	
450-328A-SK-65	Science lab prep sink, room 328A, south wall	<1.0	µg/L	
450-329-SK-66	Science lab sink, room 329, demonstration sink	<1.0	µg/L	
450-329-SK-67	Science lab sink, room 329, west wall, far left sink	<1.0	µg/L	
450-329-SK-68	Science lab sink, room 329, west wall, center left sink	<1.0	µg/L	
450-329-SK-69	Science lab sink, room 329, west wall, center sink	<1.0	µg/L	
450-329-SK-70	Science lab sink, room 329, west wall, center right sink	<1.0	µg/L	
450-329-SK-71	Science lab sink, room 329, west wall, far right sink	<1.0	µg/L	
450-329-SK-72	Science lab sink, room 329, east wall, left sink	<1.0	µg/L	
450-329-SK-73	Science lab sink, room 329, east wall, center sink	<1.0	µg/L	
450-329-SK-74	Science lab sink, room 329, east wall, right sink	<1.0	µg/L	
450-328A-SK-75	Science lab prep sink , room 328A, north wall	<1.0	µg/L	
450-324-SK-76	Science lab sink, room 324, demonstration sink	15.0	µg/L	Science Lab Notice
450-324-SK-77	Science lab sink, room 324, left sink	11.0	µg/L	
450-324-SK-78	Science lab sink, room 324, center sink	13.0	µg/L	
450-324-SK-79	Science lab sink, room 324, right sink	13.0	µg/L	
450-324A-SK-80	Science prep room sink, room 324A	18.0	µg/L	Science Lab Notice
450-323-SK-81	Science lab sink, room 323, demonstration sink	21.0	µg/L	Science Lab Notice
450-323-SK-82	Science lab sink, room 323, far right sink	7.0	µg/L	
450-323-SK-83	Science lab sink, room 323, center right sink	15.0	µg/L	Science Lab Notice

450-323-SK-84	Science lab sink, room 323, center left sink	20.0		µg/L	Science Lab Notice
450-323-SK-85	Science lab sink, room 323, far left sink	17.0		µg/L	Science Lab Notice
450-322A-SK-86	Science lab prep sink, room 322A	22.0		µg/L	Science Lab Notice
450-322-SK-87	Science lab sink, room 322, demonstration sink	>50.0		µg/L	Science Lab Notice
450-322-SK-88	Science lab sink, room 322, far right sink	39.0		µg/L	Science Lab Notice
450-322-SK-89	Science lab sink, room 322, center right sink	15.0		µg/L	Science Lab Notice
450-322-SK-90	Science lab sink, room 322, center left sink	17.0		µg/L	Science Lab Notice
450-322-SK-91	Science lab sink, room 322, far right sink	16.0		µg/L	Science Lab Notice
450-226-SK-92	Classroom sink, room 226	5.0		µg/L	
450-230-SK-93	Classroom sink, room 230	2.0		µg/L	
450-231-SK-94	Classroom sink, room 231	5.0		µg/L	
450-223D-SK-95	Office sink, room 223D	16.0	11.0	µg/L	Faucet Replaced April 2018
450-110-SK-96	Classroom sink, room 110, island sink	<2.0		µg/L	
450-110-SK-97	Classroom sink, room 110, left sink	2.0		µg/L	
450-110-SK-98	Classroom sink, room 110, right sink	1.0		µg/L	
450-109-SK-99	Classroom sink, room 109, north wall, right sink	<1.0		µg/L	
450-109-SK-100	Classroom sink, room 109, north wall, left sink	<1.0		µg/L	
450-108-SK-101	Classroom sink, room 108	10.0		µg/L	
450-111-SK-102	Classroom sink, room 111, north wall, right sink	2.0		µg/L	
450-111-SK-103	Classroom sink, room 111, north wall, left sink	2.0		µg/L	
450-105-SK-104	Classroom sink, room 105, right sink	4.0		µg/L	
450-105-SK-105	Classroom sink, room 105, center sink	4.0		µg/L	
450-105-SK-106	Classroom sink, room 105, left sink	6.0		µg/L	
450-120-SK-107	Admin office sink, room 120	8.0		µg/L	
450-09-SK-108	Classroom sink, room 09	5.0		µg/L	
450-07C-SK-109	Office sink, room 07C	<1.0		µg/L	
450-11A-SK-110	Office sink, room 11A	1.0		µg/L	
450-06-DF-111	Drinking fountain, room 06	2.0		µg/L	
450-06A-SK-112	Shop utility sink, room 06A	21.0	28.0	µg/L	Faucet Replaced April 2018 – No Drinking Notice
450-35-SK-113	Music room sink, room 35	<1.0		µg/L	

*Result less than 0.1 ppb which is the lowest level that can be reported by the lab.