

Ashley Elementary (206)

All results below 15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 8/26/2016				
Sample ID	Sample Description	Lead Result	Units	Action
206-101D-SK-01	Kitchen sink, east wall, left	2.5	µg/L	
206-101D-SK-02	Kitchen sink, east wall, right	<1.0* ¹	µg/L	
206-H160-DF-03	Drinking fountain, hallway H160, next to cafeteria	1.2	µg/L	
206-H100-DF-04	Drinking fountain, hallway H100, across from room 113, left bubbler	<1.0	µg/L	
206-H100-DF-05	Drinking fountain, hallway H100, across from room 113, right bubbler	1.2	µg/L	
206-107-DF-06	Drinking fountain, gym	<1.0	µg/L	
206-H100-DF-07	Drinking fountain, hallway H100, across from room 122	1.3	µg/L	
206-123A-DF-08	Drinking fountain, hallway 123A, between rooms 120 and 123	<1.0	µg/L	
206-125-DF-09	Drinking fountain, room 125	<1.0	µg/L	
206-127-DF-10	Drinking fountain, room 127	<1.0	µg/L	
206-H200-DF-11	Drinking fountain, hallway H200, next to room 211	2.6	µg/L	
206-H200-DF-12	Drinking fountain, hallway H200, next to room 205	4.3	µg/L	
206-HB04-DF-13	Drinking fountain, hallway HB04, left bubbler	<1.0	µg/L	
206-HB04-DF-14	Drinking fountain, hallway HB04, right bubbler	2.7	µg/L	
Phase II Sampled on 2/3/2017				
206-004-SK-15	Classroom sink, room 004, sink on left	<0.5* ²	µg/L	
206-004-SK-16	Classroom sink, room 004, sink on right	<0.5	µg/L	
206-005-SK-17	Classroom sink, room 005	1.9	µg/L	
206-111B-SK-18	LMC/IMC office sink, room 111B	0.6	µg/L	
206-112-SK-19	Classroom sink, room 112	0.5	µg/L	
206-110-SK-20	Classroom sink, room 110	0.6	µg/L	
206-108-SK-21	Classroom sink, room 108	1.2	µg/L	
206-113-SK-22	Classroom sink, room 113	2.9	µg/L	
206-114-SK-23	Classroom sink, room 114	1.1	µg/L	
206-107-SK-24	Classroom sink, room 107	0.7	µg/L	
206-106A-SK-25	Nurse sink room 106A	0.6	µg/L	
206-101C-SK-26	Faculty lounge sink, room 101C	<0.5	µg/L	
206-117-SK-27	Classroom sink, room 117	8.5	µg/L	
206-118-SK-28	Classroom sink, room 118	5.7	µg/L	
206-119-SK-29	Classroom sink, room 119	2.6	µg/L	

206-102B-SK-30	PTA kitchen sink, room 102B	12.0	µg/L
206-201-SK-31	Classroom sink, room 201	4.8	µg/L
206-210-SK-32	Classroom sink, room 210	9.1	µg/L
206-209-SK-33	Classroom sink, room 209	5.7	µg/L
206-202-SK-34	Classroom sink, room 202	4.4	µg/L
206-203-SK-35	Faculty lounge sink, room 203	1.6	µg/L
206-204-SK-36	Classroom sink, room 204	4.2	µg/L
206-207-SK-37	Classroom sink, room 207	2.2	µg/L
206-205A-SK-38	Faculty workroom sink, room 205A	2.8	µg/L
206-206-SK-39	Classroom sink, room 206	3.2	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

*2. Result less than 0.5 ppb which is the lowest level that can be reported by the external lab.

Updated July 2017