

Barnum Elementary (207)

All results below 15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 8/25/2016				
Sample ID	Sample Description	Lead Result	Units	Action
207-115-SK-01	Sink, room 115	1.7	µg/L	
207-112-DF-02	Drinking fountain, hallway 112 by room 110	<1.0* ¹	µg/L	
207-113-DF-03	Drinking fountain, gym	<1.0	µg/L	
207-121-SK-04	Kitchen kettle faucet	2.8	µg/L	
207-123B-DF-05	Drinking fountain, between rooms 123 and 124	<1.0	µg/L	
207-122-DF-06	Drinking fountain, hallway 122, by room 122A	<1.0	µg/L	
207-125-DF-07	Drinking fountain, room 125	<1.0	µg/L	
207-122-DF-08	Drinking fountain, hallway 122, next to restrooms	<1.0	µg/L	
207-105-SK-09	Sink, room 105	<1.0	µg/L	
207-106-DF-10	Drinking fountain, hallway 106, next to room 107	<1.0	µg/L	
207-112-DF-11	Drinking fountain, hallway 112, next to cafeteria	<1.0	µg/L	
207-128C-SK-12	Lounge sink, room 128C	2.9	µg/L	
207-128AA-SK-13	Nurse sink, room 128AA	8.2	µg/L	
207-215-SK-14	Sink, room 215	<1.0	µg/L	
207-203-DF-15	Drinking fountain, hallway 203, next to room 207	<1.0	µg/L	
207-216-DF-16	Drinking fountain, hallway 216, next to room 217	<1.0	µg/L	
Phase II Sampled on 1/27/2017				
207-118-SK-17	Staff workroom sink, room 118	1.4	µg/L	
207-111-SK-18	Classroom sink, room 111	0.4	µg/L	
207-110-SK-19	Classroom sink, room 110	0.4	µg/L	
207-109-SK-20	Classroom sink, room 109	0.9	µg/L	
207-108-SK-21	Staff workroom sink, room 108	0.9	µg/L	
207-107-SK-22	Classroom sink, room 107, sink on left	0.2	µg/L	
207-107-SK-23	Classroom sink, room 107, sink on right	0.1* ²	µg/L	
207-104-SK-24	Classroom sink, room 104	0.5	µg/L	
207-102-SK-25	Classroom sink, room 102	0.4	µg/L	
207-101-SK-26	Classroom sink, room 101	0.4	µg/L	
207-127-SK-27	Classroom sink, room 127	0.4	µg/L	
207-126-SK-28	Classroom sink, room 126	0.2	µg/L	
207-125-SK-29	Classroom sink, room 125, sink on left	0.3	µg/L	
207-125-SK-30	Classroom sink, room 125, sink on right	0.3	µg/L	
207-124-SK-31	Classroom sink, room 124, sink on left	0.7	µg/L	
207-124-SK-32	Classroom sink, room 124, sink on right	0.3	µg/L	
207-123-SK-33	Classroom sink, room 123, sink on left	0.5	µg/L	

207-123-SK-34	Classroom sink, room 123, sink on right	1.6	µg/L
207-220-SK-35	Classroom sink, room 220	1.3	µg/L
207-218-SK-36	Classroom sink, room 218	0.5	µg/L
207-217-SK-37	Classroom sink, room 217	0.4	µg/L
207-214-SK-38	Classroom sink, room 214	0.3	µg/L
207-213-SK-39	Office sink, room 213	0.4	µg/L
207-209-SK-40	Classroom sink, room 209	0.5	µg/L
207-208-SK-41	Classroom sink, room 208	0.4	µg/L
207-201-SK-42	Classroom sink, room 201	0.2	µg/L
207-202-SK-43	Classroom sink, room 202	0.3	µg/L
207-207-SK-44	Classroom sink, room 207	0.3	µg/L
207-205-SK-45	Classroom sink, room 205	0.3	µg/L

*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

*Result less than 0.1 ppb which is the lowest level that can be reported by the external lab.