

Beach Court Elementary (209)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 8/31/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
209-H100-DF-01	Drinking fountain, hallway H100, near room 113	1.2		µg/L	
209-H100CA-SK-02	Lounge sink, room H100CA	1.5		µg/L	
209-109-SK-03	Sink, room 109	7.2		µg/L	
209-112-SK-04	Sink, room 112	3.4		µg/L	
209-107-SK-05	Sink, room 107	6.3		µg/L	
209-H100-DF-06	Drinking fountain, hallway H100, near main office, left bubbler	<1.0*1		µg/L	
209-H100-DF-07	Bottle filler, hallway H100, near main office	<1.0		µg/L	
209-H100-DF-08	Drinking fountain, hallway H100, near main office, right bubbler	<1.0		µg/L	
209-110-SK-09	Sink, main office, room 110	5.3		µg/L	
209-003-SK-10	Sink, work room 003	30.7	2.0	µg/L	Faucet Replaced 9/17/2018
209-H010-DF-11	Drinking fountain, next to gym	<1.0		µg/L	
209-108-SK-12	Sink, nurse office	3.9		µg/L	
209-105-SK-13	Drinking fountain, room 105	4.2		µg/L	
209-106-SK-14	Sink, room 106	4.1		µg/L	
209-103-SK-15	Sink, room 103	47.8	<1.0	µg/L	Faucet Replaced 9/17/2018
209-H100-DF-16	Drinking fountain, hallway H100, by room 103	3.4		µg/L	
209-104C-DF-17	Drinking fountain, hallway 104C, between rooms 104 and 106	1.7		µg/L	
209-101A-DF-18	Drinking fountain, hallway 101A, between rooms 101 and 102	<1.0		µg/L	
209-102-SK-19	Sink, room 102	4.0		µg/L	
209-101-SK-20	Sink, room 101	3.3		µg/L	
209-201N-SK-21	Sink, room 201N	1.2		µg/L	
209-206-SK-22	Sink, room 206	2.8		µg/L	
209-203-SK-23	Sink, room 203	4.9		µg/L	
209-208-SK-24	Sink, room 208	<1.0		µg/L	
209-205-SK-25	Sink, room 205	<1.0		µg/L	
209-H200C-SK-26	Sink, room 200C, IMC LMC	15.7	8.0	µg/L	Faucet Replaced 9/17/2018
209-STAIRA-DF-27	Drinking fountain, stair A, next to room 207	<1.0		µg/L	
209-H200-DF-28	Drinking fountain, hallway H200, across from room 209	<1.0		µg/L	
209-211-SK-29	Sink, room 211	1.3		µg/L	

209-005A-SK-30	Kitchen prep sink	1.8		µg/L	
209-BLR-SK-31	Utility Sink, boiler room	18.3	N/A	µg/L	No drinking notice posted
Phase II Sampled on 2/9/2017					
209-104-SK-32	Classroom sink, room 104	1.8		µg/L	
209-103-DF-33	Drinking fountain, room 103	1.0		µg/L	
209-113B-SK-34	Nurse sink, room 113B	0.9		µg/L	
209-202-SK-35	Classroom sink, room 202	3.6		µg/L	
209-207-SK-36	Classroom sink, room 207	9.6		µg/L	
209-209-SK-37	Classroom sink, room 209	1.8		µg/L	

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.