

## CEC Early College (605)

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Sample ID	Sample Description	Lead Result	Units	Action
<b>Phase I Sampled on 10/1/2016</b>				
605-127-df-01	Drinking fountain, hallway 127, next to restroom 130, left bubbler	<1.0*	µg/L	
605-127-DF-02	Drinking fountain, hallway 127, next to restroom 130, right bubbler	<1.0	µg/L	
605-123-DF-03	Drinking fountain, hallway 123, next to room 125	<1.0	µg/L	
605-123-DF-04	Bottle fill, hallway 123, next to room 125	<1.0	µg/L	
605-108A-SK-05	Food prep sink, café room 108A	1.3	µg/L	
605-108-SK-06	Beverage fill station, room 108	2.0	µg/L	
605-123-DF-07	Drinking fountain, hallway 123, next to room 125A	<1.0	µg/L	
605-100-SK-08	Classroom sink, room, 100, middle faucet	<1.0	µg/L	
605-102-SK-09	Classroom sink, room 102, north faucet	2.0	µg/L	
605-106-SK-10	Classroom sink, room 106, east wall, on left	4.4	µg/L	
605-106-SK-11	Classroom sink, room 106, southeast corner	1.3	µg/L	
605-118-DF-12	Drinking fountain, room 118	<1.0	µg/L	
605-117-DF-13	Drinking fountain, room 117	<1.0	µg/L	
605-116-DF-14	Drinking fountain, room 116	4.0	µg/L	
605-101-SK-15	Classroom sink, room 101, east wall	1.6	µg/L	
605-101-SK-16	Classroom sink, room 101, northwest corner	<1.0	µg/L	
605-244-DF-17	Drinking fountain, hallway 244, next to restroom 247, left bubbler	<1.0	µg/L	
605-244-DF-18	Drinking fountain, hallway 244, next to restroom 247, right bubbler	<1.0	µg/L	
605-H231-DF-19	Drinking fountain, hallway H231, next to room 225C	<1.0	µg/L	
605-241-SK-20	Nurse sink, room 241	1.2	µg/L	
605-234A-SK-21	Workroom sink, room 234A	1.5	µg/L	
605-H231-DF-22	Drinking fountain, hallway H231, next to room 227C	<1.0	µg/L	
605-H231-DF-23	Bottle fill, hallway H231, next to room 227C	<1.0	µg/L	
605-203-SK-24	Faculty lounge sink, room 203	<1.0	µg/L	
605-204-SK-25	Classroom sink, room 204	2.4	µg/L	
605-200-SK-26	Classroom sink, room 200	1.1	µg/L	
605-136-SK-27	Food prep sink, kitchen 136, west wall	1.5	µg/L	
605-136-SK-28	Food prep sprayer, kitchen 136, west wall	4.8	µg/L	
<b>Phase II Sampled on 10/4/2017</b>				
605-109-SK-29	Classroom sink, room 109, east wall, next to rest rooms	1.3	µg/L	
605-109-SK-30	Classroom sink, room 109, east wall	0.4	µg/L	
605-111-SK-31	Classroom sink, room 111	3.0	µg/L	
605-113B-SK-32	Classroom sink, room 113B	7.0	µg/L	
605-112-SK-33	Classroom sink, room 112	0.6	µg/L	

<b>605-110A-SK-34</b>	Dark room sink, room 110A, east wall, left faucet	18.0	µg/L	Lab Sink – No Drinking Notice
<b>605-110A-SK-35</b>	Dark room sink, room 110A, east wall, right faucet	>50.0	µg/L	Lab Sink – No Drinking Notice
<b>605-110A-SK-36</b>	Dark room sink, room 110A, west wall, left faucet	>50.0	µg/L	Lab Sink – No Drinking Notice
<b>605-110A-SK-37</b>	Dark room sink, room 110A, west wall, right faucet	>50.0	µg/L	Lab Sink – No Drinking Notice
<b>605-100-SK-38</b>	Classroom sink, room 100, east wall, far left sink	1.3	µg/L	
<b>605-100-SK-39</b>	Classroom sink, room 100, east wall, right sink	0.5	µg/L	
<b>605-102-SK-40</b>	Classroom sink, room 102, east wall, center left sink	1.5	µg/L	
<b>605-102-SK-41</b>	Classroom sink, room 102, east wall, center right sink	2.6	µg/L	
<b>605-102-SK-42</b>	Classroom sink, room 102, east wall, far right sink	2.0	µg/L	
<b>605-106-SK-43</b>	Classroom sink, room 106, north wall, left sink	4.0	µg/L	
<b>605-106-SK-44</b>	Classroom sink, room 106, north wall, center sink	1.7	µg/L	
<b>605-106-SK-45</b>	Classroom sink, room 106, north wall, right sink	2.0	µg/L	
<b>605-105-SK-46</b>	Classroom sink, room 105	1.0	µg/L	
<b>605-119F-SK-47</b>	Shop sink, hallway 119F	4.2	µg/L	
<b>605-119G-SK-48</b>	Classroom sink, room 119G	4.2	µg/L	
<b>605-220-SK-49</b>	Science lab sink, room 220, north wall, left sink	3.2	µg/L	
<b>605-220-SK-50</b>	Science lab sink, room 220, north wall, center sink	6.9	µg/L	
<b>605-220-SK-51</b>	Science lab sink, room 220, north wall, right sink	1.9	µg/L	
<b>605-220-SK-52</b>	Science lab sink, room 220, east wall, left sink	18.0	µg/L	Lab Sink – No Drinking Notice
<b>605-220-SK-53</b>	Science lab sink, room 220, south wall, left sink	3.4	µg/L	
<b>605-220-SK-54</b>	Science lab sink, room 220, south wall, center sink	2.4	µg/L	
<b>605-220-SK-55</b>	Science lab sink, room 220, south wall, right sink	24.5	µg/L	Lab Sink – No Drinking Notice
<b>605-222A-SK-56</b>	Science prep sink, room 222A	5.4	µg/L	
<b>605-222-SK-57</b>	Science lab sink, room 222, west wall, left sink	30.6	µg/L	Lab Sink – No Drinking Notice
<b>605-222-SK-58</b>	Science lab sink, room 222, west wall, right sink	3.4	µg/L	
<b>605-222-SK-59</b>	Science lab sink, room 222, north wall, far left sink	24.1	µg/L	Lab Sink – No Drinking Notice
<b>605-222-SK-60</b>	Science lab sink, room 222, north wall, second left sink	11.6	µg/L	
<b>605-222-SK-61</b>	Science lab sink, room 222, north wall, center left sink	14.4	µg/L	
<b>605-222-SK-62</b>	Science lab sink, room 222, north wall, center right sink	11.0	µg/L	
<b>605-222-SK-63</b>	Science lab sink, room 222, north wall, second right sink	13.0	µg/L	
<b>605-222-SK-64</b>	Science lab sink, room 222, north wall, far right sink	8.1	µg/L	
<b>605-222-SK-65</b>	Science lab sink, room 222, east wall, left sink	6.8	µg/L	
<b>605-222-SK-66</b>	Science lab sink, room 222, east wall, right sink	13.6	µg/L	
<b>605-222-SK-67</b>	Science lab sink, room 222, south wall	2.0	µg/L	
<b>605-224-SK-68</b>	Classroom sink, room 224	0.7	µg/L	
<b>605-209-SK-69</b>	Classroom sink, room 209	0.5	µg/L	

---

<b>605-211-SK-70</b>	Classroom sink, room 211	0.7	µg/L
<b>605-201-SK-71</b>	Admin office sink, room 201	2.0	µg/L
<b>605-218B-SK-72</b>	Workroom sink, room 218B	2.0	µg/L
<b>605-252C-SK-73</b>	LMC/IMC workroom sink, room 252C	1.0	µg/L

\*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.