

## Castro Elementary (287)

All results <15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/29/2016				
Sample ID	Sample Description	Lead Result	Units	Action
287-121A-SK-01	Kitchen sink, north wall, left faucet	1.9	µg/L	
287-121A-SK-02	Kitchen sink, north wall, center faucet	<1.0* <sup>1</sup>	µg/L	
287-121A-SK-03	Kitchen sink, north wall, right faucet	<1.0	µg/L	
287-121A-SK-04	Kitchen sink, island	3.2	µg/L	
287-121A-SK-05	Kitchen sink, south wall	1.0	µg/L	
287-121-DF-06	Drinking fountain, all purpose room, left fixture	<1.0	µg/L	
287-121-DF-07	Drinking fountain, all purpose room, right fixture	<1.0	µg/L	
287-123-SK-08	Sink, staff community room 123	1.0	µg/L	
287-124-DF-09	Drinking fountain, hallway 124, north of gym, left bubbler	<1.0	µg/L	
287-124-DF-10	Drinking fountain, hallway 124, north of gym, right bubbler	<1.0	µg/L	
287-119-DF-11	Drinking fountain, gymnasium	<1.0	µg/L	
287-124-DF-12	Drinking fountain, hallway 124, next to rest rooms, left bubbler	<1.0	µg/L	
287-124-DF-13	Drinking fountain, hallway 124, next to rest rooms, right bubbler	<1.0	µg/L	
287-116-SK-14	Classroom sink, room 116	5.7	µg/L	
287-111-SK-15	Classroom sink, room 111, on right	1.5	µg/L	
287-112-SK-16	Classroom sink, room 112, on left	7.4	µg/L	
287-110-SK-17	Classroom sink, room 110, on left	<1.0	µg/L	
287-109-SK-18	Classroom sink, room 109, on right	4.8	µg/L	
287-104-SK-19	Classroom sink, room 104, on left	<1.0	µg/L	
287-104B-DF-20	Drinking fountain, hall 104B, between rooms 104 and 105	<1.0	µg/L	
287-101F-SK-21	Nurse sink, room 101F	4.0	µg/L	
287-154-DF-22	Drinking fountain, hallway 154, across from room 155, left bubbler	<1.0	µg/L	
287-154-DF-23	Drinking fountain, hallway 154, across from room 155, right bubbler	<1.0	µg/L	
287-157-SK-24	Classroom sink, room 157	1.8	µg/L	
287-140-DF-25	Drinking fountain, hallway 140, across from room 145, right bubbler	<1.0	µg/L	
287-140-DF-26	Drinking fountain, hallway 140, across from room 145, left bubbler	<1.0	µg/L	
287-125-DF-27	Drinking fountain, hallway 125, across from room 131, left bubbler	1.3	µg/L	
287-125-DF-28	Drinking fountain, hallway 125, across from room 131, right bubbler	1.2	µg/L	
287-129-SK-29	Classroom sink, room 129	2.9	µg/L	
287-100G-SK-30	Staff lounge sink, room 100G	<1.0	µg/L	
287-100-DF-31	Drinking fountain, hallway 100, across from LMC, left bubbler	<1.0	µg/L	
287-100-DF-32	Drinking fountain, hallway 100, across from LMC, right bubbler	<1.0	µg/L	

**Phase II Sampled on 4/19/2017**

<b>287-153-SK-33</b>	Classroom sink, room 153	3.0	µg/L
<b>287-151-SK-34</b>	Classroom sink, room 151	4.0	µg/L
<b>287-150-SK-35</b>	Classroom sink, room 150	1.0	µg/L
<b>287-149-SK-36</b>	Classroom sink, room 149	3.0	µg/L
<b>287-155-SK-37</b>	Classroom sink, room 155	4.0	µg/L
<b>287-146-SK-38</b>	Classroom sink, room 146, right sink	<1.0	µg/L
<b>287-146-DF-39</b>	Drinking fountain, room 146	12.0	µg/L
<b>287-146-SK-40</b>	Classroom sink, room 146, left sink	<1.0	µg/L
<b>287-145-SK-41</b>	Classroom sink, room 145	1.0	µg/L
<b>287-144-SK-42</b>	Classroom sink, room 144	1.0	µg/L
<b>287-142-SK-43</b>	Classroom sink, room 142	3.0	µg/L
<b>287-141-SK-44</b>	Classroom sink, room 141	2.0	µg/L
<b>287-140-SK-45</b>	Classroom sink, room 140	2.0	µg/L
<b>287-138-SK-46</b>	Classroom sink, room 138	<1.0	µg/L
<b>287-137-SK-47</b>	Classroom sink, room 137	<1.0	µg/L
<b>287-136-SK-48</b>	Classroom sink, room 136	<1.0	µg/L
<b>287-130-SK-49</b>	Classroom sink, room 130	1.0	µg/L
<b>287-128-SK-51</b>	Classroom sink, room 128	5.0	µg/L
<b>287-126-SK-52</b>	Classroom sink, room 126	13.0	µg/L
<b>287-126-SK-53</b>	Classroom sink, room 126	14.0	µg/L
<b>287-127-SK-54</b>	Classroom sink, room 127	1.0	µg/L
<b>287-117-SK-55</b>	Classroom sink, room 117	3.0	µg/L
<b>287-118A-SK-57</b>	LMC/IMC office sink, room 118A	1.0	µg/L
<b>287-114-SK-58</b>	Classroom sink, room 114	<1.0	µg/L
<b>287-112-SK-59</b>	Classroom sink, room 112	<1.0	µg/L
<b>287-110-SK-60</b>	Classroom sink, room 110, right sink	1.0	µg/L
<b>287-109-SK-61</b>	Classroom sink, room 109, left sink	2.0	µg/L
<b>287-104-SK-62</b>	Classroom sink, room 104, right sink	1.0	µg/L
<b>287-105-SK-63</b>	Classroom sink, room 105, left sink	1.0	µg/L
<b>287-105-SK-64</b>	Classroom sink, room 105, right sink	<1.0	µg/L
<b>287-161-SK-65</b>	Classroom sink, room 161	5.0	µg/L
<b>287-160-SK-66</b>	Classroom sink, room 160	2.0	µg/L
<b>287-159-SK-67</b>	Classroom sink, room 159	6.0	µg/L
<b>287-158-SK-68</b>	Classroom sink, room 158	1.0	µg/L
<b>287-134-SK-69</b>	Classroom sink, room 134	3.0	µg/L
<b>287-133-SK-70</b>	Classroom sink, room 133	<1.0	µg/L
<b>287-131-SK-71</b>	Classroom sink, room 131	<1.0	µg/L
<b>287-152-SK-72</b>	Admin office sink, room 152	5.0	µg/L

\*1. Result less than 1.0 ppb is the lowest level that can be reported by the lab.