

## College View Elementary (220)

All results less than 15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase II Sampled on 9/29/2016				
Sample ID	Sample Description	Lead Result	Units	Action
220-K1-SK-01	Kitchen sink, east wall, left faucet	1.6	µg/L	
220-K1-SK-02	Kitchen sink, east wall, right faucet	1.6	µg/L	
220-K1-SK-03	Kitchen sink, north wall	<1.0* <sup>1</sup>	µg/L	
220-K1-SK-04	Kitchen, kettle fill	1.6	µg/L	
220-113-DF-05	Drinking fountain, all purpose room, north wall	<1.0	µg/L	
220-HC7-DF-06	Drinking fountain, hall HC7, across from gym, left fixture	<1.0	µg/L	
220-HC7-DF-07	Drinking fountain, hall HC7, across from gym, right fixture	<1.0	µg/L	
220-112-DF-08	Drinking fountain, gymnasium, west wall	<1.0	µg/L	
220-N-101-DF-09	Drinking fountain, room N-101, attached to sink	<1.0	µg/L	
220-N-108-DF-10	Drinking fountain, room N-108, attached to sink	<1.0	µg/L	
220-111-DF-11	Drinking fountain, room 111	<1.0	µg/L	
220-106-DF-12	Drinking fountain, room 112	<1.0	µg/L	
220-HC1-DF-13	Drinking fountain, hall HC1/lobby, across from main office, left fixture	<1.0	µg/L	
220-HC1-DF-14	Drinking fountain, hall HC1/lobby, across from main office, right fixture	<1.0	µg/L	
220-135-SK-15	Staff lounge sink, room 135	<1.0	µg/L	
220-132-SK-16	Staff lounge sink, room 132	<1.0	µg/L	
220-115G-SK-17	Nurse sink, room 115G	<1.0	µg/L	
220-115-DF-18	Bottle fill, room 115	<1.0	µg/L	
220-131B-SK-19	LMC office sink, room 131B	<1.0	µg/L	
220-RR-DF-20	Drinking fountain, hall RR, south of room 124, left fixture	<1.0	µg/L	
220-RR-DF-21	Drinking fountain, hall RR, south of room 124, right fixture	<1.0	µg/L	
220-104-SK-22	Classroom sink, room 104	<1.0	µg/L	
220-103-SK-23	Classroom sink, room 103	<1.0	µg/L	
220-102A-DF-24	Drinking fountain, room 102A, between rooms 102 and 103	<1.0	µg/L	
220-102-SK-25	Classroom sink, room 102, right fixture	<1.0	µg/L	
220-102-SK-26	Classroom sink, room 102, left fixture	<1.0	µg/L	
220-101-DF-27	Drinking fountain, room 101	<1.0	µg/L	
220-101-SK-28	Classroom sink, room 101, left fixture	<1.0	µg/L	
220-101-SK-29	Classroom sink, room 101, right fixture	<1.0	µg/L	
Phase II Sampled on 4/19/2017				
220-N101-SK-30	Classroom sink, room N101	2.0	µg/L	
220-N108-SK-31	Classroom sink, room N108	<1.0	µg/L	
220-111-SK-32	Classroom sink, room 111	<1.0	µg/L	
220-110-SK-33	Classroom sink, room 110	<1.0	µg/L	
220-104-SK-34	Classroom sink, room 104	<1.0	µg/L	

<b>220-105-SK-35</b>	Classroom sink, room 105	<1.0	µg/L
<b>220-109-SK-36</b>	Classroom sink, room 109	<1.0	µg/L
<b>220-108-SK-37</b>	Classroom sink, room 108	<1.0	µg/L
<b>220-106-SK-38</b>	Classroom sink, room 106	<1.0	µg/L
<b>220-107-SK-39</b>	Classroom sink, room 107	<1.0	µg/L
<b>220-121-SK-40</b>	Classroom sink, room 121	<1.0	µg/L
<b>220-122-SK-41</b>	Classroom sink, room 122	<1.0	µg/L
<b>220-123-SK-42</b>	Classroom sink, room 123	<1.0	µg/L
<b>220-124-SK-43</b>	Classroom sink, room 124	<1.0	µg/L
<b>220-125-SK-44</b>	Classroom sink, room 125	<1.0	µg/L
<b>220-130-SK-45</b>	Classroom sink, room 130	<1.0	µg/L
<b>220-129-SK-46</b>	Classroom sink, room 129	<1.0	µg/L
<b>220-128-SK-47</b>	Classroom sink, room 128	<1.0	µg/L
<b>220-127-SK-48</b>	Classroom sink, room 127	<1.0	µg/L
<b>220-126-SK-49</b>	Classroom sink, room 126	<1.0	µg/L

\*1. Result less than 1.0 ppb is the lowest level that can be reported by the lab.