

DCIS @ Baker (401)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
Phase I Sampled 10/27/2016					
401-136-DF-01	Drinking fountain, cafeteria 136, south wall, left bubbler	7.0		µg/L	
401-136-DF-02	Drinking fountain, cafeteria 136, south wall, right bubbler	5.0		µg/L	
401-137-SK-03	Kitchen kettle fill, center of room 137, next to steam kettle	>50.0	N/A	µg/L	Removed
401-137-SK-04	Kitchen prep sink, room 137, east wall	3.0		µg/L	
401-139-DF-05	Drinking fountain, west gymnasium 139, west wall	10.0		µg/L	
401-103-SK-06	Community room sink, room 103	2.0		µg/L	
401-100-DF-07	Drinking fountain, hallway 100, across from room 101B	1.0		µg/L	
401-101D-SK-08	Nurse sink, room 101D	5.0		µg/L	
401-106-SK-09	Admin office sink, room 106	3.0		µg/L	
401-100H-DF-10	Drinking fountain, hallway 100H, across from auditorium	11.0		µg/L	
401-106A-SK-11	Admin office sink, room 106A	5.0		µg/L	
401-109-SK-12	Classroom sink, room 109	3.0		µg/L	
401-100-BF-13	Bottle fill, hallway 100, next to room 110D	<1.0		µg/L	
401-108-DF-14	Drinking fountain, hallway 108, across from room 118	3.0		µg/L	
401-H200-BF-15	Bottle fill, hallway H200, across from room 218B	2.0		µg/L	
401-H204-DF-16	Bottle fill, hallway H204, next to room 210A	2.0		µg/L	
401-H204-DF-17	Drinking fountain, hallway H204, across from room 202A, left bubbler	4.0		µg/L	
401-H204-DF-18	Drinking fountain, hallway H204, across from room 202A, right bubbler	3.0		µg/L	
401-201BA-SK-19	Office sink, room 201B	8.0		µg/L	
Phase II Sampled 9/21/2017					
401-107-SK-20	Classroom sink, room 107	1.6		µg/L	
401-106B-SK-21	Office sink, room 106B	0.5		µg/L	
401-101C-SK-22	Nurse sink, room 101C	14.0		µg/L	
401-140C-SK-23	Gym office sink, room 140C	14.0		µg/L	
401-138B-SK-24	Gym office sink, room 138B	12.0		µg/L	
401-117-SK-25	Classroom sink, room 117	22.0	23.0	µg/L	Faucet replaced 4/2018; failed follow up – No drinking notice
401-IMCA-SK-26	LMC/IMC office sink, room IMCA	16.0	12.0	µg/L	Faucet replaced 4/2018
401-201A-SK-27	Classroom sink, room 201A	7.0		µg/L	

401-223-SK-28	Science lab sink, room 223, south wall	8.0	µg/L	
401-223-SK-29	Science lab sink, room 223, north wall, left sink	17.0	µg/L	Science Lab Notice
401-223-SK-30	Science lab sink, room 223, north wall, right sink	15.0	µg/L	Science Lab Notice
401-222A-SK-31	Science prep sink, room 222A	>50.0	µg/L	Science Lab Notice
401-222-SK-32	Science lab sink, room 222, north wall, right sink	12.3	µg/L	
401-222-SK-33	Science lab sink, room 222, south wall, left sink	10.0	µg/L	
401-222-SK-34	Science lab sink, room 222, south wall, right sink	16.0	µg/L	Science Lab Notice
401-220-SK-35	Science lab sink, room 220, north wall, left sink	30.0	µg/L	Science Lab Notice
401-220-SK-36	Science lab sink, room 220, north wall, right sink	18.0	µg/L	Science Lab Notice
401-220-SK-37	Science lab sink, room 220, south wall, left sink	13.0	µg/L	
401-220-SK-38	Science lab sink, room 220, south wall, right sink	26.0	µg/L	Science Lab Notice
401-215-SK-39	Science lab sink, room 215, south wall, left sink	36.0	µg/L	Science Lab Notice
401-215-SK-40	Science lab sink, room 215, south wall, right sink	18.0	µg/L	Science Lab Notice
401-215-SK-41	Science lab sink, room 215, north wall, left sink	19.0	µg/L	Science Lab Notice
401-215-SK-42	Science lab sink, room 215, north wall, right sink	16.4	µg/L	Science Lab Notice
401-216A-SK-43	Classroom sink, room 216A, east wall, left sink	2.4	µg/L	
401-216A-SK-44	Classroom sink, room 216A east wall, right sink	5.0	µg/L	
401-217B-SK-45	Classroom sink, room 217B	11.0	µg/L	
401-216B-SK-46	Classroom sink, room 216B, left sink	4.0	µg/L	
401-216B-SK-47	Classroom sink, room 216B, center sink	3.0	µg/L	
401-216B-SK-48	Classroom sink, room 216B, right sink	10.0	µg/L	

*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.