

DCIS @ Fairmont Elementary (237)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 8/26/2016

Sample ID	Sample Description	Lead Result	Flush Sample Result	Units	Action
237-103DF-01	Drinking fountain, hallway 103, left bubbler	<1.0*1		µg/L	
237-103-DF-02	Drinking fountain, hallway 103, right bubbler	<1.0		µg/L	
237-104-SK-03	Sink, room 104	<1.0		µg/L	
237-101A-SK-04	Nurse sink, room 101A	1.3		µg/L	
237-100-DF-05	Drinking fountain, hallway 100, outside of gym, left bubbler	<1.0		µg/L	
237-107-DF-06	Drinking fountain, gym, east wall	<1.0		µg/L	
237-107-DF-07	Drinking fountain, gym, west wall	<1.0		µg/L	
237-107-DF-08	Bottle filler, gym, east wall	9.7		µg/L	
237-109-DF-09	Drinking fountain, hallway 109, left bubbler	<1.0		µg/L	
237-109-DF-10	Drinking fountain, hallway 109, right bubbler	<1.0		µg/L	
237-110-SK-11	Sink, room 110	1.3		µg/L	
237-106-DF-12	Drinking fountain, hallway 106, left bubbler	<1.0		µg/L	
237-106-DF-13	Drinking fountain, hallway 106, right bubbler	<1.0		µg/L	
237-106-DF-14	Bottle filler, hallway 106	<1.0		µg/L	
237-122-SK-15; 237-122-SK-31-FL	Kitchen, kettle filler	27.6 (1.0*2 Flush)	Pending	µg/L	Flush notice posted, Replaced 7/2018
237-122-SK-16	Kitchen sink, east wall	2.7		µg/L	
237-122-SK-17	Kitchen sink, south wall	1.1		µg/L	
237-151-SK-18	Sink, room 151	1.4		µg/L	
237-149-SK-19	Sink, room 149	2.7		µg/L	
237-150-SK-20	Sink, room 150	2.4		µg/L	
237-130-DF-21	Drinking fountain, hallway 130, left bubbler	3.2		µg/L	
237-130-DF-22	Drinking fountain, hallway 130, right bubbler	1.3		µg/L	
237-144-DF-23	Drinking fountain, hallway 144, left bubbler	7.8		µg/L	
237-144-DF-24	Drinking fountain, hallway 144, right bubbler	3.0		µg/L	
237-137-DF-25	Drinking fountain, hallway 137, left bubbler	5.0		µg/L	
237-137-DF-26	Drinking fountain, hallway 137, right bubbler	3.8		µg/L	
237-230-DF-27	Drinking fountain, hallway 230, left bubbler	<1.0		µg/L	
237-230-DF-28	Drinking fountain, hallway 230, right bubbler	<1.0		µg/L	
237-220-DF-29	Drinking fountain, hallway 220, left bubbler	<1.0		µg/L	
237-220-DF-30	Drinking fountain, hallway 220, right bubbler	<1.0		µg/L	

Phase II Sampled on 2/3/2017

237-006B-SK-32	Bookstore room sink, room 006B	3.3		µg/L	
237-105B-SK-34	Admin office sink, room 105B	2.7		µg/L	
237-139-SK-35	Classroom sink, room 139	5.6		µg/L	
237-140-SK-36	Classroom sink, room 140	13		µg/L	
237-141-SK-37	Classroom sink, room 141	2.8		µg/L	

237-142-SK-38	Classroom sink, room 142	6.6	µg/L
237-143-SK-39	Classroom sink, room 143	3.3	µg/L
237-145-SK-40	Classroom sink, room 145	5.0	µg/L
237-146-SK-41	Classroom sink, room 146	5.1	µg/L
237-147-SK-42	Classroom sink, room 147	2.6	µg/L
237-135-SK-43	Classroom sink, room 135	4.6	µg/L
237-133-SK-44	Classroom sink, room 133	4.4	µg/L
237-134-SK-45	Classroom sink, room 134	9.6	µg/L
237-131-SK-46	Classroom sink, room 131	3.1	µg/L
237-149A-DF-47	Drinking fountain, room 149A	3.0	µg/L
237-206-SK-48	Classroom sink, room 206	<0.5* ³	µg/L
237-201-SK-49	Classroom sink, room 201	0.9	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

*2. Follow up samples field tested with a Palintest SA1100 scanning analyzer.

*3. Result less than 0.5 ppb which is the lowest level that can be reported by the external lab.