

Denver School of the Arts (475)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Sample ID	Sample Description	Lead Result	Units	Action
Phase I Sampled on 11/9/2016				
475-17-DF-01	Drinking fountain, room 017, next to sink	0.6	µg/L	
475-18-DF-02	Drinking fountain, room 018, next to sink	0.3	µg/L	
475-010-DF-03	Drinking fountain, hallway 010, next to 010A, left bubbler	0.6	µg/L	
475-010-DF-04	Drinking fountain, hallway 010, right bubbler	1.6	µg/L	
475-132A-SK-05	Faculty workroom sink, room 132A	0.2	µg/L	
475-100-DF-06	Drinking fountain, hallway 100, next to restroom 100M	<0.1	µg/L	
475-137-SK-07	Classroom sink, room 137	0.4	µg/L	
475-138-DF-08	Drinking fountain, room 138, next to sink	1.5	µg/L	
475-140B-SK-09	LMC/IMC sink, room 140B	2.8	µg/L	
475-141-DF-10	Drinking fountain, hallway 141, next to auditorium stage 142	5.5	µg/L	
475-123A-SK-11	Faculty workroom sink, room 123A	0.7	µg/L	
475-100-DF-12	Drinking fountain, hallway 100, next to restroom 100G	0.1	µg/L	
475-100-DF-13	Drinking fountain, hallway 100, next to 117	0.8	µg/L	
475-144-DF-14	Bottle fill, hallway 144, next to restroom 144C	<0.1	µg/L	
475-144-DF-15	Drinking fountain, hallway 144, next to restroom 144C	<0.1	µg/L	
475-157-DF-16	Drinking fountain, hallway 157, next to auditorium stage 150	0.6	µg/L	
475-100-DF-17	Bottle fill, hallway 100, next to restroom 100D	<0.1	µg/L	
475-100-DF-18	Drinking fountain, hallway 100, next to restroom 100D	<0.1	µg/L	
475-114A-SK-19	Faculty workroom sink, room 114A	0.3	µg/L	
475-108AA-SK-20	Nurse sink, room 108AA	0.5	µg/L	
475-104-SK-21	Faculty lounge sink, room 104	0.3	µg/L	
475-103E-SK-22	Food prep sink, kitchen 103E, west wall, left faucet	0.6	µg/L	
475-103E-SK-23	Food prep sink, kitchen 103E, west wall, right faucet	1.1	µg/L	
475-222A-SK-24	Faculty workroom sink, room 222A	0.2	µg/L	
475-200-DF-25	Drinking fountain, hallway 200, next to restroom 200P	0.1	µg/L	
475-216A-SK-26	Faculty workroom sink, room 216A	0.3	µg/L	
475-200-DF-27	Bottle fill, hallway 200, next to restroom 200K	<0.1	µg/L	
475-200-DF-28	Drinking fountain, hallway 200, next to restroom 200K	<0.1	µg/L	
475-208A-SK-29	Faculty workroom sink, room 209A	0.4	µg/L	
475-200-DF-30	Drinking fountain, hallway 200, next to restroom 200C	0.2	µg/L	
475-203A-SK-31	Faculty workroom sink, room 203A	0.3	µg/L	
Phase II Sampled on 10/11/2017				
475-017-SK-32	Music room sink, room 017	2.2	µg/L	

475-018-SK-33	Music room sink, room 018	0.8	µg/L	
475-134-SK-34	Science lab sink, room 134, south wall	0.6	µg/L	
475-134-SK-35	Science lab sink, room 134, west wall, left sink	1.1	µg/L	
475-134-SK-36	Science lab sink, room 134, west wall, right sink	1.3	µg/L	
475-134-SK-37	Science lab sink, room 134, north wall	1.3	µg/L	
475-134-SK-38	Science lab sink, room 134, island demonstration sink	13.1	µg/L	
475-136-SK-39	Music room sink, room 136	3.0	µg/L	
475-138-SK-40	Music room sink, room 138	1.4	µg/L	
475-125-SK-41	Science lab sink, room 125, south wall	0.5	µg/L	
475-125-SK-42	Science lab sink, room 125, west wall, left sink	1.7	µg/L	
475-125-SK-43	Science lab sink, room 125, west wall, right sink	11.6	µg/L	
475-125-SK-44	Science lab sink, room 125, north wall	1.0	µg/L	
475-125-SK-45	Science lab sink, room 125, island demonstration sink	2.0	µg/L	
475-152-SK-46	Auditorium storage room sink, room 152	0.5	µg/L	
475-160-SK-47	Shop sink, room 160	0.7	µg/L	
475-161-SK-48	Shop sink, room 161	0.7	µg/L	
475-156-SK-49	Storage room sink, room 156	2.2	µg/L	
475-112-SK-50	Science lab sink, room 112, south wall	2.0	µg/L	
475-112-SK-51	Science lab sink, room 112, east wall, right sink	1.1	µg/L	
475-112-SK-52	Science lab sink, room 112, east wall, left sink	0.7	µg/L	
475-112-SK-53	Science lab sink, room 112, north wall	1.8	µg/L	
475-112-SK-54	Science lab sink, island demonstration sink	0.6	µg/L	
475-161A-SK-55	Art storage sink, room 161A	1.4	µg/L	
475-162-SK-56	Art room sink, room 162	1.1	µg/L	
475-162C-SK-57	Art prep room sink, room 162C	0.8	µg/L	
475-162AA-SK-58	Art storage room sink, room 162AA	0.8	µg/L	
475-163-SK-59	Art room sink, room 163, left sink	1.1	µg/L	
475-163-SK-60	Art room sink, room 163, right sink	0.9	µg/L	
475-224-SK-61	Science lab sink, room 224, south wall	1.2	µg/L	
475-224-SK-62	Science lab sink, room 224, west wall, left sink	1.0	µg/L	
475-224-SK-63	Science lab sink, room 224, west wall, right sink	1.1	µg/L	
475-224-SK-64	Science lab sink, room 224, north wall	1.4	µg/L	
475-224A-SK-65	Science prep sink, room 224A	25.7	µg/L	Lab Sink - No Drinking Notice
475-218-SK-66	Science lab sink, room 218, west wall, left sink	0.4	µg/L	
475-218-SK-67	Science lab sink, room 218, west wall, right sink	0.6	µg/L	
475-218-SK-68	Science lab sink, room 218, north wall	0.8	µg/L	
475-218-SK-69	Science lab sink, room 218, demonstration sink	0.8	µg/L	
475-218A-SK-70	Science prep sink, room 218A	7.4	µg/L	
475-206-SK-71	Science lab sink, room 206, demonstration sink	1.6	µg/L	
475-206-SK-72	Science lab sink, room 206, north wall	0.5	µg/L	
475-206-SK-73	Science lab sink, room 206, east wall, left sink	6.3	µg/L	
475-206-SK-74	Science lab sink, room 206, east wall, center sink	0.9	µg/L	

475-206-SK-75	Science lab sink, room 206, east wall, right sink	1.8	µg/L
475-206-SK-76	Science lab sink, room 206, south wall	1.3	µg/L
475-206A-SK-77	Science prep sink, room 206A	2.1	µg/L
475-201-SK-78	Science lab sink, room 201, west wall	1.4	µg/L
475-201-SK-79	Science lab sink, room 201, north wall	1.8	µg/L
475-201-SK-80	Science lab sink, room 201, south wall	3.0	µg/L
475-201A-SK-81	Science prep sink, room 201A	1.7	µg/L
475-228-SK-82	Classroom sink, room 228	0.7	µg/L

*Result less than 0.1 ppb which is the lowest level that can be reported by the lab.