

DSST Cole MS @ Mitchell Elementary (255)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/21/16					
Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
255-103-DF-01	Drinking fountain, hallway 103, outside of gym	<1.0* ¹		µg/L	
255-104-DF-02	Drinking fountain, gym	<1.0		µg/L	
255-103-DF-03	Drinking fountain, hallway 103, next to restrooms	1.6		µg/L	
255-126-DF-04	Drinking fountain, hallway 126, across from room 129, left bubbler	<1.0		µg/L	
255-126-DF-05	Drinking fountain, hallway 126, across from room 129, right bubbler	<1.0		µg/L	
255-106-DF-06	Drinking fountain, hallway 106, across from room 122	4.0		µg/L	
255-116-DF-07	Drinking fountain, cafeteria, left bubbler	8.7		µg/L	
255-116-DF-08	Drinking fountain, cafeteria, right bubbler	7.6		µg/L	
255-114A-DF-09	Drinking fountain, hall 114A, next to custodial office	13.3		µg/L	
255-200-DF-10	Drinking fountain, hallway 200, next to room 205	6.0		µg/L	
255-200-DF-11	Drinking fountain, hallway 200, next to room 201	3.3		µg/L	
255-117-SK-12	Kitchen sink, west wall	<1.0		µg/L	
Phase II Sampled on 3/15/17* ²					
255-101F-SK-13	Admin office sink, room 101F	0.3		µg/L	
255-131-SK-14	Classroom sink, room 131, left sink	0.1		µg/L	
255-131-SK-15	Classroom sink, room 131, middle sink	0.2		µg/L	
255-131-SK-16	Classroom sink, room 131, right sink	0.2		µg/L	
255-130-SK-17	Classroom sink, room 130	7.8		µg/L	
255-128-SK-18	Classroom sink, room	7.6		µg/L	
255-125-SK-19	Classroom sink, room 125	1.6		µg/L	
255-124-SK-20	Classroom sink, room 124	2.3		µg/L	
255-123-SK-21	Classroom sink, room 123	3.1		µg/L	
255-105-SK-22	Classroom sink, room 105, north wall, on left	0.2		µg/L	
255-122-SK-23	Classroom sink, room 122, south wall	17.2	8.0	µg/L	Replaced 7/2017
255-122-SK-24	Classroom sink, room 122, east wall	10.2		µg/L	
255-121-SK-25	Classroom sink, room 121	11.3		µg/L	
255-120-SK-26	Classroom sink, room 120	7.3		µg/L	
255-119-SK-27	Classroom sink, room 119	6.3		µg/L	
255-113-SK-28	Community room sink, room 113	6.6		µg/L	
255-112-SK-29	Classroom sink, room 112	11.3		µg/L	
255-107-SK-30	Classroom sink, room 107	5.2		µg/L	
255-205-SK-31	Classroom sink, room 205	0.3		µg/L	

255-203-SK-32	Classroom sink, room 203	16.8	9.0	µg/L	Replaced 7/2017
255-202-SK-33	Classroom sink, room 202	8.7		µg/L	
255-201-SK-34	Classroom sink, room 201	11.1		µg/L	
255-209-SK-35	Resource room sink, room 209	2.9		µg/L	
255-208-SK-36	Classroom sink, room 208	6.1		µg/L	
255-207-SK-37	Classroom sink, room 207	>50.0	12.0	µg/L	Replaced 7/2017
255-206-SK-38	Classroom sink, room 206	14.3		µg/L	

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

*2. Phase II samples were sent to an external lab with a lower reporting limit of <0.1 ppb.