

Dora Moore Elementary (259)

All results below 15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 8/16/2016				
Sample ID	Sample Description	Lead Result	Units	Action
259-014-SK-01	Kitchen sink, north east wall	1.1	µg/L	
259-014-SK-02	Kitchen prep sink faucet	9.1	µg/L	
259-014-SK-03	Spray, next to prep sink	1.9	µg/L	
259-014-SK-04	Kitchen kettle faucet	1.5	µg/L	
259-009-DF-05	Drinking fountain hallway 009, left	<1.0*	µg/L	
259-009-DF-06	Drinking fountain hallway 009, right	<1.0	µg/L	
259-000-DF-07	Drinking fountain hallway 000	1.5	µg/L	
259-006A-DF-08	Drinking fountain hallway 006A, left	<1.0	µg/L	
259-006A-DF-09	Drinking fountain hallway 006A, right	<1.0	µg/L	
259-108-SK-10	Faculty lounge sink	<1.0	µg/L	
259-105-DF-11	Drinking fountain hallway 105, left	<1.0	µg/L	
259-105-DF-12	Drinking fountain hallway 105, right	<1.0	µg/L	
259-103F-SK-13	Nurse sink	4.0	µg/L	
259-125-DF-14	Drinking fountain hallway 125, left, east wall	<1.0	µg/L	
259-125-DF-15	Drinking fountain hallway 125, right, east wall	<1.0	µg/L	
259-125-DF-16	Drinking fountain hallway 125, left, west wall	<1.0	µg/L	
259-125-DF-17	Drinking fountain hallway 125, right, west wall	<1.0	µg/L	
259-121-DF-18	Drinking fountain in room 121	2.6	µg/L	
259-110-DF-19	Drinking fountain in room 110	<1.0	µg/L	
259-215-DF-20	Drinking fountain hallway 215, left, east wall	3.8	µg/L	
259-215-DF-21	Drinking fountain hallway 215, right, east wall	1.8	µg/L	
259-215-DF-22	Drinking fountain hallway 215, left, west wall	<1.0	µg/L	
259-215-DF-23	Drinking fountain hallway 215, right, west wall	<1.0	µg/L	
259-205-DF-24	Drinking fountain hallway 205	<1.0	µg/L	
259-005-DF-25	Drinking fountain in room 005	<1.0	µg/L	
Phase II Sampled on 1/18/2017				
259-013-SK-26	Classroom sink, room 013, left faucet	<1.0	µg/L	
259-013-SK-27	Classroom sink, room 013, middle faucet	<1.0	µg/L	
259-013-SK-28	Classroom sink, room 013, right faucet	4.0	µg/L	
259-005-SK-29	Classroom sink, room 005	<1.0	µg/L	
259-008B-SK-30	Office sink, room 008B	1.0	µg/L	
259-004-SK-31	Classroom sink, room 004	<1.0	µg/L	
259-003-SK-32	Classroom sink, room 003	2.0	µg/L	

259-106-SK-33	Classroom sink, room 106	1.0	µg/L
259-107-SK-34	Classroom sink, room 107	<1.0	µg/L
259-103E-SK-35	Nurse sink, room 103E	4.0	µg/L
259-121-SK-36	Classroom sink, room 121	1.0	µg/L
259-110-SK-37	Classroom sink, room 110	<1.0	µg/L
259-118-SK-38	Classroom sink, room 118	<1.0	µg/L
259-116-SK-39	Classroom sink, room 116	2.0	µg/L
259-115-SK-40	Classroom sink, room 115	1.0	µg/L
259-114-SK-41	Classroom sink, room 114	3.0	µg/L
259-112-SK-42	Classroom sink, room 112	1.0	µg/L
259-212-SK-43	Classroom sink, room 212	7.0	µg/L
259-211-SK-44	Classroom sink, room 211	1.0	µg/L
259-209-SK-45	Classroom sink, room 209	4.0	µg/L
259-208-SK-46	Classroom sink, room 208	<1.0	µg/L
259-207-SK-47	Classroom sink, room 207	1.0	µg/L
259-214-SK-48	Classroom sink, room 214	<1.0	µg/L
259-206-SK-49	Classroom sink, room 206	<1.0	µg/L
259-204-SK-50	Classroom sink, room 204	<1.0	µg/L
259-203-SK-51	Classroom sink, room 203	<1.0	µg/L
259-201-SK-52	Classroom sink, room 201	5.0	µg/L
259-202A-SK-53	LMC/IMC office sink, room 202A	<1.0	µg/L

*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.