

## East High School (451)

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

### Phase I Sampled on 10/8/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
451-022-DF-01	Drinking fountain, boys locker room 022	0.3		µg/L	
451-142A-SK-02	Kitchen kettle fill, room 142A, next to room 142I	16.7 (<2.0* <sup>1</sup> flush)	3.0	µg/L	Flush notice, – filler replaced 7/2018
451-142A-SK-03	Kitchen prep sink, room 142A, next to room 142I	4.0		µg/L	
451-137-DF-04	Drinking fountain, hallway 137, across from room 170F	10.7		µg/L	
451-137-DF-05	Drinking fountain, hallway 137, next to room 169	0.1		µg/L	
451-137-DF-06	Bottle fill, hallway 137, next to room 169	0.2		µg/L	
451-139H-SK-07	Nurse sink, room 139H	13.3		µg/L	
451-139E-SK-08	Nurse sink, room 139E	10.8		µg/L	
451-139D-SK-09	Nurse sink, room 139D	9.4		µg/L	
451-139C-SK-10	Nurse sink, room 139C	8.2		µg/L	
451-137-DF-11	Bottle fill, hallway 137, next to room 144B	<0.1*		µg/L	
451-137-DF-12	Drinking fountain, hallway 137, next to room 144B	<0.1		µg/L	
451-145-DF-13	Drinking fountain, north gymnasium 145, west wall	1.5		µg/L	
451-145-DF-14	Drinking fountain, north gymnasium 145, east wall	1.5		µg/L	
451-117-DF-15	Drinking fountain, hallway 117, next to room 102	0.8		µg/L	
451-117-DF-16	Bottle fill, hallway 117, next to room 113	0.2		µg/L	
451-117-DF-17	Drinking fountain, hallway 117, next to room 113	0.2		µg/L	
451-132-DF-18	Drinking fountain, hallway 132, next to room 130	1.4		µg/L	
451-249-DF-19	Drinking fountain, hallway 249, next to room 234F, left bubbler	1.7		µg/L	
451-249-DF-20	Drinking fountain, hallway 249, next to room 234F, right bubbler	1.3		µg/L	
451-257-DF-21	Drinking fountain, hallway 257, next to room 238	2.4		µg/L	
451-247-DF-22	Drinking fountain, auxiliary gymnasium 247, left bubbler	10.1		µg/L	
451-247-DF-23	Drinking fountain, auxiliary gymnasium 247, right bubbler	7.6		µg/L	
451-208-DF-24	Drinking fountain, hallway 208, next to room 230	1.0		µg/L	
451-208-DF-25	Bottle fill, hallway 208, next to room 221	0.5		µg/L	
451-208-DF-26	Drinking fountain, hallway 208, next to room 221	0.6		µg/L	
451-201G-DF-27	Plumbed water cooler, admin office lounge, room 201G	0.2		µg/L	
451-202A-SK-28	Sink, PTA kitchen room 202A	2.9		µg/L	
451-208-DF-29	Drinking fountain, hallway 208, next to room 202	1.1		µg/L	
451-208-DF-30	Drinking fountain, hallway 208, next to room 213	1.1		µg/L	
451-313A-SK-31	Faculty lounge sink, room 313A	5.7		µg/L	
451-316-DF-32	Bottle fill, hallway 316, next to room 309	0.1		µg/L	
451-316-DF-33	Drinking fountain, hallway 316, next to room 309	0.1		µg/L	
451-316-DF-34	Drinking fountain, hallway 316, next to room 303	1.8		µg/L	
451-316-DF-35	Drinking fountain, hallway 316, next to room 329	2.4		µg/L	
451-316-DF-36	Bottle fill, hallway 316, next to room 324	0.3		µg/L	

451-316-DF-37	Drinking fountain, hallway 316, next to room 324	0.4		µg/L	
451-417-DF-38	Bottle fill, hallway 417, next to room 402	<0.1		µg/L	
451-417-DF-39	Drinking fountain, hallway 417, next to room 402	<0.1		µg/L	
451-417-DF-40	Drinking fountain, hallway 417, next to room 400, left bubbler	4.3		µg/L	
451-417-DF-41	Drinking fountain, hallway 417, next to room 400, right bubbler	4.1		µg/L	
451-412-DF-42	Drinking fountain, hallway 412, next to room 411	1.9		µg/L	
451-412-DF-43	Drinking fountain, hallway 412, next to room 407	1.6		µg/L	
451-412-DF-44	Drinking fountain, hallway 412, next to room 404	2.1		µg/L	
<b>Phase II Sampled on 9/30/2017</b>					
451-008-SK-45	Art room sink, room 008, next to kilns, left faucet	0.5		µg/L	
451-008-SK-46	Art room sink, room 008, next to kilns, right faucet	0.7		µg/L	
451-008-SK-47	Art room sink, room 008, east wall, left faucet	0.3		µg/L	
451-008-SK-48	Art room sink, room 008, east wall, right faucet	0.3		µg/L	
451-107B-SK-49	Office sink, room 107B	5.1		µg/L	
451-107-SK-50	Classroom sink, room 107	8.0		µg/L	
451-122-SK-51	Classroom sink, room 122	7.0		µg/L	
451-123-SK-52	Classroom sink, room 123	3.0		µg/L	
451-125-SK-53	Classroom sink, room 125	7.0		µg/L	
451-169-SK-54	Classroom sink, room 169	13.0		µg/L	
451-159-SK-55	Classroom sink, room 159	15.7	11.0	µg/L	Faucet replaced 4/2018
451-163-SK-56	Classroom sink, room 163, left sink	8.7		µg/L	
451-163-SK-57	Classroom sink, room 163, right sink	9.3		µg/L	
451-170-DF-58	Drinking fountain, shop room 170	14.6		µg/L	
451-170-SK-59	Shop sink, room 170, right sink	22.1	10.0	µg/L	Faucet replaced 4/2018
451-248A-SK-60	Gymnasium office sink, room 248A	10.9		µg/L	
451-243-SK-61	Classroom sink, room 243, east wall, far left sink	<1.0		µg/L	
451-243-SK-62	Classroom sink, room 243, east wall, center left sink	6.0		µg/L	
451-243-SK-63	Classroom sink, room 243, east wall, center right sink	7.0		µg/L	
451-243-SK-64	Classroom sink, room 243, east wall, far right sink	5.0		µg/L	
451-243-SK-65	Classroom sink, room 243, south wall, left sink	2.8		µg/L	
451-243-SK-66	Classroom sink, room 243, south wall, center sink	3.8		µg/L	
451-243-SK-67	Classroom sink, room 243, south wall, right sink	3.4		µg/L	
451-240-SK-68	Classroom sink, room 240	1.0		µg/L	
451-239-SK-69	Classroom sink, room 239, north wall, left sink	1.2		µg/L	
451-239-SK-70	Classroom sink, room 239, north wall, right sink	2.0		µg/L	
451-239-SK-71	Classroom sink, room 239, east wall	2.1		µg/L	
451-237-SK-72	Classroom sink, room 237, left sink	2.2		µg/L	
451-237-SK-73	Classroom sink, room 237, right sink	4.0		µg/L	
451-251D-SK-74	Office sink, room 251D	8.0		µg/L	
451-329A-SK-75	LMC/IMC office sink, room 329A	29.1	7.0	µg/L	Faucet replaced 4/2018
451-329-SK-76	Classroom sink, room 329	25.4	6.0	µg/L	Faucet replaced 4/2018
451-009B-SK-77	JROTC sink, room 009B	3.2		µg/L	

<b>451B-185-SK-78</b>	Robotics lab sink, building 451B, room 185	2.4	µg/L
<b>451-402-SK-79</b>	Classroom sink, room 402	5.1	µg/L
<b>451-400-SK-80</b>	Classroom sink, room 400	6.0	µg/L
<b>451-408-SK-81</b>	Classroom sink, room 408, west wall, left sink	<1.0	µg/L
<b>451-408-SK-82</b>	Classroom sink, room 408, west wall, center sink	<1.0	µg/L
<b>451-408-SK-83</b>	Classroom sink, room 408, west wall, right sink	<1.0	µg/L
<b>451-407-SK-84</b>	Classroom sink, room 407, west wall, left sink	9.0	µg/L
<b>451-407-SK-85</b>	Classroom sink, room 407, west wall, center sink	3.4	µg/L
<b>451-407-SK-86</b>	Classroom sink, room 407, west wall, right sink	2.5	µg/L
<b>451-405-SK-87</b>	Science lab sink, room 405, west wall, left sink, left faucet	0.3	µg/L
<b>451-405-SK-88</b>	Science lab sink, room 405, west wall, left sink, right faucet	0.3	µg/L
<b>451-405-SK-89</b>	Science lab sink, room 405, west wall, right sink, left faucet	0.7	µg/L
<b>451-405-SK-90</b>	Science lab sink, room 405, west wall, right sink, right faucet	0.5	µg/L
<b>451-405-SK-91</b>	Science lab sink, room 405, north wall, left sink, left faucet	<1.0	µg/L
<b>451-405-SK-92</b>	Science lab sink, room 405, north wall, left sink, right faucet	<1.0	µg/L
<b>451-405-SK-93</b>	Science lab sink, room 405, north wall, right sink, left faucet	<1.0	µg/L
<b>451-405-SK-94</b>	Science lab sink, room 405, north wall, right sink, right faucet	<1.0	µg/L
<b>451-405-SK-95</b>	Science lab sink, room 405, east wall, left sink, left faucet	<1.0	µg/L
<b>451-405-SK-96</b>	Science lab sink, room 405, east wall, left sink, right faucet	0.5	µg/L
<b>451-405-SK-97</b>	Science lab sink, room 405, east wall, right sink, left faucet	<1.0	µg/L
<b>451-405-SK-98</b>	Science lab sink, room 405, east wall, right sink, right faucet	0.4	µg/L
<b>451-409-SK-99</b>	Science lab sink, room 409, east wall, left faucet	0.4	µg/L
<b>451-409-SK-100</b>	Science lab sink, room 409, east wall, right faucet	0.3	µg/L
<b>451-409-SK-101</b>	Science lab sink, room 409, south wall, left faucet	<1.0	µg/L
<b>451-409-SK-102</b>	Science lab sink, room 409, south wall, right faucet	0.4	µg/L
<b>451-410-SK-103</b>	Science lab sink, room 410, south wall, left sink, left faucet	<1.0	µg/L
<b>451-410-SK-104</b>	Science lab sink, room 410, south wall, left sink, right faucet	0.4	µg/L
<b>451-410-SK-105</b>	Science lab sink, room 410, south wall, center sink, left faucet	0.4	µg/L
<b>451-410-SK-106</b>	Science lab sink, room 410, south wall, center sink, right faucet	0.3	µg/L
<b>451-410-SK-107</b>	Science lab sink, room 410, south wall, right sink, left faucet	0.4	µg/L
<b>451-410-SK-108</b>	Science lab sink, room 410, south wall, right sink, right faucet	0.4	µg/L
<b>451-410-SK-109</b>	Science lab sink, room 410, north wall, left sink, left faucet	1.0	µg/L
<b>451-410-SK-110</b>	Science lab sink, room 410, north wall, left sink, right faucet	0.6	µg/L

<b>451-410-SK-111</b>	Science lab sink, room 410, north wall, right sink, left faucet	0.5	µg/L	
<b>451-410-SK-112</b>	Science lab sink, room 410, north wall, right sink, right faucet	0.4	µg/L	
<b>451-410-SK-113</b>	Science lab sink, room 410, east wall, left faucet	2.8	µg/L	
<b>451-410-SK-114</b>	Science lab sink, room 410, east wall, right faucet	1.0	µg/L	
<b>451-411-SK-115</b>	Science lab sink, room 411, south wall, center sink	3.0	µg/L	
<b>451-411-SK-116</b>	Science lab sink, room 411, south wall, right sink	2.2	µg/L	
<b>451-411-SK-117</b>	Science lab sink, room 411, north wall, left sink	34.4	µg/L	Lab Sink – No Drinking Notice
<b>451-411-SK-118</b>	Science lab sink, room 411, north wall, center sink	24.0	µg/L	Lab Sink – No Drinking Notice
<b>451-411-SK-119</b>	Science lab sink, room 411, north wall, right sink	2.3	µg/L	
<b>451-403-SK-120</b>	Science lab sink, room 403, south wall, left sink	1.6	µg/L	
<b>451-403-SK-121</b>	Science lab sink, room 403, south wall, center sink	2.2	µg/L	
<b>451-403-SK-122</b>	Science lab sink, room 403, south wall, right sink	6.5	µg/L	
<b>451-403-SK-123</b>	Science lab sink, room 403, north wall, left sink	4.0	µg/L	
<b>451-403-SK-124</b>	Science lab sink, room 403, north wall, right sink	3.7	µg/L	
<b>451-403A-SK-125</b>	Science prep sink, room 403A	>50.0	µg/L	Lab Sink – No Drinking Notice
<b>451-403C-SK-126</b>	Science lab sink, room 403C, left sink, left faucet	>50.0	µg/L	Lab Sink – No Drinking Notice
<b>451-403C-SK-127</b>	Science lab sink, room 403C, left sink, right faucet	>50.0	µg/L	Lab Sink – No Drinking Notice
<b>451-403C-SK-128</b>	Science lab sink, room 403C, right sink, left faucet	39.1	µg/L	Lab Sink – No Drinking Notice
<b>451-403C-SK-129</b>	Science lab sink, room 403C, right sink, right faucet	34.4	µg/L	Lab Sink – No Drinking Notice
<b>451-404-SK-130</b>	Science lab sink, room 404, south wall, left sink	1.5	µg/L	
<b>451-404-SK-131</b>	Science lab sink, room 404, south wall, center sink	>50.0	µg/L	Lab Sink – No Drinking Notice
<b>451-404-SK-132</b>	Science lab sink, room 404, north wall, left sink	12.1	µg/L	
<b>451-404-SK-133</b>	Science lab sink, room 404, north wall, center sink	8.0	µg/L	

\*Result less than 0.1 ppb which is the lowest level that can be reported by the lab.

\*1. Follow up samples are tested with a Palintest SA1100 scanning analyzer.