

Edison Elementary (230)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 8/26/2016				
Sample ID	Sample Description	Lead Result	Units	Action
230-100-DF-01	Drinking fountain, hallway 100, next to room 105	<1.0* ¹	µg/L	
230-114-DF-02	Drinking fountain hallway 114, next to Auditorium	<1.0	µg/L	
230-114-DF-03	Bottle filler, hallway 114, next to gym	<1.0	µg/L	
230-114-DF-04	Drinking fountain, hallway 114, next to gym	<1.0	µg/L	
230-100-DF-05	Drinking fountain, hallway 100, next to room 117	<1.0	µg/L	
230-118-DF-06	Drinking fountain, hallway 118, next to 118A	1.1	µg/L	
230-101-SK-07	Sink, room 101	<1.0	µg/L	
230-108-DF-08	Bottle filler, cafeteria	<1.0	µg/L	
230-108-DF-09	Drinking fountain, cafeteria	<1.0	µg/L	
230-109-SK-10	Kitchen prep sink	4.0	µg/L	
230-000-DF-11	Drinking fountain, hallway 000, next to room 002	<1.0	µg/L	
230-H200-DF-12	Drinking fountain, hallway H200, next to room 211	<1.0	µg/L	
230-H200-DF-13	Drinking fountain, hallway H200, next to room 205	1.2	µg/L	
Phase II Sampled on 2/1/2017				
230-002-SK-14	Faculty lounge sink, room 002	3.1	µg/L	
230-001-SK-15	Art room sink, room 001	<0.5* ²	µg/L	
230-104-SK-16	Classroom sink, room 104	2.9	µg/L	
230-105-SK-17	Classroom sink, room 105	>50.0	µg/L	Hand wash/cleaning only notice
230-103-SK-18	Classroom sink, room 103	2.2	µg/L	
230-102-SK-19	Classroom sink, room 102	1.8	µg/L	
230-125-SK-20	Classroom sink, room 125	1.6	µg/L	
230-124-SK-21	Classroom sink, room 124	0.6	µg/L	
230-123-SK-22	Classroom sink, room 123	1.6	µg/L	
230-122-SK-23	Classroom sink, room 122	0.5	µg/L	
230-121-SK-24	Classroom sink, room 121	0.9	µg/L	
230-120-SK-25	Classroom sink, room 120	0.6	µg/L	
230-119-SK-26	LMC/IMC sink, room 119	3.0	µg/L	
230-117-SK-27	Classroom sink, room 117	1.1	µg/L	
230-112-SK-28	Nurse sink, room 112	0.7	µg/L	
230-111-SK-29	Classroom sink, room 111	1.6	µg/L	
230-107-SK-30	Classroom sink, room 107	<0.5	µg/L	
230-207-SK-31	Classroom sink, room 207	<0.5	µg/L	
230-205-SK-32	Classroom sink, room 205	2.6	µg/L	
230-204-SK-33	Classroom sink, room 204	5.5	µg/L	

230-203-SK-34	Classroom sink, room 203	3.0	µg/L
230-202-SK-35	Classroom sink, room 202	2.2	µg/L
230-201-SK-36	Classroom sink, room 201	8.7	µg/L
230-217-SK-37	Classroom sink, room 217	2.0	µg/L
230-216-SK-38	Classroom sink, room 216	7.0	µg/L
230-215-SK-39	Classroom sink, room 215	2.5	µg/L
230-214-SK-40	Classroom sink, room 214	2.1	µg/L
230-213-SK-41	Classroom sink, room 213	3.7	µg/L
230-211-SK-42	Classroom sink, room 211	2.8	µg/L
230-210-SK-43	Classroom sink, room 210	7.3	µg/L
230-212-SK-44	Staff office sink, room 212	1.8	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

*2. Result less than 0.5 ppb which is the lowest level that can be reported by the external lab.