

Garden Place Elementary (241)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 8/24/2016					
Sample ID	Sample Description* ¹	Lead Result	Follow Up Result	Units	Action
241-H000-DF-01	Drinking fountain, hallway 100, next to boys restroom	<1.0* ²		µg/L	
241-H000-DF-02	Drinking fountain, hallway 100, next to rooms 102 and 103	1.3		µg/L	
241-007A-DF-03	Drinking fountain, room 105A	<1.0		µg/L	
241-004-DF-04	Drinking fountain, room 103	<1.0		µg/L	
241-GYM-DF-05	Drinking fountain, gymnasium room 110	9.7		µg/L	
241-H100-DF-06	Drinking fountain, hallway 200, next to room 205	3.9		µg/L	
241-H100-DF-07	Drinking fountain, hallway 200, next to room 208	3.0		µg/L	
241-H100-DF-08	Drinking fountain, hallway 200, next to room 201	<1.0		µg/L	
241-OFF-SK-09	Sink, admin office, room 209	<1.0		µg/L	
241-TLA-SK-10	Sink, PTA kitchen, room 312A	4.1		µg/L	
241-H200-DF-11	Drinking fountain, hallway 300, next to room 310	2.6		µg/L	
241-210-SK-12	Sink, room 309	2.6		µg/L	
241-H200-DF-13	Drinking fountain, hallway 300, next to room 305	<1.0		µg/L	
241-H000-DF-14	Drinking fountain, hallway 100, next to room 101	1.4		µg/L	
241-KIT-SK-15	Kitchen prep sink, next to hand washing sink, room 111	1.5		µg/L	
Phase II Sampled on 1/20/2017					
241-118-SK-16	Classroom sink, room 118, left faucet	1.0		µg/L	
241-118-SK-17	Classroom sink, room 118, right faucet	1.0		µg/L	
241-119-SK-18	Classroom sink, room 119, left faucet	<1.0		µg/L	
241-119-SK-19	Classroom sink, room 119, right faucet	2.0		µg/L	
241-101-SK-20	Classroom sink, room 101	<1.0		µg/L	
241-102-SK-21	Classroom sink, room 102	1.0		µg/L	
241-210-SK-22	Classroom sink, room 210	5.0		µg/L	
241-208-SK-23	Classroom sink, room 208	<1.0		µg/L	
241-201-SK-24	Classroom sink, room 201	16.0	10.0	µg/L	Replaced 7/2017
241-207-SK-25	Classroom sink, room 207	7.0		µg/L	
241-202-SK-26	Classroom sink, room 202	4.0		µg/L	
241-203-SK-27	Classroom sink, room 203	3.0		µg/L	
241-204-SK-28	Classroom sink, room 204	<1.0		µg/L	
241-205-SK-29	Classroom sink, room 205	<1.0		µg/L	
241-311-SK-30	Classroom sink, room 311	1.0		µg/L	
241-313-SK-31	Classroom sink, room 313	13.0		µg/L	
241-301-SK-32	Classroom sink, room 301	3.0		µg/L	
241-310-SK-33	Classroom sink, room 310	19.0	11.0	µg/L	Replaced 7/2017

241-302-SK-34	Classroom sink, room 302	4.0	µg/L
241-307-SK-35	Office sink, room 307	<1.0	µg/L
241-303-SK-36	Classroom sink, room 303	<1.0	µg/L
241-306-SK-37	Classroom sink, room 306	1.0	µg/L
241-305-SK-38	Classroom sink, room 305	<1.0	µg/L
241-304-SK-39	Classroom sink, room 304	<1.0	µg/L

*1. Room numbering changed between phases I and II. The location description for phase I samples has been updated to match the current numbering.

*2. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.