

George Washington High School (452)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled 11/19/2016 & 12/8/2016					
Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
452-001-DF-01	Drinking fountain, hallway 001, next to room 006	<1.0*		µg/L	
452-11-DF-02	Drinking fountain, hallway 11, next to room 27	7.0		µg/L	
452-11-DF-03	Bottle fill, hallway 11, next to room 24	<1.0		µg/L	
452-11-DF-04	Drinking fountain, hallway 11, next to room 24	<1.0		µg/L	
452-19-DF-05	Drinking fountain, swim pool 19, southeast corner, next to lobby 18	9.0		µg/L	
452-19-DF-06	Drinking fountain, swim pool 19, southwest corner	9.0		µg/L	
452-19-DF-07	Drinking fountain, swim pool 19, northeast corner, next to lobby 20	19.0	N/A	µg/L	Cut and cap
452-19-DF-08	Drinking fountain, swim pool 19, northwest corner	19.0	<1.0	µg/L	Bottle fill station install
452-17-DF-09	Drinking fountain, girls locker room 17, south wall	5.0		µg/L	
452-13-DF-10	Drinking fountain, boys locker room 13, north wall	3.0		µg/L	
452-126-DF-11	Drinking fountain, hallway 126, next to room 133	5.0		µg/L	
452-131-SK-12	Classroom sink, room 131, northwest corner	9.0		µg/L	
452-131-SK-13	Classroom sink, room 131, northeast corner	10.0		µg/L	
452-126-DF-14	Drinking fountain, hallway 126, across from room 129	3.0		µg/L	
452-129-SK-15	Classroom sink, room 129, southwest corner	6.0		µg/L	
452-129-SK-16	Classroom sink, room 129, right of 452-129-SK-15	4.0		µg/L	
452-126-DF-17	Bottle fill, hallway 126, next to room 128	<1.0		µg/L	
452-126-DF-18	Drinking fountain, hallway 126, next to room 128	<1.0		µg/L	
452-128-SK-19	Classroom sink, room 128, north corner, next to room 128B	12.0		µg/L	
452-127-DF-20	Drinking fountain, gymnasium 127, southeast corner	3.0		µg/L	
452-127-DF-21	Drinking fountain, gymnasium 127, southwest corner	7.0		µg/L	
452-127-DF-22	Drinking fountain, gymnasium 127, northwest corner	4.0		µg/L	
452-127-DF-23	Drinking fountain, gymnasium 127, northeast corner	4.0		µg/L	
452-127B-DF-24	Drinking fountain, weight room 127B	5.0		µg/L	
452-123-DF-25	Drinking fountain, hallway 123, next to room 125D	12.0		µg/L	
452-124-DF-26	Drinking fountain, cafeteria 124, southeast corner	6.0		µg/L	
452-122-DF-27	Bottle fill, lobby 122, across from room 114	<1.0		µg/L	
452-122-DF-28	Drinking fountain, lobby 122 across from room 114	<1.0		µg/L	
452-101-DF-29	Drinking fountain, hallway 101, next to stair B	11.0		µg/L	
452-104D-SK-30	Nurse sink, room 104D	7.0		µg/L	
452-107-SK-31	Faculty lounge sink, room 107	3.0		µg/L	

452-101-DF-32	Drinking fountain, hallway 101, next to room 102	4.0		µg/L	
452-110A-SK-33	Community room sink, room 110A	10.0		µg/L	
452-111-DF-34	Drinking fountain, hallway 111, next to room 111H	6.0		µg/L	
452-111-DF-35	Drinking fountain, hallway 111, next to elevator and stair C	<1.0		µg/L	
452-111-DF-36	Drinking fountain, hallway 111, next to room 119	2.0		µg/L	
452-225-DF-37	Drinking fountain, hallway 225, next to room 231	7.0		µg/L	
452-225-DF-38	Drinking fountain, hallway 225, next to room 236	6.0		µg/L	
452-225-DF-39	Bottle fill, hallway 225, across from room 238	<1.0		µg/L	
452-225-DF-40	Drinking fountain, hallway 225, across from 238	<1.0		µg/L	
452-239-SK-41	Faculty lounge sink, room 239	23.0	32.0	µg/L	Faucet replaced 7/2017, No Drinking Notice
452-225-DF-42	Drinking fountain, hallway 225, across from room 221D	20.0	1.0	µg/L	Bubbler replaced 4/2018, Filter installed 10/2018
452-221-DF-43	Drinking fountain, hallway 221, next to room 241	11.0		µg/L	
452-233B-SK-44	LMC/IMC sink, room 223B	7.0		µg/L	
452-221-DF-45	Drinking fountain, hallway 221, next to room 223B	9.0		µg/L	
452-200-DF-46	Drinking fountain, hallway 200, across from room 203	9.0		µg/L	
452-200-DF-47	Drinking fountain, hallway 200, next to room 201	4.0		µg/L	
452-200-DF-48	Bottle fill, hallway 200, across from room 209	<1.0		µg/L	
452-200-DF-49	Drinking fountain, hallway 200, across from room 209	<1.0		µg/L	
452-242-SK-50	Faculty lounge sink, room 242	28.0	8.0	µg/L	Faucet replaced 7/2017
452-200-DF-51	Drinking fountain, hallway 200, next to room 200G and elevator	<1.0		µg/L	
452-200-DF-52	Drinking fountain, hallway 200, across from room 217	<1.0		µg/L	
452-300-DF-53	Drinking fountain, hallway 300, next to room 304	7.0		µg/L	
452-300-DF-54	Drinking fountain, hallway 300, across from room 306	1.0		µg/L	
452-300-DF-55	Drinking fountain, hallway 300, across from room 309	3.0		µg/L	
452-300-DF-56	Drinking fountain, hallway 300, across from room 316	3.0		µg/L	
452-300-DF-57	Bottle fill, hallway 300, across from room 312	<1.0		µg/L	
452-300-DF-58	Drinking fountain, hallway 300, across from room 312	<1.0		µg/L	
452-125-SK-59	Kettle fill, kitchen 125, northwest wall	1.5		µg/L	
452-125-SK-60	Food prep sink, kitchen 125, south wall	8.8		µg/L	
Phase II Sampled 10/26/2017					
452-005-SK-61	Science lab sink, room 005, west wall, far left	3.0		µg/L	
452-005-SK-62	Science lab sink, room 005, west wall, center left	<1.0		µg/L	
452-005-SK-63	Science lab sink, room 005, west wall, center right, after bend	10.0		µg/L	
452-005-SK-64	Science lab sink, room 005, west wall, far right, after bend	<1.0		µg/L	
452-005-SK-65	Science lab sink, room 005, north east wall, left	<1.0		µg/L	
452-005-SK-66	Science lab sink, room 005, north east wall, right	<1.0		µg/L	

452-005-SK-67	Science lab sink, room 005, demonstration sink	1.0		µg/L	
452-005-SK-68	Science lab sink, room 005, southwest wall, left sink	<1.0		µg/L	
452-005-SK-69	Science lab sink, room 005, southwest wall, center sink	<1.0		µg/L	
452-005-SK-70	Science lab sink, room 005, southwest wall, right sink	1.0		µg/L	
452-004-SK-71	Science prep room sink, room 004	1.0		µg/L	
452-003-SK-72	Science lab sink, room 003, southwest wall	<1.0		µg/L	
452-003-SK-73	Science lab sink, room 003, south of demo sink	<1.0		µg/L	
452-003-SK-74	Science lab sink, room 003, west of demo sink	<1.0		µg/L	
452-003-SK-75	Science lab sink, room 003, demonstration sink	<1.0		µg/L	
452-003-SK-76	Science lab sink, room 003, west island, south sink	1.0		µg/L	
452-003-SK-77	Science lab sink, room 003, west island, center sink	<1.0		µg/L	
452-003-SK-78	Science lab sink, room 003, west island, north sink	3.0		µg/L	
452-003-SK-79	Science lab sink, room 003, east island, north sink	1.0		µg/L	
452-003-SK-80	Science lab sink, room 003, east island, center sink	<1.0		µg/L	
452-003-SK-81	Science lab sink, room 003, east island, south sink,	2.0		µg/L	
452-28-SK-82	Science lab sink, room 28, southeast wall, center right sink	17.0		µg/L	Science Lab Notice
452-28-SK-83	Science lab sink, room 28, southeast wall, center left sink	5.0		µg/L	
452-28-SK-84	Science lab sink, room 28, southeast wall, far left sink	5.0		µg/L	
452-28-SK-85	Science lab sink, room 28, demonstration sink	15.0		µg/L	Science Lab Notice
452-27-SK-86	Classroom sink room 27, southeast corner	7.0		µg/L	
452-29-SK-87	Science lab sink, room 29, west island	3.0		µg/L	
452-29-SK-88	Science lab sink, room 29, north island	4.0		µg/L	
452-29-SK-89	Science lab sink, room 29, east island	2.0		µg/L	
452-29-SK-90	Science lab sink, room 29, south island	2.0		µg/L	
452-29-SK-91	Science lab sink, room 29, demonstration sink	2.0		µg/L	
452-29-SK-92	Science lab sink, room 29, northeast corner	2.0		µg/L	
452-29C-SK-93	Science prep room sink, room 29C	2.0		µg/L	
452-30-SK-94	Science lab sink, room 30, demonstration sink	1.0		µg/L	
452-30-SK-95	Science lab sink, room 30, south island	2.0		µg/L	
452-30-SK-96	Science lab sink, room 30, east island	2.0		µg/L	
452-30-SK-97	Science lab sink, room 30, north island	1.0		µg/L	
452-30-SK-98	Science lab sink, room 30, west island	3.0		µg/L	
452-30-SK-99	Science lab sink, room 30, southeast corner	2.0		µg/L	
452-26-DF-100	Drinking fountain, room 26	7.0		µg/L	
452-26-SK-101	Art room wash sink, room 26	15.0		µg/L	Shop Sink Notice
452-25-SK-102	Shop utility sink, room 25	27.0		µg/L	Shop Sink Notice
452-24-SK-103	Art room sink, room 24	1.0		µg/L	
452-24A-SK-104	Art room prep sink, room 24A	3.0		µg/L	
452-142A-SK-105	Fitting room sink, room 142A	4.0		µg/L	
452-141-SK-106	Music room sink, room 141	4.0		µg/L	
452-129-SK-107	Classroom sink, room 129, northwest wall, center right sink	26.0	32.0	µg/L	Faucet Replaced 2/2018, No Drinking Notice

452-129-SK-108	Classroom sink, room 129, northwest wall, far right sink	13.0		µg/L	
452-131-SK-109	Classroom sink, room 131, northwest wall, second sink from north	17.0	13.0	µg/L	Faucet Replaced 4/2018
452-131-SK-110	Classroom sink, room 131, northwest wall, third sink from north	18.0	8.0	µg/L	Faucet Replaced 4/2018
452-131-SK-111	Classroom sink, room 131, northwest wall, fourth sink from north	21.0	8.0	µg/L	Faucet Replaced 4/2018
452-131-SK-112	Classroom sink, room 131, northwest wall, fifth sink from north	25.0	9.0	µg/L	Faucet Replaced 4/2018
452-131-SK-113	Classroom sink, room 131, northwest wall, sixth sink from north	19.0	6.0	µg/L	Faucet Replaced 4/2018
452-133-SK-114	Classroom sink, room 133, southeast corner, science sinks INOP	9.0		µg/L	
452-238-SK-117	Science lab sink, room 238, northwest wall, right demonstration sink, left faucet	46.0		µg/L	Science Lab Notice
452-238-SK-118	Science lab sink, room 238, northwest wall, right demonstration sink, right faucet	27.0		µg/L	Science Lab Notice
452-238-SK-119	Science lab sink, room 238, northwest wall, left demonstration sink, left faucet	41.0		µg/L	Science Lab Notice
452-238-SK-120	Science lab sink, room 238, northeast wall, left counter, left faucet	37.0		µg/L	Science Lab Notice
452-238-SK-121	Science lab sink, room 238, northeast wall, left counter, right faucet	20.0		µg/L	Science Lab Notice
452-238-SK-122	Science lab sink, room 238, northeast wall, center counter, left faucet	46.0		µg/L	Science Lab Notice
452-238-SK-123	Science lab sink, room 238, northeast wall, right counter, left faucet	33.0		µg/L	Science Lab Notice
452-238-SK-124	Science lab sink, room 238, northeast wall, right counter, right faucet	22.0		µg/L	Science Lab Notice
452-238-SK-125	Science lab sink, room 238, east wall, left counter, left faucet	50.0		µg/L	Science Lab Notice
452-238-SK-126	Science lab sink, room 238, east wall, left counter, right faucet	27.0		µg/L	Science Lab Notice
452-238-SK-127	Science lab sink, room 238, east wall, center counter, left faucet	31.0		µg/L	Science Lab Notice
452-238-SK-128	Science lab sink, room 238, east wall, center counter, right faucet	20.0		µg/L	Science Lab Notice
452-238-SK-129	Science lab sink, room 238, east wall, right counter, left faucet	26.0		µg/L	Science Lab Notice
452-238-SK-130	Science lab sink, room 238, east wall, right counter, right faucet	25.0		µg/L	Science Lab Notice
452-238-SK-131	Science lab sink, room 238, south wall, demonstration sink, left faucet	22.0		µg/L	Science Lab Notice
452-238-SK-132	Science lab sink, room 238, south wall, demonstration sink, right faucet	34.0		µg/L	Science Lab Notice
452-238B-SK-133	Science prep sink, room 238B, east wall	26.0		µg/L	Science Lab Notice
452-237B-SK-134	Science prep sink, room 237B, east wall	23.0		µg/L	Science Lab Notice

452-237-SK-135	Science lab sink, room 237, northwest wall, right demonstration sink, right faucet	25.0	µg/L	Science Lab Notice
452-237-SK-136	Science lab sink, room 237, northwest wall, left demonstration sink, right faucet	27.0	µg/L	Science Lab Notice
452-237-SK-137	Science lab sink, room 237, northwest wall, left demonstration sink, left faucet	18.0	µg/L	Science Lab Notice
452-237-SK-138	Science lab sink, room 237, east wall, left counter, left faucet	41.0	µg/L	Science Lab Notice
452-237-SK-139	Science lab sink, room 237, east wall, center counter, left faucet	35.0	µg/L	Science Lab Notice
452-237-SK-140	Science lab sink, room 237, east wall, center counter, right faucet	33.0	µg/L	Science Lab Notice
452-237-SK-141	Science lab sink, room 237, east wall, right counter, left faucet	45.0	µg/L	Science Lab Notice
452-237-SK-142	Science lab sink, room 237, east wall, right counter, right faucet	23.0	µg/L	Science Lab Notice
452-237-SK-143	Science lab sink, room 237, south wall, left counter, left faucet	35.0	µg/L	Science Lab Notice
452-237-SK-144	Science lab sink, room 237, south wall, left counter, right faucet	26.0	µg/L	Science Lab Notice
452-237-SK-145	Science lab sink, room 237, south wall, center counter, left faucet	>50.0	µg/L	Science Lab Notice
452-237-SK-146	Science lab sink, room 237, south wall, center counter, right faucet	30.0	µg/L	Science Lab Notice
452-237-SK-147	Science lab sink, room 237, south wall, right counter, left faucet	23.0	µg/L	Science Lab Notice
452-237-SK-148	Science lab sink, room 237, south wall, right counter, right faucet	18.0	µg/L	Science Lab Notice
452-237A-SK-149	Science prep sink, room 237A	16.0	µg/L	Science Lab Notice
452-236-SK-150	Science lab sink, room 236, demonstration sink	28.0	µg/L	Science Lab Notice
452-236A-SK-151	Science prep sink, room 236A	27.0	µg/L	Science Lab Notice
452-235D-SK-152	Science prep sink, room 235D	40.0	µg/L	Science Lab Notice
452-235-SK-153	Science lab sink, room 235, demonstration sink	34.0	µg/L	Science Lab Notice
452-232-SK-154	Science lab sink, room 232	21.0	µg/L	Science Lab Notice
452-231-SK-155	Science lab sink, room 231, west wall, left sink	>50.0	µg/L	Science Lab Notice
452-231-SK-156	Science lab sink, room 231, west wall, center sink	19.0	µg/L	Science Lab Notice
452-231-SK-157	Science lab sink, room 231, west wall, right sink	13.0	µg/L	
452-230-SK-158	Art room sink, room 230	4.0	µg/L	
452-229-SK-159	Art room sink, room 229, next to 229A	2.0	µg/L	
452-229-SK-160	Art room sink, room 229, west wall, left sink	4.0	µg/L	
452-229-SK-161	Art room sink, room 229, west wall, right sink	13.0	µg/L	
452-226-SK-162	Science lab sink, room 226, south wall, left counter, left faucet	6.0	µg/L	
452-226-SK-163	Science lab sink, room 226, south wall, left counter, right faucet	10.0	µg/L	

452-226-SK-164	Science lab sink, room 226, south wall, center counter, left faucet	19.0		µg/L	Science Lab Notice
452-226-SK-165	Science lab sink, room 226, south wall, center counter, right faucet	18.0		µg/L	Science Lab Notice
452-226-SK-166	Science lab sink, room 226, south wall, far right sink	21.0		µg/L	Science Lab Notice
452-226-SK-167	Science lab sink, room 226, west wall, left counter, left faucet	15.0		µg/L	Science Lab Notice
452-226-SK-168	Science lab sink, room 226, west wall, left counter, right faucet	18.0		µg/L	Science Lab Notice
452-226-SK-169	Science lab sink, room 226, west wall, 2nd left counter, left faucet	19.0		µg/L	Science Lab Notice
452-226-SK-170	Science lab sink, room 226, west wall, 2nd left counter, right faucet	21.0		µg/L	Science Lab Notice
452-226-SK-171	Science lab sink, room 226, west wall, center counter, left faucet	34.0		µg/L	Science Lab Notice
452-226-SK-172	Science lab sink, room 226, west wall, center counter, right faucet	14.0		µg/L	
452-226-SK-173	Science lab sink, room 226, west wall, 2nd right counter, left faucet	42.0		µg/L	Science Lab Notice
452-226-SK-174	Science lab sink, room 226, west wall, 2nd right counter, right faucet	36.0		µg/L	Science Lab Notice
452-226-SK-175	Science lab sink, room 226, west wall, right counter, left faucet	28.0		µg/L	Science Lab Notice
452-226-SK-176	Science lab sink, room 226, west wall, right counter, right faucet	36.0		µg/L	Science Lab Notice
452-226-SK-177	Science lab sink, room 226, demonstration sink	20.0		µg/L	Science Lab Notice
452-240-SK-178	Music room sink, room 240	42.0	9.0	µg/L	Faucet replaced 4/2018

*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.