

## Grant Beacon Middle School (405)

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
<b>Phase I Sampled on 10/26/2016</b>					
405-115-DF-01	Bottle fill, hallway 115, next to room 116	<1.0* <sup>1</sup>		µg/L	
405-115-DF-02	Drinking fountain, hallway 115, next to room 116	<1.0		µg/L	
405-120-SK-03	Kitchen prep sink, room 120, west wall	<1.0		µg/L	
405-120-SK-04	Kitchen food prep sprayer, room 120, west wall	<1.0		µg/L	
405-120-SK-05	Kitchen kettle fill, room 120, east wall	3.0		µg/L	
405-000-DF-06	Drinking fountain, hallway 000, next to elevator	<1.0		µg/L	
405-210-DF-07	Drinking fountain, hallway 210, across from room 214	<1.0		µg/L	
405-210-DF-08	Drinking fountain, hallway 210, next to room 210D	<1.0		µg/L	
405-210-DF-09	Bottle fill, hallway 210, across from room 210F	<1.0		µg/L	
405-210-DF-10	Drinking fountain, hallway 210, across from room 210F	<1.0		µg/L	
405-118-SK-11	Classroom sink, room 118, east wall	4.0		µg/L	
405-113-SK-12	Faculty lounge sink, room 113, south wall	3.0		µg/L	
405-112-SK-13	Nurse sink, room 102	2.0		µg/L	
<b>Phase II Sampled 9/21/2017</b>					
405-105-SK-14	Classroom sink, room 105, north wall, left sink	4.1		µg/L	
405-105-SK-15	Classroom sink, room 105, north wall, right sink	2.2		µg/L	
405-003-SK-16	Custodial office sink, room 003	4.5		µg/L	
405-006-DF-17	Drinking fountain, gymnasium 006, east wall	0.1		µg/L	
405-006B-SK-18	Gym office sink, room 006B	18.4	14.0* <sup>2</sup>	µg/L	Faucet Replaced 04/2018
405-005-DF-19	Drinking fountain, gymnasium 005, south wall	5.3		µg/L	
405-209-SK-20	Classroom sink, room 209, left sink	3.5		µg/L	
405-209-SK-21	Classroom sink, room 209, right sink	4.6		µg/L	
405-208-SK-22	Classroom sink, room 208	10.8		µg/L	
405-201-SK-23	LMC/IMC sink, room 201	>50.0	6.0* <sup>2</sup>	µg/L	Faucet Replaced 04/2018
405-207-SK-24	Classroom sink, room 207, left sink	3.0		µg/L	
405-207-SK-25	Classroom sink, room 207, right sink	2.3		µg/L	
405-202-SK-26	Science lab sink, room 202, north wall, left sink	10.5		µg/L	
405-202-SK-27	Science lab sink, room 202, north wall, right sink	>50.0		µg/L	Lab Sink – No Drinking Notice
405-203-SK-28	Science lab sink, room 203, south wall, left sink	18.8		µg/L	Lab Sink – No Drinking Notice
405-203-SK-29	Science lab sink, room 203, south wall, right sink	21.7		µg/L	Lab Sink – No Drinking Notice
405-122-SK-30	Music room sink, room 122	5.4		µg/L	

\*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

\*2. Follow up samples post faucet swap collected on 5/2/2018.