

Harrington Elementary (248)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/29/2016					
Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
248-110-SK-01	Kitchen sink, north wall, left faucet	1.5		µg/L	
248-110-SK-02	Kitchen sink, east wall, left faucet	1.0		µg/L	
248-110-SK-03	Kitchen kettle faucet	1.9		µg/L	
248-109-DF-04	Drinking fountain, cafeteria, left bubbler	<1.0* ¹		µg/L	
248-109-DF-05	Drinking fountain, cafeteria, right bubbler	<1.0		µg/L	
248-107-DF-06	Drinking fountain, gymnasium, west wall	<1.0		µg/L	
248-106-DF-07	Drinking fountain, hall 106, next to room 105, left bubbler	<1.0		µg/L	
248-106-DF-08	Drinking fountain, hall 106, next to room 105, right bubbler	<1.0		µg/L	
248-101-DF-09	Drinking fountain, hall 106, by main office, left bubbler	<1.0		µg/L	
248-101-DF-10	Drinking fountain, hall 106, by main office, right bubbler	1.3		µg/L	
248-102C-SK-11	Nurse sink, room 102C	1.3		µg/L	
248-120-SK-12	Staff lounge sink, room 120	<1.0		µg/L	
248-205-DF-13	Drinking fountain, hall 205, next to room 206, left bubbler	<1.0		µg/L	
248-205-DF-14	Drinking fountain, hall 205, next to room 206, right bubbler	<1.0		µg/L	
248-200-DF-15	Drinking fountain, hall 200, across from room 219, left bubbler	<1.0		µg/L	
248-200-DF-16	Drinking fountain, hall 200, across from room 219, right bubbler	<1.0		µg/L	
Phase II Sampled on 4/21/2017					
248-121-SK-17	Classroom sink, room 121	<1.0		µg/L	
248-119-SK-18	Classroom sink, room 119, east wall	<1.0		µg/L	
248-119-SK-19	Classroom sink, room 119, south wall	<1.0		µg/L	
248-119-DF-20	Drinking fountain, room 119	<1.0		µg/L	
248-118-DF-21	Drinking fountain, room 118	<1.0		µg/L	
248-118-SK-22	Classroom sink, room 118, north wall	1.0		µg/L	
248-118-SK-23	Classroom sink, room 118, east wall	<1.0		µg/L	
248-103A-SK-24	LMC/IMC workroom sink, room 103A	2.0		µg/L	
248-117-SK-25	Classroom sink, room 117	<1.0		µg/L	
248-116-SK-26	Classroom sink, room 116	<1.0		µg/L	
248-104-SK-27	Classroom sink, room 104	<1.0		µg/L	
248-105-SK-28	Classroom sink, room 105	<1.0		µg/L	
248-115-SK-29	Classroom sink, room 115	<1.0		µg/L	
248-114-SK-30	Classroom sink, room 114	<1.0		µg/L	

248-113-SK-31	Classroom sink, room 113	<1.0		µg/L	
248-112-SK-32	Classroom sink, room 112	<1.0		µg/L	
248-211-SK-33	Staff workroom sink, room 211	1.0		µg/L	
248-212-SK-34	Classroom sink, room 212	2.0		µg/L	
248-214-SK-35	Classroom sink, room 214	18.0	1.0	µg/L	Replaced 11/2018
248-215-SK-36	Classroom sink, room 215	<1.0		µg/L	
248-216-SK-37	Classroom sink, room 216	<1.0		µg/L	
248-217-SK-38	Classroom sink, room 217	1.0		µg/L	
248-218-SK-39	Classroom sink, room 218	<1.0		µg/L	
248-219-SK-40	Classroom sink, room 219	<1.0		µg/L	
248-220-SK-41	Classroom sink, room 220	1.0		µg/L	
248-221-SK-42	Classroom sink, room 221	<1.0		µg/L	
248-222-SK-43	Classroom sink, room 222	1.0		µg/L	
248-223-SK-44	Classroom sink, room 223	<1.0		µg/L	
248-224-SK-45	Classroom sink, room 224	1.0		µg/L	
248-201-SK-46	Classroom sink, room 201	<1.0		µg/L	
248-204-SK-47	Classroom sink, room 204	1.0		µg/L	
248-206-SK-48	Classroom sink, room 206	1.0		µg/L	
248-207-SK-49	Classroom sink, room 207	<1.0		µg/L	
248-208-SK-50	Classroom sink, room 208	3.0		µg/L	
248-209-SK-51	Classroom sink, room 209	2.0		µg/L	
248-102G-SK-52	Conference room sink, room 102G	<1.0		µg/L	

*1. Result less than 1.0 ppb is the lowest level that can be reported by the lab.