

Henry World School (418)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Sample ID	Sample Description	Lead Result	Units	Action
Phase I Sampled on 11/1/2016				
418-150-SK-01	Kitchen prep sink, room 150, east wall	1.4	µg/L	
418-150-SK-02	Kitchen kettle fill, center of room 150	2.9	µg/L	
418-150-SK-03	Kitchen sink, right faucet, room 150, south wall	1.4	µg/L	
418-137-DF-04	Drinking fountain, hallway 137, next to room 103, left bubbler	1.4	µg/L	
418-137-DF-05	Drinking fountain, hallway 137, next to room 103, right bubbler	3.3	µg/L	
418-136-DF-06	Drinking fountain, hallway 136, next to girls locker room 125C, left bubbler	1.7	µg/L	
418-136-DF-07	Drinking fountain, hallway 136, next to girls locker room 125C, right bubbler	1.8	µg/L	
418-125-DF-08	Drinking fountain, south gymnasium 125, east wall	2.1	µg/L	
418-135-DF-09	Drinking fountain, north gymnasium 135, east wall	0.3	µg/L	
418-162A-SK-10	Nurse sink, room 162A	2.7	µg/L	
418-140-DF-11	Drinking fountain, hallway 140, across from room 122	0.9	µg/L	
418-142-DF-12	Drinking fountain, hallway 142, next to room 114, left bubbler	0.4	µg/L	
418-142-DF-13	Drinking fountain, hallway 142, next to room 114, right bubbler	0.9	µg/L	
418-225-DF-14	Drinking fountain, room 225	2.6	µg/L	
418-245-DF-15	Drinking fountain, hallway 245, across from room 211, left bubbler	2.0	µg/L	
418-245-DF-16	Drinking fountain, hallway 245, across from room 211, right bubbler	2.9	µg/L	
418-320-DF-17	Drinking fountain, hallway 320, across from room 312	0.9	µg/L	
418-312A-SK-18	Office sink, room 312A	2.8	µg/L	
418-310A-SK-19	Faculty lounge sink, room 310A	6.1	µg/L	
418-324B-SK-20	LMC/IMC sink, room 324B	4.4	µg/L	
418-321-DF-21	Drinking fountain, hallway 321, next to room 307, left bubbler	1.7	µg/L	
418-321-DF-22	Drinking fountain, hallway 321, next to room 307, right bubbler	0.9	µg/L	
418-161C-DF-23	Plumbed water cooler, faculty lounge, room 161C	<0.1*	µg/L	
Phase II Sampled on 9/29/2017				
418-141B-SK-24	Classroom sink, room 141B	1.9	µg/L	
418-224-SK-25	Classroom utility sink, room 224	2.0	µg/L	
418-225-SK-26	Shop utility sink, room 225	2.4	µg/L	
418-210-SK-27	Art room sink, room 210, right sink	2.8	µg/L	
418-210A-SK-28	Prep room sink, room 210A	4.9	µg/L	
418-209-SK-29	Classroom sink, room 209	2.5	µg/L	
418-208-SK-30	Classroom sink, room 208	4.2	µg/L	

418-211-SK-31	Classroom sink, room 211, north wall	2.1	µg/L	
418-211-SK-32	Classroom sink, room 211, south wall	5.2	µg/L	
418-213-SK-33	Classroom sink, room 213	12.5	µg/L	
418-212-SK-34	Classroom sink, room 212, north wall, far left sink	7.0	µg/L	
418-212-SK-35	Classroom sink, room 212, north wall, center left sink	4.7	µg/L	
418-212-SK-36	Classroom sink, room 212, north wall, far right sink	5.7	µg/L	
418-312-SK-37	Classroom sink, room 312, right sink	10.5	µg/L	
418-313-SK-38	Science lab sink, room 313, far left sink	2.8	µg/L	
418-313-SK-39	Science lab sink, room 313, center left sink	1.5	µg/L	
418-313-SK-40	Science lab sink, room 313, center right sink	7.2	µg/L	
418-313-SK-41	Science lab sink, room 313, far right sink	3.5	µg/L	
418-309-SK-42	Science lab sink, room 309, east wall, far left sink	6.0	µg/L	
418-309-SK-43	Science lab sink, room 309, east wall, far right sink	18.2	µg/L	
418-310-SK-44	Science lab sink, room 310, west wall, far left sink	3.9	µg/L	
418-310-SK-45	Science lab sink, room 310, west wall, center left sink	4.4	µg/L	
418-310-SK-46	Science lab sink, room 310, west wall, center right sink	6.1	µg/L	
418-308A-SK-47	Science prep sink, room 308A	>50.0	µg/L	Lab Sink – No Drinking Notice
418-307-SK-48	Science lab sink, room 307, east wall, far left sink	4.8	µg/L	
418-307-SK-49	Science lab sink, room 307, east wall, center left sink	13.7	µg/L	
418-307-SK-50	Science lab sink, room 307, east wall, center right sink	22.0	µg/L	Lab Sink – No Drinking Notice
418-307-SK-51	Science lab sink, room 307, east wall, far right sink	10.2	µg/L	
418-307-SK-52	Science lab sink, room 307, west wall, far left sink	32.5	µg/L	Lab Sink – No Drinking Notice
418-307-SK-53	Science lab sink, room 307, west wall, center left sink	>50.0	µg/L	Lab Sink – No Drinking Notice
418-307-SK-54	Science lab sink, west wall, center right sink	49.9	µg/L	Lab Sink – No Drinking Notice
418-307-SK-55	Science lab sink, west wall, far right sink	22.2	µg/L	Lab Sink – No Drinking Notice
418-308-SK-56	Science lab sink, room 308, east wall, far left sink	8.3	µg/L	
418-308-SK-57	Science lab sink, room 308, east wall, center left sink	16.7	µg/L	Lab Sink – No Drinking Notice
418-308-SK-58	Science lab sink, room 308, east wall, far right sink	11.8	µg/L	
418-308-SK-59	Science lab sink, room 308, west wall, far left sink	7.2	µg/L	
418-308-SK-60	Science lab sink, room 308, west wall, center left sink	25.1	µg/L	Lab Sink – No Drinking Notice
418-308-SK-61	Science lab sink, room 308, west wall, center right sink	23.4	µg/L	Lab Sink – No Drinking Notice
418-308-SK-62	Science lab sink, room 308, west wall, far right sink	9.8	µg/L	
418-324K-SK-63	LMC/IMC office sink, room 324K	2.2	µg/L	

*Result less than <0.1 ppb which is the lowest level that can be reported by the lab.