

## Hill Campus of Arts and Sciences (407)

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Sample ID	Sample Description	Lead Result	Units	Action
<b>Phase I Sampled on 10/26/2016</b>				
407-126D-SK-01	Kitchen sink, room 126D, south wall, on right	<1.0	µg/L	
407-126D-SK-02	Kettle fill, room 126D, center of kitchen	3.0	µg/L	
407-130-DF-03	Drinking fountain, south gymnasium 130	<1.0	µg/L	
407-131-DF-04	Drinking fountain, north gymnasium 131	<1.0	µg/L	
407-126-DF-05	Drinking fountain, cafeteria 126, north wall, west corner	2.0	µg/L	
407-126-DF-06	Drinking fountain, cafeteria 126, north wall, center (east corner INOP)	<1.0	µg/L	
407-116-DF-08	Drinking fountain, hallway 116m next to room 116C	<1.0	µg/L	
407-121D-SK-09	Nurse sink, room 121D	<1.0	µg/L	
407-115B-SK-10	Faculty lounge sink, room 115B	<1.0	µg/L	
407-100-DF-11	Drinking fountain, hallway 100, across from room 104A	<1.0	µg/L	
407-100-DF-12	Drinking fountain, hallway 100, next to room 110W	<1.0	µg/L	
407-200-DF-13	Drinking fountain, hallway 200, across from stair C	<1.0	µg/L	
407-200-DF-14	Drinking fountain, hallway 200, next to room 210	<1.0	µg/L	
407-212-SK-15	Classroom sink, room 212, north wall, on right	<1.0	µg/L	
407-204A-SK-16	Faculty lounge sink, room 204A	<1.0	µg/L	
407-220-DF-17	Drinking fountain, hallway 220, next to room 222	<1.0	µg/L	
407-224-DF-18	Office sink, room 224	<1.0	µg/L	
407-300-DF-19	Drinking fountain, hallway 300, across from stair C	<1.0	µg/L	
407-01-DF-20	Drinking fountain, hallway 01, next to room 21	<1.0	µg/L	
407-27-DF-21	Drinking fountain, girls locker room 27, east wall	<1.0	µg/L	
407-26-DF-22	Drinking fountain, auxiliary gym 26, east wall	<1.0	µg/L	
407-24-DF-23	Drinking fountain, boys locker room 24, east wall	<1.0	µg/L	
<b>Phase II Sampled on 9/20/2017</b>				
407-117-DF-24	Drinking fountain, music room 117	<0.1	µg/L	
407-117-SK-25	Music room sink, room 117	0.3	µg/L	
407-118-SK-26	Classroom sink, room 118, south wall	0.6	µg/L	
407-118-SK-27	Classroom sink, room 118, west wall	1.0	µg/L	
407-119-SK-28	Classroom sink, room 119, south wall	<0.1	µg/L	
407-19-DF-29	Drinking fountain, room 19	1.5	µg/L	
407-19-SK-30	Classroom sink, room 19	3.4	µg/L	
407-02-SK-31	Custodial office sink, room 02	0.9	µg/L	
407-17B-SK-32	Shop sink, room 17B	2.1	µg/L	
407-120-SK-33	Classroom sink, room, 120, north wall, left sink	0.2	µg/L	

<b>407-120-SK-34</b>	Classroom sink, room 120, north wall, right sink	5.0	µg/L	
<b>407-120-SK-35</b>	Classroom sink, room 120, east wall, far left sink	9.4	µg/L	
<b>407-120-SK-36</b>	Classroom sink, room 120, east wall, center left sink	1.1	µg/L	
<b>407-120-SK-37</b>	Classroom sink, room 120, east wall, center sink, right faucet	4.0	µg/L	
<b>407-120-SK-38</b>	Classroom sink, room 120, east wall, center sink, left faucet	0.4	µg/L	
<b>407-120-SK-39</b>	Classroom sink, room 120, east wall, center right sink	6.1	µg/L	
<b>407-120-SK-40</b>	Classroom sink, room 120, east wall, far right sink, right faucet	0.3	µg/L	
<b>407-120-SK-41</b>	Classroom sink, room 120, east wall, far right sink, left faucet	3.5	µg/L	
<b>407-120-SK-42</b>	Classroom hand sink, room 120, west wall	0.5	µg/L	
<b>407-213-SK-43</b>	Classroom sink, room 213, north wall, left sink	0.4	µg/L	
<b>407-213-SK-44</b>	Classroom sink, room 213, north wall, right sink	0.2	µg/L	
<b>407-212-SK-45</b>	Classroom sink, room 212, north wall, left sink	0.3	µg/L	
<b>407-212-SK-46</b>	Classroom sink, room 212, north wall, right sink	0.7	µg/L	
<b>407-211-SK-47</b>	Classroom sink, room 211	0.1	µg/L	
<b>407-210-SK-48</b>	Classroom sink, room 210	1.7	µg/L	
<b>407-208-SK-49</b>	Science lab sink, room 208, demonstration table, left sink	6.6	µg/L	
<b>407-208-SK-50</b>	Science lab sink, room 208, demonstration table, right sink	20.1	µg/L	Lab Sink – No Drinking Notice
<b>407-207-SK-51</b>	Science lab sink, room 207, demonstration sink	0.3	µg/L	
<b>407-207-SK-52</b>	Science lab sink, room 207, east wall, left sink	19.3	µg/L	Lab Sink – No Drinking Notice
<b>407-207-SK-53</b>	Science lab sink, room 207, east wall, center sink	7.8	µg/L	
<b>407-207-SK-54</b>	Science lab sink, room 207, east wall, right sink	7.0	µg/L	

\*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.