

Holm Elementary (294)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/23/2016				
Sample ID	Sample Description	Lead Result	Units	Action
294-136-df-01	Drinking fountain, cafeteria, west wall	2.5	µg/L	
294-136a-sk-02	Kitchen sink, west wall, left faucet	2.9	µg/L	
294-136a-sk-03	Kitchen sink, west wall, right faucet	2.2	µg/L	
294-100-df-04	Drinking fountain, hallway 100, next to auditorium, left bubbler	5.2	µg/L	
294-100-df-05	Drinking fountain, hallway 100, next to auditorium, right bubbler	1.3	µg/L	
294-101g-sk-06	Nurse sink, room 101G	3.5	µg/L	
294-137-sk-07	Faculty lounge sink, room 137	1.2	µg/L	
294-104-df-08	Drinking fountain, hallway 104, across from cafeteria	<1.0* ¹	µg/L	
294-135-df-09	Drinking fountain, gymnasium, next to doors	<1.0	µg/L	
291-126-df-10	Drinking fountain, hallway 126, next to room 111C	3.0	µg/L	
294-126-df-11	Drinking fountain, hallway 126, next to room 122	<1.0	µg/L	
294-119-df-12	Drinking fountain, room 119, next to restrooms	<1.0	µg/L	
294-105-df-13	Drinking fountain, hallway 105, next to room 119	<1.0	µg/L	
294-105-df-14	Drinking fountain, hallway 105, across from room 112	<1.0	µg/L	
294-105-df-15	Drinking fountain, hallway 105, across from room 109	2.5	µg/L	
Phase II Sampled on 4/7/2017				
294-134-SK-16	Classroom sink, room 134	5.0	µg/L	
294-133-SK-17	Classroom sink, room 133	4.0	µg/L	
294-130-SK-18	Classroom sink, room 130	2.0	µg/L	
294-131-SK-19	Classroom sink, room 131	26.0	µg/L	Removed during classroom renovation, Summer 2019
294-129-SK-20	Classroom sink, room 129	3.0	µg/L	
294-128-SK-21	Classroom sink, room 128	3.0	µg/L	
294-125-SK-22	Classroom sink, room 125	3.0	µg/L	
294-127-SK-23	Classroom sink, room 127	1.0	µg/L	
294-124-SK-24	Classroom sink, room 124	2.0	µg/L	
294-123-SK-25	Classroom sink, room 123	2.0	µg/L	
294-122-SK-26	Classroom sink, room 122	<1.0	µg/L	
294-121-SK-27	Classroom sink, room 121	2.0	µg/L	
294-120-SK-28	Classroom sink, room 120	3.0	µg/L	
294-119-SK-29	Classroom sink, room 119	<1.0	µg/L	
294-118-SK-30	Classroom sink, room 118	2.0	µg/L	

294-117-SK-31	Classroom sink, room 117	4.0	µg/L
294-115-SK-32	Classroom sink, room 115	<1.0	µg/L
294-114-SK-33	Classroom sink, room 114	<1.0	µg/L
294-112-SK-34	Classroom sink, room 112	1.0	µg/L
294-113-SK-35	Classroom sink, room 113	3.0	µg/L
294-110-SK-36	Classroom sink, room 110	5.0	µg/L
294-109-SK-37	Classroom sink, room 109	4.0	µg/L
294-106-SK-38	Classroom sink, room 106	1.0	µg/L
294-108-SK-39	Classroom sink, room 108, sink on right	<1.0	µg/L
294-132-SK-40	Classroom sink, room 132, sink on left	3.0	µg/L
294-107-SK-41	Classroom sink, room 107	2.0	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.