

Trevista @ Horace Mann (411)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/25/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
411-34A-SK-01	Sink, room 34A, next to cafeteria	7.0		µg/L	
411-34-DF-02	Drinking fountain, cafeteria, west wall	3.0		µg/L	
411-34-DF-03	Drinking fountain, cafeteria, east wall	3.0		µg/L	
411-40-DF-04	Drinking fountain, hallway 40, across from stair C	1.0		µg/L	
411-33-SK-05	Kitchen sink, room 33, east wall	6.0		µg/L	
411-33-SK-06	Kitchen kettle fill, room 33, next to range	>50.0	N/A	µg/L	Flush notice; removed summer 2018
411-33-SK-07	Kitchen kettle fill, room 33, next to steam kettle	>50.0	9.0	µg/L	Flush notice; filler replaced summer 2018
411-33-SK-08	Kitchen sink, room 33, northwest corner	<1.0*		µg/L	
411-20-DF-09	Drinking fountain, hallway 20, across from room 22	2.0		µg/L	
411-120-DF-10	Drinking fountain, hallway 120, across from room 122	3.0		µg/L	
411-121-SK-11	Faculty lounge sink, room 121	1.0		µg/L	
411-120-DF-12	Drinking fountain, hallway 120, across from gymnasium 126	2.0		µg/L	
411-129-DF-13	Drinking fountain, room 129	<1.0		µg/L	
411-129-SK-14	Classroom sink, room 129	10.0		µg/L	
411-128-SK-15	Classroom sink, room 128	8.0		µg/L	
411-128-DF-16	Drinking fountain, room 128	2.0		µg/L	
411-127A-DF-17	Drinking fountain, room 127A	2.0		µg/L	
411-126-DF-18	Drinking fountain, south gymnasium 126	2.0		µg/L	
411-100-DF-19	Drinking fountain, hallway 100, next to room 108B	<1.0		µg/L	
411-108-DF-20	Drinking fountain, room 108	<1.0		µg/L	
411-109-DF-21	Drinking fountain, room 109	<1.0		µg/L	
411-110-DF-22	Drinking fountain, room 110	<1.0		µg/L	
411-111-DF-23	Drinking fountain, room 111	<1.0		µg/L	
411-112-SK-24	Nurse sink, room 112	2.0		µg/L	
411-114D-SK-25	Admin office sink, room 114D	5.0		µg/L	
411-101D-SK-26	Faculty lounge sink, room 101D	3.6		µg/L	
411-100-DF-27	Drinking fountain, hallway 100, next to stair B	<1.0		µg/L	
411-220-DF-28	Drinking fountain, hallway 220, next to room 229	1.8		µg/L	
411-200-DF-29	Drinking fountain, hallway 200, across from room 214	0.5		µg/L	

411-200-DF-30	Drinking fountain, hallway 200, across from room 202	0.5	µg/L	
411-201B-SK-31	LMC/IMC sink, room 201B	5.4	µg/L	
411-300-DF-32	Drinking fountain, hallway 300, next to room 302	2.2	µg/L	
Phase II Sampled on 9/12/2017				
411-109-SK-33	Classroom sink, room 109, lower counter sink	3.0	µg/L	
411-108-SK-34	Classroom sink, room 108, lower counter sink	4.0	µg/L	
411-109-SK-35	Classroom sink, room 109, left sink	4.0	µg/L	
411-108-SK-36	Classroom sink, room 108, right sink	8.0	µg/L	
411-110-SK-37	Classroom sink, room 110, left sink	4.0	µg/L	
411-110-SK-38	Classroom sink, room 110, right sink	2.0	µg/L	
411-111-SK-39	Classroom sink, room 111, left sink	2.0	µg/L	
411-111-SK-40	Classroom sink, room 111, right sink	2.0	µg/L	
411-105-SK-41	Classroom sink, room 105	8.0	µg/L	
411-103-SK-42	Classroom sink, room 103, south wall	7.0	µg/L	
411-128-SK-43	Classroom sink, room 128, right sink	1.0	µg/L	
411-127-SK-44	Classroom sink, room 127, right sink	2.0	µg/L	
411-129-SK-45	Classroom sink, room 129, lower left sink	2.0	µg/L	
411-125-DF-46	Drinking fountain, gymnasium, room 125	5.0	µg/L	
411-24-SK-47	Shop sink, room 24	1.0	µg/L	
411-221-SK-48	Classroom sink, room 221, right sink	<1.0	µg/L	
411-222-SK-49	Science lab sink, room 222, left sink	6.0	µg/L	
411-222-SK-50	Science lab sink, room 222, right sink	20.0	µg/L	Lab Sink - No Drinking Notice
411-223-SK-51	Science lab sink, room, 223, left sink	3.0	µg/L	
411-223-SK-52	Science lab sink, room 223, right sink	5.0	µg/L	
411-225-SK-53	Science lab sink, room 225, north wall, left sink	20.0	µg/L	Lab Sink - No Drinking Notice
411-225-SK-54	Science lab sink, room 225, north wall, right sink	31.0	µg/L	Lab Sink - No Drinking Notice
411-228-SK-55	Classroom sink, room 228	2.0	µg/L	
411-229-SK-56	Classroom sink, room 229	2.0	µg/L	
411-225-SK-57	Science lab sink, room 225, east wall, far left sink	0.9	µg/L	
411-225-SK-58	Science lab sink, room 225, east wall, center left sink	0.9	µg/L	
411-225-SK-59	Science lab sink, room 225, east wall, center right sink	0.6	µg/L	
411-225-SK-60	Science lab sink, room 225, east wall, far right sink	6.6	µg/L	
411-225-SK-61	Science lab sink, room 225, demonstration sink	13.4	µg/L	

*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

1. Follow up action samples tested with Palintest SA1100 scanning analyzer. Flush sample result.