

## John F. Kennedy High School (453)

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled 11/5/2016					
Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
453-34-SK-01	Staff lounge sink, room 34	2.2		µg/L	
453-20-DF-02	Drinking fountain, hallway 20, next to room 37	7.6		µg/L	
453-06-DF-03	Drinking fountain, girls locker room 06	4.6		µg/L	
453-00-DF-04	Drinking fountain, hallway 00, next to room 10	1.4		µg/L	
453-13-DF-05	Drinking fountain, boys locker room 13, next to 13E	4.3		µg/L	
453-13-DF-06	Drinking fountain, boys locker room 13, next to 13M, left bubbler	1.8		µg/L	
453-13-DF-07	Drinking fountain, boys locker room 13, next to 13M, right bubbler	1.6		µg/L	
453-03-DF-08	Drinking fountain, music room 03	4.3		µg/L	
453-110-DF-09	Drinking fountain, hallway 110, next to room 112, left bubbler	3.0		µg/L	
453-110-DF-10	Drinking fountain, hallway 110, next to room 112, right bubbler	3.0		µg/L	
453-109-SK-11	Food prep sink, kitchen 109, northeast corner	1.0		µg/L	
453-109-SK-12	Food prep sink, kitchen 109, southeast corner	0.9		µg/L	
453-109-SK-13	Kettle fill, kitchen 109, near 109D	>50.0	<1.0	µg/L	Filler replaced Summer 2018
453-109-SK-14	Kettle fill, kitchen 109, near 109A	1.4		µg/L	
453-100-DF-15	Drinking fountain, hallway 100, next to 121B, left bubbler	1.6		µg/L	
453-100-DF-16	Drinking fountain, hallway 100, next to 121B, right bubbler	0.6		µg/L	
453-120-DF-17	Drinking fountain, gymnasium 120, east wall	2.4		µg/L	
453-120A-DF-18	Drinking fountain, gymnasium 120A, west wall	5.0		µg/L	
453-100-DF-19	Drinking fountain, hallway 100, across from room 123	0.7		µg/L	
453-103A-SK-20	Community room sink, room 103A	0.8		µg/L	
453-100-DF-21	Drinking fountain, hallway 100, across from room 126	1.5		µg/L	
453-101F-SK-22	Nurse sink, room 101F	1.8		µg/L	
453-125C-SK-23	Faculty lounge sink, room 125C	1.0		µg/L	
453-221-SK-24	Classroom sink, room 221	4.9		µg/L	
453-200-DF-25	Drinking fountain, hallway 200, next to room 220, left bubbler	2.0		µg/L	
453-200-DF-26	Drinking fountain, hallway 200, next to room 220, right bubbler	0.8		µg/L	
453-200-DF-27	Drinking fountain, hallway 200, next to elevator	1.8		µg/L	
453-210-SK-28	Faculty lounge sink, room 210	1.3		µg/L	
453-200-DF-29	Drinking fountain, hallway 200, next to room 205	1.2		µg/L	

453-300-DF-30	Drinking fountain, hallway 300, across from room 312, left bubbler	1.9		µg/L	
453-300-DF-31	Drinking fountain, hallway 300, across from room 312, right bubbler	1.6		µg/L	
453-300-DF-32	Drinking fountain, hallway 300, next to elevator	3.6		µg/L	
453-300-DF-33	Drinking fountain, hallway 300, next to room 306	1.7		µg/L	
453-326-SK-34	Office sink, room 326	2.0		µg/L	
453-400-DF-35	Drinking fountain, hallway 400, across from room 413, left bubbler	0.7		µg/L	
453-400-DF-36	Drinking fountain, hallway 400, across from room 413, right bubbler	0.8		µg/L	
453-400-DF-37	Drinking fountain, hallway 400, next to 400D	1.7		µg/L	
453-400-DF-38	Drinking fountain, hallway 400, next to room 402, left bubbler	2.1		µg/L	
453-400-DF-39	Drinking fountain, hallway 400, next to room 402, right bubbler	2.1		µg/L	
453A-150-DF-40	Drinking fountain, fitness center room 150, left bubbler	1.5		µg/L	
453A-150-DF-41	Drinking fountain, fitness center room 150, right bubbler	1.9		µg/L	
<b>Phase II Sampled 10/28/2018</b>					
453-111-SK-42	Classroom sink, room 111	3.0		µg/L	
453-105-DF-43	Drinking fountain, behind auditorium stage 105	24.0	14.0	µg/L	Bubbler replaced 5/2018
453-105D-SK-44	Auditorium storage sink, room 105D	5.0		µg/L	
453-214-SK-45	Classroom sink, room 214, west wall, left sink	11.0		µg/L	
453-214-SK-46	Classroom sink, room 214, west wall, right sink	11.0		µg/L	
453-214-SK-47	Classroom sink, room 214, east wall, far left sink	12.0		µg/L	
453-214-SK-48	Classroom sink, room 214, east wall, center left sink	3.0		µg/L	
453-214-SK-49	Classroom sink, room 214, east wall, center sink	3.0		µg/L	
453-214-SK-50	Classroom sink, room 214, east wall, center right sink	3.0		µg/L	
453-214-SK-51	Classroom sink, room 214, east wall, far right sink	6.0		µg/L	
453-214-SK-52	Classroom sink, room 214, south wall	17.0	5.0	µg/L	Faucet replaced 5/2018
453-216-SK-53	Classroom sink, room 216, north wall	5.0		µg/L	
453-216-SK-54	Classroom sink, room 216, east wall, far left sink	3.0		µg/L	
453-216-SK-55	Classroom sink, room 216, east wall, center left sink	4.0		µg/L	
453-216-SK-56	Classroom sink, room 216, east wall, center sink	6.0		µg/L	
453-216-SK-57	Classroom sink, room 216, east wall, right sink	4.0		µg/L	
453-216-SK-58	Classroom sink, room 216, east wall, far right sink	5.0		µg/L	
453-216-SK-59	Classroom sink, room 216, west wall, right sink	27.0	7.0	µg/L	Faucet replaced 5/2018
453-216-SK-60	Classroom sink, room 216, west wall, left sink	4.0		µg/L	
453-220-SK-61	Classroom sink, room 220, east wall	7.0		µg/L	

<b>453-308AA-SK-62</b>	Storage room sink, room 308AA	31.0	13.0	µg/L	Faucet replaced 5/2018
<b>453-312-SK-63</b>	Art room sink, room 212, left sink	4.0		µg/L	
<b>453-312-SK-64</b>	Art room sink, room 212, right sink	2.0		µg/L	
<b>453-313-SK-65</b>	Classroom sink, room 313, east wall, left sink	16.0	7.0	µg/L	Faucet replaced 5/2018
<b>453-313-SK-66</b>	Classroom sink, room 313, east wall, right sink	8.0		µg/L	
<b>453-316-SK-67</b>	Art room sink, room 316, left sink	2.0		µg/L	
<b>453-316-SK-68</b>	Art room sink, room 316, center sink	2.0		µg/L	
<b>453-316-SK-69</b>	Art room sink, room 316, right sink	2.0		µg/L	
<b>453-317-SK-70</b>	Art room sink, room 317, left sink	8.0		µg/L	
<b>453-317-SK-71</b>	Art room sink, room 317, center sink	10.0		µg/L	
<b>453-317-SK-72</b>	Art room sink, room 317, right sink	6.0		µg/L	
<b>453-318A-SK-73</b>	Office sink, room 318A	3.0		µg/L	
<b>453-424-SK-74</b>	Science lab sink, room 424, left sink	<1.0		µg/L	
<b>453-424-SK-75</b>	Science lab sink, room 424, right sink	2.0		µg/L	
<b>453-426-SK-76</b>	Science lab sink, room 426, far left sink	5.0		µg/L	
<b>453-426-SK-77</b>	Science lab sink, room 426, center left sink	8.0		µg/L	
<b>453-426-SK-78</b>	Science lab sink, room 426, center sink	4.0		µg/L	
<b>453-426-SK-79</b>	Science lab sink, room 426, center right sink	9.0		µg/L	
<b>453-426-SK-80</b>	Science lab sink, room 426, far right sink	5.0		µg/L	
<b>453-426B-SK-81</b>	Science prep sink, room 426B	11.0		µg/L	
<b>453-426A-SK-82</b>	Science prep sink, room 426A	12.0		µg/L	
<b>453-427-SK-83</b>	Science lab sink, room 427, far left sink	7.0		µg/L	
<b>453-427-SK-84</b>	Science lab sink, room 427, center left sink	7.0		µg/L	
<b>453-427-SK-85</b>	Science lab sink, room 427, center sink	6.0		µg/L	
<b>453-427-SK-86</b>	Science lab sink, room 427, center right sink	3.0		µg/L	
<b>453-427-SK-87</b>	Science lab sink, room 427, far right sink	4.0		µg/L	
<b>453-428-SK-88</b>	Science lab sink, room 428, east wall, far left sink	2.0		µg/L	
<b>453-428-SK-89</b>	Science lab sink, room 428, east wall, center left sink	1.0		µg/L	
<b>453-428-SK-90</b>	Science lab sink, room 428, east wall, center sink	1.0		µg/L	
<b>453-428-SK-91</b>	Science lab sink, room 428, east wall, center right sink	<1.0		µg/L	
<b>453-428-SK-92</b>	Science lab sink, room 428, east wall, far right sink	2.0		µg/L	
<b>453-428-SK-93</b>	Science lab sink, room 428, west wall, far left sink	4.0		µg/L	
<b>453-428-SK-94</b>	Science lab sink, room 428, west wall, center left sink	5.0		µg/L	
<b>453-428-SK-95</b>	Science lab sink, room 428, west wall, center right sink	3.0		µg/L	
<b>453-428-SK-96</b>	Science lab sink, room 428, west wall, far right sink	1.0		µg/L	
<b>453-428B-SK-97</b>	Science prep sink, room 428B	<1.0		µg/L	
<b>453-429-SK-98</b>	Science lab sink, room 429, west wall, far left sink	2.0		µg/L	
<b>453-429-SK-99</b>	Science lab sink, room 429, west wall, center left sink	<1.0		µg/L	
<b>453-429-SK-100</b>	Science lab sink, room 429, west wall, center sink	1.0		µg/L	

<b>453-429-SK-101</b>	Science lab sink, room 429, west wall, center right sink	1.0	µg/L	
<b>453-429-SK-102</b>	Science lab sink, room 429, west wall, far right sink	1.0	µg/L	
<b>453-429-SK-103</b>	Science lab sink, room 429, east wall, far left sink	2.0	µg/L	
<b>453-429-SK-104</b>	Science lab sink, room 429, east wall, center left sink	1.0	µg/L	
<b>453-429-SK-105</b>	Science lab sink, room 429, east wall, center right sink	2.0	µg/L	
<b>453-429-SK-106</b>	Science lab sink, room 429, east wall, far right sink	3.0	µg/L	
<b>453-401-SK-107</b>	Science lab sink, room 401, west wall	13.0	µg/L	
<b>453-401-SK-108</b>	Science lab sink, room 401, east wall	8.0	µg/L	
<b>453-401-SK-109</b>	Science lab sink, room 401, south wall	19.0	µg/L	Science Lab Notice
<b>453-401B-SK-110</b>	Science prep sink, room 401B	17.0	µg/L	Science Lab Notice
<b>453-402-SK-111</b>	Science lab sink, room 402, east wall, right sink	15.0	µg/L	Science Lab Notice
<b>453-402-SK-112</b>	Science lab sink, room 402, demonstration sink	37.0	µg/L	Science Lab Notice
<b>453-402B-SK-113</b>	Science prep sink, room 402B	11.0	µg/L	
<b>453-403-SK-114</b>	Science lab sink, room 403, east wall, left sink	7.0	µg/L	
<b>453-403-SK-115</b>	Science lab sink, room 403, east wall, center sink	2.0	µg/L	
<b>453-403-SK-116</b>	Science lab sink, room 403, east wall, right sink	7.0	µg/L	
<b>453-403-SK-117</b>	Science lab sink, room 403, east wall, far right sink	14.0	µg/L	