

KIPP Sunshine Peak Academy (426) – Sampled 10/5/2017

All results below 15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Sample ID	Sample Description	Lead Result	Units	Action
426-132-SK-01	Workroom sink, room 132	<1.0	µg/L	
426-100-DF-02	Drinking fountain, hallway 100, left bubbler	0.1	µg/L	
426-100-DF-03	Drinking fountain, hallway 100, right bubbler	0.2	µg/L	
426-154-SK-04	Classroom sink, room 154	1.9	µg/L	
426-158-SK-05	Classroom sink, room 158	<1.0	µg/L	
426-110-DF-06	Drinking fountain, hallway 110, left bubbler	<1.0	µg/L	
426-110-DF-07	Drinking fountain, hallway 110, right bubbler	<1.0	µg/L	
426-141-SK-08	Kitchen sink, room 141, left sink	0.8	µg/L	
426-141-SK-09	Kitchen sink, room 141, right sink	1.6	µg/L	
426A-COR-DF-10	Building 426A, left middle fountain	<0.1*	µg/L	
426A-COR-DF-11	Building 426A, right middle fountain	<0.1	µg/L	

*Result less than 0.1 ppb which is the lowest level that can be reported by the lab.