

## Kepner Middle School (408)

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

### Phase I Sampled on 10/25/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
408-139-DF-01	Drinking fountain, cafeteria, southwest corner, right bubbler	8.0		µg/L	
408-140-SK-02	Kitchen prep sink, room 140, west wall	2.0		µg/L	
408-140-SK-03	Kitchen kettle fill, center of room	8.0		µg/L	
408-135-DF-04	Drinking fountain, room 135	<1.0*		µg/L	
408-136A-SK-05	Classroom sink, room 136A	<1.0		µg/L	
408-131-DF-06	Drinking fountain, hallway 131, next to room 133	<1.0		µg/L	
408-132-DF-07	Drinking fountain, room 132	<1.0		µg/L	
408-137-DF-08	Drinking fountain, room 137	<1.0		µg/L	
408-129-DF-09	Drinking fountain, west gymnasium 126, northeast corner	4.0		µg/L	
408-120-DF-10	Drinking fountain, hallway 120, next to cafeteria 139, left bubbler	6.0		µg/L	
408-120-DF-11	Drinking fountain, hallway 120, next to cafeteria 139, right bubbler	6.0		µg/L	
408-127-DF-12	Drinking fountain, east gymnasium 127, northwest corner	5.0		µg/L	
408-141-SK-13	Classroom sink, room 141, northwest corner, left sink	10.0		µg/L	
408-141-SK-14	Classroom sink, room 141, northwest corner, right sink	2.0		µg/L	
408-123A-SK-15	Sink, room 123A	5.0		µg/L	
408-120-DF-16	Drinking fountain, hallway 120, across from room 145	<1.0		µg/L	
408-119-SK-17	Sink, room 119	3.0		µg/L	
408-100-DF-18	Drinking fountain, hallway 100, next to room 102, left bubbler	3.0		µg/L	
408-100-DF-19	Drinking fountain, hallway 100, next to room 102, right bubbler	2.0		µg/L	
408-102-SK-20	Nurse sink, room 102	4.0		µg/L	
408-100-DF-21	Drinking fountain, hallway 100, next to room 115, left bubbler	3.0		µg/L	
408-100-DF-22	Drinking fountain, hallway 100, next to room 115, right bubbler	4.0		µg/L	
408-113-SK-23	Classroom sink, room 113	3.0		µg/L	
408-100-DF-24	Drinking fountain, hallway 100, next to room 110, left bubbler	4.0		µg/L	

408-213-DF-25	Drinking fountain, hallway 213, next to room 218, left bubbler	5.0		µg/L	
408-213-DF-26	Drinking fountain, hallway 213, next to room 218, right bubbler	4.0		µg/L	
408-213-DF-27	Drinking fountain, hallway 213, next to room 213A	3.0		µg/L	
408-200-DF-28	Drinking fountain, hallway 200, across from room 211, left bubbler	4.0		µg/L	
408-210-SK-29	Classroom sink, room 210	29.0	<1.0	µg/L	Faucet Replaced June 2018.
408-209-SK-30	Classroom sink, room 209, left sink	<1.0		µg/L	
408-209-SK-31	Classroom sink, room 209, right sink	2.0		µg/L	
408-200-DF-32	Drinking fountain, hallway 200, next to room 209, left bubbler	5.0		µg/L	
408-200-DF-33	Drinking fountain, hallway 200, next to room 209, right bubbler	4.0		µg/L	
408-018-DF-34	Drinking fountain, hallway 018, next to room 018A	2.0		µg/L	
408-000-DF-35	Drinking fountain, hallway 000, next to room 003	6.0		µg/L	
408-015-SK-36	Classroom sink, room 015, east wall, on left	5.0		µg/L	
408-015-SK-37	Classroom sink, room 015, east wall, on right	1.0		µg/L	
408-000-DF-38	Drinking fountain, hallway 000, across from room 006	<1.0		µg/L	
408-013-SK-39	Classroom sink, room 013, south wall	2.0		µg/L	
408-008-SK-40	Classroom sink, room 008, north wall	2.0		µg/L	
408-012-SK-41	Classroom sink, room 012, south wall	2.0		µg/L	
408-000-DF-42	Drinking fountain, hallway 000, across from room 009	9.0		µg/L	
408-011-SK-43	Classroom sink, room 011, south wall	3.0		µg/L	
<b>Phase II Sampled on 9/14/2017</b>					
408-018B-SK-44	Custodial office sink, room 018B	1.0		µg/L	
408-016-DF-45	Classroom sink, room 016	1.0		µg/L	
408-014-SK-46	Classroom sink, room 014	<1.0		µg/L	
408-007-SK-47	Classroom sink, room 007	2.0		µg/L	
408-142-SK-48	Music room sink, room 142	5.0		µg/L	
408-141A-SK-49	Storage room sink, room 141A	<1.0		µg/L	
408-141-SK-50	Classroom sink, room 141, next to room 141A	<1.0		µg/L	
408-130-SK-51	Faculty lounge sink, room 130	<1.0		µg/L	
408-102-SK-52	Admin office sink, room 102	1.0		µg/L	
408-211-SK-53	Classroom sink, room 211	2.0		µg/L	
408-207-SK-54	Science lab sink, room 207, south wall, left sink	4.0		µg/L	
408-207-SK-55	Science lab sink, room 207, south wall, right sink	8.0		µg/L	
408-207-SK-56	Science lab sink, room 207, north wall, left sink	22.0		µg/L	Lab Sink - No Drinking Notice
408-206-SK-57	Science lab sink, room 206, south wall, left sink	28.0		µg/L	Lab Sink - No Drinking Notice
408-206-SK-58	Science lab sink, room 206, north wall, left sink	32.0		µg/L	Lab Sink - No Drinking Notice

<b>408-215-SK-59</b>	Classroom sink, room 215, east wall, far right sink	1.0	µg/L	
<b>408-215-SK-60</b>	Classroom sink, room 215, east wall, center right sink	1.0	µg/L	
<b>408-215-SK-61</b>	Classroom sink, room 215, east wall, center left sink	3.0	µg/L	
<b>408-215A-SK-62</b>	Storage room sink, room 215A	2.0	µg/L	
<b>408-216-SK-63</b>	Classroom sink, room 216, east wall, left sink	<1.0	µg/L	
<b>408-216-SK-64</b>	Classroom sink, room 216, east wall, right sink	<1.0	µg/L	
<b>408-218-SK-65</b>	Science lab sink, room 218, east wall, right sink	4.0	µg/L	
<b>408-218-SK-66</b>	Science lab sink, room 218, south wall	2.0	µg/L	
<b>408-218-SK-67</b>	Science lab sink, room 218, east wall, left sink	5.0	µg/L	
<b>408-206-SK-68</b>	Science lab sink, room 206, south wall, right sink	25.0	µg/L	Lab Sink - No Drinking Notice
<b>408-206-SK-69</b>	Science lab sink, room 206, north wall, right sink	31.0	µg/L	Lab Sink - No Drinking Notice
<b>408-207-SK-70</b>	Science lab sink, room 207, north wall, right sink	>50.0	µg/L	Lab Sink - No Drinking Notice
<b>408-208-SK-71</b>	Science lab sink, room 208, north wall, right sink	34.0	µg/L	Lab Sink - No Drinking Notice
<b>408-208-SK-72</b>	Science lab sink, room 208, north wall, left sink	29.0	µg/L	Lab Sink - No Drinking Notice
<b>408-208-SK-73</b>	Science lab sink, room 208, south wall, left sink	23.0	µg/L	Lab Sink - No Drinking Notice
<b>408-208-SK-74</b>	Science lab sink, room 208, south wall, right sink	47.0	µg/L	Lab Sink - No Drinking Notice

\*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.