

## Dr. Martin Luther King, Jr. Early College (419)

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

### Phase I Sampled 11/1/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
419-186-DF-01	Drinking fountain, all purpose room 186, northeast corner	<1.0*		µg/L	
419-140-DF-02	Drinking fountain, room 140, north wall	2.0		µg/L	
419-189-SK-03	Kitchen kettle faucet, room 189, center of room	27.0	4.0	µg/L	Flush notice; faucet replaced 12/2018
419-189-SK-04	Kitchen sink, room 189, southeast corner	2.0		µg/L	
419-196F-SK-05	Nurse sink, room 196F	2.0		µg/L	
419-195-DF-06	Drinking fountain, hallway 198, across from room 196	<1.0		µg/L	
419-195-DF-07	Bottle filler, hallway 198, across from room 196	<1.0		µg/L	
419-178-DF-08	Drinking fountain, north gymnasium 178, northeast corner	<1.0		µg/L	
419-178A-DF-09	Drinking fountain, north gymnasium 178, northwest corner	12.0		µg/L	
419-179A-DF-10	Drinking fountain, south gymnasium 179, southwest corner	2.0		µg/L	
419-178-DF-11	Drinking fountain, south gymnasium 179, southeast corner	<1.0		µg/L	
419-147T-DF-12	Drinking fountain, hallway 147T, next to room 147D	<1.0		µg/L	
419-199G-SK-13	Community room sink, room 199G, south wall	2.0		µg/L	
419-147O-SK-14	Admin office sink, room 147D, north wall	<1.0		µg/L	
419-147-DF-15	Drinking fountain, hallway 147, next to room 109	<1.0		µg/L	
419-146-DF-16	Drinking fountain, hallway 146, next to room 107	<1.0		µg/L	
419-292-DF-17	Drinking fountain, hallway 292, next to room 264	<1.0		µg/L	
419-282-DF-18	Drinking fountain, hallway 282, next to room 211	<1.0		µg/L	
419-273-DF-19	Drinking fountain, hallway 273, next to room 213	<1.0		µg/L	
419-252-SK-20	Admin workroom sink, room 252, south wall	5.0		µg/L	
419-290-DF-21	Drinking fountain, hallway 290, next to room 237B, left bubbler	<1.0		µg/L	
419-290-DF-22	Drinking fountain, hallway 290, next to room 237B, right bubbler	<1.0		µg/L	
419-238-SK-23	Faculty lounge sink, room 238	1.0		µg/L	
419-282-DF-24	Drinking fountain, hallway 282, next to room 228	<1.0		µg/L	
419-273-DF-25	Drinking fountain, hallway 273, next to room 225	<1.0		µg/L	

**Phase II Sampled on 9/26-27/2017**

<b>419-196A-SK-26</b>	Admin office sink, room 196A	<1.0	µg/L	
<b>419-196E-SK-27</b>	Nurse office sink, room 196E	<1.0	µg/L	
<b>419-101A-SK-28</b>	LMC/IMC office sink, room 101A	3.0	µg/L	
<b>419-174-SK-29</b>	Faculty workroom sink, room 174	<1.0	µg/L	
<b>419-141-SK-30</b>	Classroom sink, room 141, south wall, left sink	<1.0	µg/L	
<b>419-141-SK-31</b>	Classroom sink, room 141 south wall, right sink	<1.0	µg/L	
<b>419-140-SK-32</b>	Classroom sink, room 140, north wall	1.0	µg/L	
<b>419-138-SK-33</b>	Classroom sink, room 138, north wall	<1.0	µg/L	
<b>419-137-SK-34</b>	Classroom sink, room 137, west wall	<1.0	µg/L	
<b>419-136-SK-35</b>	Science lab sink, room 136, north wall, right sink	5.0	µg/L	
<b>419-115-SK-36</b>	Science lab sink, room 115, west wall, right sink	14.0	µg/L	
<b>419-115-SK-37</b>	Science lab sink, room 115, west wall, center sink	10.0	µg/L	
<b>419-115-SK-38</b>	Science lab sink, room 115, west wall, left sink	17.0	µg/L	Lab Sink – No Drinking Notice
<b>419-115-SK-39</b>	Science lab sink, room 115, south wall, center sink	4.0	µg/L	
<b>419-115-SK-40</b>	Science lab sink, room 115, south wall, left sink	4.0	µg/L	
<b>419-115-SK-41</b>	Science lab sink, room 115, south wall, far left sink	4.0	µg/L	
<b>419-115-SK-42</b>	Science lab sink, room 115, east wall, right sink	5.0	µg/L	
<b>419-115-SK-43</b>	Science lab sink, room 115, east wall, center sink	6.0	µg/L	
<b>419-115B-SK-44</b>	Science prep room sink, room 115B	39.0	µg/L	Lab Sink – No Drinking Notice
<b>419-113-SK-45</b>	Science lab sink, room 113, west wall, left sink	5.0	µg/L	
<b>419-113-SK-46</b>	Science lab sink, room 113, west wall, right sink	9.0	µg/L	
<b>419-113-SK-47</b>	Science lab sink, room 113, north wall, left sink	10.0	µg/L	
<b>419-113-SK-48</b>	Science lab sink, room 113, north wall, right sink	8.0	µg/L	
<b>419-106-SK-49</b>	Science lab sink, room 106, south wall, left sink	15.0	µg/L	Lab Sink – No Drinking Notice
<b>419-106-SK-50</b>	Science lab sink, room 106, south wall, right sink	11.0	µg/L	
<b>419-106-SK-51</b>	Science lab sink, room 106, north wall, left sink	4.0	µg/L	
<b>419-106-SK-52</b>	Science lab sink, room 106, north wall, center sink	7.0	µg/L	
<b>419-106-SK-53</b>	Science lab sink, room 106, north wall, right sink	12.0	µg/L	
<b>419-114-SK-54</b>	Science lab sink, room 114, west wall, right sink	11.0	µg/L	
<b>419-114-SK-55</b>	Science lab sink, room 114, north wall, left sink	37.0	µg/L	Lab Sink – No Drinking Notice
<b>419-114-SK-56</b>	Science lab sink, room 114, north wall, right sink	38.0	µg/L	Lab Sink – No Drinking Notice
<b>419-114-SK-57</b>	Science lab sink, room 114, east wall, left sink	9.0	µg/L	
<b>419-114-SK-58</b>	Science lab sink, room 114, east wall, center sink	36.0	µg/L	Lab Sink – No Drinking Notice
<b>419-114-SK-59</b>	Science lab sink, room 114, east wall, right sink	12.0	µg/L	
<b>419-123-SK-60</b>	Science lab sink, room 123, west wall, right sink	2.0	µg/L	
<b>419-189-SK-61</b>	Kitchen kettle fill, room 189, west side of partition wall	23.0	N/A	µg/L Removed 12/2018

419-122-SK-62	Science lab sink, room 122, west wall, left sink	21.0		µg/L	Lab Sink – No Drinking Notice
419-122-SK-63	Science lab sink, room 122, west wall, center sink	25.0		µg/L	Lab Sink – No Drinking Notice
419-122-SK-64	Science lab sink, room 122, west wall, right sink	10.0		µg/L	
419-122-SK-65	Science lab sink, room 122, north wall, far left sink	10.0		µg/L	
419-122-SK-66	Science lab sink, room 122, north wall, left sink	19.0		µg/L	Lab Sink – No Drinking Notice
419-122-SK-67	Science lab sink, room 122, north wall, center sink	25.0		µg/L	Lab Sink – No Drinking Notice
419-122-SK-68	Science lab sink, room 122, north wall, right sink	8.0		µg/L	
419-122-SK-69	Science lab sink, room 122, north wall, far right sink	5.0		µg/L	
419-122-SK-70	Science lab sink, room 122, east wall, left sink	20.0		µg/L	Lab Sink – No Drinking Notice
419-122-SK-71	Science lab sink, room 122, east wall, center sink	13.0		µg/L	
419-122-SK-72	Science lab sink, room 122, east wall, right sink	5.0		µg/L	
419-200B-SK-73	Classroom sink, room 200B, north wall, left sink	42.0	3.0	µg/L	Faucet replaced 4/2018
419-200B-SK-74	Classroom sink, room 200B, north wall, right sink	24.0	3.0	µg/L	Faucet replaced 4/2018
419-200B-SK-75	Classroom sink, room 200B, east wall, left sink	8.0		µg/L	
419-200B-SK-76	Classroom sink, room 200B, east wall, right sink	8.0		µg/L	
419-201-SK-77	Classroom sink, room 201, west wall, left sink	2.0		µg/L	
419-201-SK-78	Classroom sink, room 201, west wall, right sink	3.0		µg/L	
419-201-SK-79	Classroom sink, room 201, east wall, left sink	1.0		µg/L	
419-201-SK-80	Classroom sink, room 201, east wall, right sink	<1.0		µg/L	
419-202-SK-81	Classroom sink, room 202, east wall, left sink	<1.0		µg/L	
419-202-SK-82	Classroom sink, room 202, east wall, right sink	3.0		µg/L	
419-202-SK-83	Classroom sink, room 202, west wall, left sink	1.0		µg/L	
419-202-SK-84	Classroom sink, room 202, west wall, right sink	1.0		µg/L	
419-206-SK-85	Science lab sink, room 206, east wall, left sink	14.0		µg/L	
419-206-SK-86	Science lab sink, room 206, east wall, center sink	9.0		µg/L	
419-206-SK-87	Science lab sink, room 206, east wall, right sink	6.0		µg/L	
419-206-SK-88	Science lab sink, room 206, south wall	6.0		µg/L	
419-214-SK-89	Science lab sink, room 214, east wall, right sink	4.0		µg/L	
419-214-SK-90	Science lab sink, room 214, east wall, center sink	10.0		µg/L	
419-214-SK-91	Science lab sink, room 214, east wall, left sink	1.0		µg/L	
419-214-SK-92	Science lab sink, room 214, north wall	7.0		µg/L	
419-215-SK-93	Science lab sink, room 215, west wall, right sink	8.0		µg/L	
419-215-SK-94	Science lab sink, room 215, west wall, center sink	7.0		µg/L	
419-215-SK-95	Science lab sink, room 215, west wall, left sink	5.0		µg/L	
419-215-SK-96	Science lab sink, room 215, south wall, far right sink	19.0		µg/L	Lab Sink – No Drinking Notice
419-215-SK-97	Science lab sink, room 215, south wall, center right sink	7.0		µg/L	

<b>419-215-SK-98</b>	Science lab sink, room 215, south wall, center sink	18.0	µg/L	Lab Sink – No Drinking Notice
<b>419-215-SK-99</b>	Science lab sink, room 215, south wall, center left sink	11.0	µg/L	
<b>419-215-SK-100</b>	Science lab sink, room 215, south wall, far left sink	8.0	µg/L	
<b>419-215-SK-101</b>	Science lab sink, room 215, east wall, right sink	4.0	µg/L	
<b>419-215-SK-102</b>	Science lab sink, room 215, east wall, center sink	5.0	µg/L	
<b>419-215-SK-103</b>	Science lab sink, room 215, east wall, left sink	2.0	µg/L	
<b>419-215A-SK-104</b>	Science prep sink, room 215A	25.0	µg/L	Lab Sink – No Drinking Notice
<b>419-223-SK-105</b>	Science lab sink, room 223, west wall, left sink	16.0	µg/L	Lab Sink – No Drinking Notice
<b>419-223-SK-106</b>	Science lab sink, room 223, west wall, center sink	15.0	µg/L	Lab Sink – No Drinking Notice
<b>419-223-SK-107</b>	Science lab sink, room 223, west wall, right sink	18.0	µg/L	Lab Sink – No Drinking Notice
<b>419-223-SK-108</b>	Science lab sink, room 223, north wall, far left sink	20.0	µg/L	Lab Sink – No Drinking Notice
<b>419-223-SK-109</b>	Science lab sink, room 223, north wall, center right sink	11.0	µg/L	
<b>419-223-SK-110</b>	Science lab sink, room 223, north wall, far right sink	9.0	µg/L	
<b>419-223-SK-111</b>	Science lab sink, room 223, east wall, left sink	11.0	µg/L	
<b>419-223-SK-112</b>	Science lab sink, room 223, east wall, center sink	7.0	µg/L	
<b>419-223-SK-113</b>	Science lab sink, room 223, east wall, right sink	3.0	µg/L	
<b>419-224-SK-114</b>	Science lab sink, room 224, east wall, left sink	3.0	µg/L	
<b>419-224-SK-115</b>	Science lab sink, room 224, east wall, center sink	2.0	µg/L	
<b>419-224-SK-116</b>	Science lab sink, room 224, east wall, right sink	4.0	µg/L	
<b>419-224-SK-117</b>	Science lab sink, room 224, south wall	5.0	µg/L	
<b>419-231-SK-118</b>	Science lab sink, room 231, east wall, right sink	6.0	µg/L	
<b>419-231-SK-119</b>	Science lab sink, room 231, east wall, center sink	21.0	µg/L	Lab Sink – No Drinking Notice
<b>419-231-SK-120</b>	Science lab sink, room 231, east wall, left sink	18.0	µg/L	Lab Sink – No Drinking Notice
<b>419-231-SK-121</b>	Science lab sink, room 231, north wall	16.0	µg/L	Lab Sink – No Drinking Notice

\*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.