

Lake Middle School (410)

All results <15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Sample ID	Sample Description	Lead Result	Units	Action
Phase I Sampled on 10/21/2016				
410-000-DF-01	Bottle fill, hallway 000, across from room 011	<1.0*	µg/L	
410-000-DF-02	Drinking fountain, hallway 000, across from room 011, left bubbler	<1.0	µg/L	
410-000-DF-03	Drinking fountain, hallway 000, across from room 011, right bubbler	<1.0	µg/L	
410-100-DF-04	Bottle fill, hallway 100, next to stair D	<1.0	µg/L	
410-100-DF-05	Drinking fountain, hallway 100, next to stair D, left bubbler	<1.0	µg/L	
410-100-DF-06	Drinking fountain, hallway 100, next to stair D, right bubbler	<1.0	µg/L	
410-103-SK-07	Faculty lounge sink, room 103	<1.0	µg/L	
410-100-DF-08	Drinking fountain, hallway 100, next to room 104	<1.0	µg/L	
410-106-SK-09	Kitchen prep sink, northeast corner, room 106	<1.0	µg/L	
410-106-SK-10	Kitchen kettle fill, center of room 106	<1.0	µg/L	
410-105-DF-11	Drinking fountain, cafeteria 105, northwest corner	2.2	µg/L	
410-109-DF-12	Drinking fountain, weight room 109	2.5	µg/L	
410-112-DF-13	Drinking fountain, north gymnasium 112	<1.0	µg/L	
410-114-DF-14	Drinking fountain, south gymnasium 114	<1.0	µg/L	
410-118-DF-15	Bottle fill, hallway 118, across from room 136	<1.0	µg/L	
410-118-DF-16	Drinking fountain, hallway 118, across from room 136, left bubbler	<1.0	µg/L	
410-118-DF-17	Drinking fountain, hallway 118, across from room 136, right bubbler	<1.0	µg/L	
410-123-DF-18	Drinking fountain, hallway 123, next to room 130, right bubbler	<1.0	µg/L	
410-124-DF-19	Drinking fountain, hallway 124, across from room 128, left bubbler	<1.0	µg/L	
410-124-DF-20	Drinking fountain, hallway 124, across from room 128, right bubbler	<1.0	µg/L	
410-200-DF-21	Drinking fountain, hallway 200, next to stair D	<1.0	µg/L	
410-200-DF-22	Bottle fill, hallway 200, across from room 203	<1.0	µg/L	
410-200-DF-23	Drinking fountain, hallway 200, across from room 203, left bubbler	<1.0	µg/L	
410-200-DF-24	Drinking fountain, hallway 200, across from room 203, right bubbler	<1.0	µg/L	
410-210-DF-25	Bottle fill, hallway 210, next to room 212	<1.0	µg/L	
410-210-DF-26	Drinking fountain, hallway 210, next to room 212, left bubbler	<1.0	µg/L	
410-210-DF-27	Drinking fountain, hallway 210, next to room 212, right bubbler	<1.0	µg/L	
410-217-DF-28	Bottle fill, hallway 217, next to stair M	<1.0	µg/L	
410-217-DF-29	Drinking fountain, hallway 217, next to stair M, left bubbler	<1.0	µg/L	
410-217-DF-30	Drinking fountain, hallway 217, next to stair M, right bubbler	<1.0	µg/L	
410-218-DF-31	Drinking fountain, hallway 218, next to room 221, left bubbler	<1.0	µg/L	
410-218-DF-32	Drinking fountain, hallway 218, next to room 221, right bubbler	<1.0	µg/L	
410-300-DF-33	Bottle fill, hallway 300, across from room 304	<1.0	µg/L	
410-300-DF-34	Drinking fountain, hallway 300, across from room 304, right bubbler	<1.0	µg/L	

410-300-DF-35	Drinking fountain, hallway 300, across from room 304, left bubbler	<1.0	µg/L
410-300-DF-36	Drinking fountain, hallway 300, across from room 308	<1.0	µg/L
Phase II Sampled on 9/15/2017			
410-009-BF-37	Bottler filler, room 009	<1.0	µg/L
410-107-SK-38	Classroom sink, room 107	1.0	µg/L
410-132-SK-39	Science lab sink, room 132, demonstration sink	2.0	µg/L
410-132-SK-40	Science lab sink, room 132, left sink	3.0	µg/L
410-132-SK-41	Science lab sink, room 132, center sink	4.0	µg/L
410-132-SK-42	Science lab sink, room 132, right sink	2.0	µg/L
410-131-SK-43	Science lab sink, room 131, left sink	<1.0	µg/L
410-131-SK-44	Science lab sink, room 131, center sink	<1.0	µg/L
410-131-SK-45	Science lab sink, room 131, right sink	<1.0	µg/L
410-131-SK-46	Science lab sink, room 131, demonstration sink	<1.0	µg/L
410-130-SK-47	Science lab sink, room 130, north wall, left sink	6.0	µg/L
410-130-SK-48	Science lab sink, room 130, north wall, center sink	6.0	µg/L
410-130-SK-49	Science lab sink, room 130, north wall, right sink	12.0	µg/L
410-130-SK-72	Science lab sink, room 130, south wall, far left sink	1.1	µg/L
410-130-SK-73	Science lab sink, room 130, south wall, center left sink	2.0	µg/L
410-130-SK-74	Science lab sink, room 130, south wall, center sink	2.6	µg/L
410-130-SK-75	Science lab sink, room 130, south wall, center right sink	2.0	µg/L
410-130-SK-76	Science lab sink, room 130, south wall, far right sink	2.6	µg/L
410-130-SK-77	Science lab sink, room 130, demonstration sink	1.5	µg/L
410-125-SK-55	Classroom sink, room 125	<1.0	µg/L
410-126-SK-56	Classroom sink, room 126	1.0	µg/L
410-127-SK-57	Classroom sink, room 127	<1.0	µg/L
410-128-SK-58	Art room sink, room 128, left sink	<1.0	µg/L
410-128-SK-59	Art room sink, room 128, right sink	3.0	µg/L
410-208-SK-60	Art room sink, room 208, left sink	4.0	µg/L
410-208-SK-61	Art room sink, room 208, center sink	1.0	µg/L
410-208-SK-62	Art room sink, room 208, right sink	2.0	µg/L
410-207-SK-63	Classroom sink, room 207	<1.0	µg/L
410-220-SK-64	Classroom sink, room 220	<1.0	µg/L
410-221-SK-65	Classroom sink, room 221	<1.0	µg/L
410-222-SK-66	Classroom sink, room 222	<1.0	µg/L
410-304-SK-67	Classroom sink, room 304	<1.0	µg/L
410-303-SK-68	Classroom sink, room 303	3.0	µg/L
410-306-SK-69	Classroom sink, room 306	<1.0	µg/L
410-307-SK-70	Classroom sink, room 307	5.0	µg/L
410-231C-SK-71	Faculty workroom sink, room 231C	2.9	µg/L

*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.