

Lincoln Elementary (252)

Sample ID Key:

Building number – room number – fixture type (DF – drinking fountain, SK – sink) – consecutive sample number

Phase I Sampling 8/24/2016						
Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action	
252-100-DF-01	Drinking fountain, hallway 100, right	<1.0*1		µg/L		
252-100-DF-2	Drinking fountain, hallway 100, left	<1.0		µg/L		
252-101-DF-3	Drinking fountain, cafeteria, right	<1.0		µg/L		
252-101-DF-4	Drinking fountain, cafeteria, left	<1.0		µg/L		
252-104-DF-5	Drinking fountain, hallway 104, next to room 106	1.4		µg/L		
252-110-DF-6	Drinking fountain, hallway 110, next to stair D	<1.0		µg/L		
252-205-DF-7	Drinking fountain, hallway 205, next to room 208	<1.0		µg/L		
252-205C-DF-8	Drinking fountain, near restrooms	<1.0		µg/L		
252-200-DF-9	Drinking fountain, hallway 200, next to room 210	2.3		µg/L		
252-300-DF-10	Drinking fountain, hallway 300, next to room 303	4.4		µg/L		
252-304-DF-11	Drinking fountain, hallway 304, next to restrooms	<1.0		µg/L		
252-304D-DF-12	Drinking fountain, hallway 304D, next to room 310	<1.0		µg/L		
252-210-SK-13	Sink, faculty lounge, room 210	3.1		µg/L		
252-102-SK-14	Kitchen sink, next to oven	2.6		µg/L		
252-102-SK-15	Kitchen sink, next to office, left	16.7	2.0	µg/L	Faucet replaced 11/2018	
252-102-SK-16	Kitchen sink, next to office, right	2.9		µg/L		
Phase II Sampled on 1/19/2017						
252-106-SK-17	Classroom sink, room 106	3.0		µg/L		
252-105-SK-18	Classroom sink, room 105	4.0		µg/L		
252-111-SK-19	Classroom sink, room 111	3.0		µg/L		
252-113-SK-20	Classroom sink, room 113	3.0		µg/L		
252-112-SK-21	Classroom sink, room 112	2.0		µg/L		
252-201-SK-22	Classroom sink, room 201	3.0		µg/L		
252-202-SK-23	Classroom sink, room 202	3.0		µg/L		
252-203-SK-24	Classroom sink, room 203	6.0		µg/L		
252-206-SK-25	Classroom sink, room 206	5.0		µg/L		
252-209B-SK-26	Workroom sink, room 209B	3.0		µg/L		

252-301-SK-27	Classroom sink, room 301	3.0	µg/L
252-302-SK-28	Classroom sink, room 302	2.0	µg/L
252-303-SK-29	Classroom sink, room 303	3.0	µg/L
252-305-SK-30	Classroom sink, room 305	3.0	µg/L
252-306-SK-31	Office sink, room 306	9.0	µg/L
252-307-SK-32	Classroom sink, room 307	7.0	µg/L
252-309-SK-33	Classroom sink, room 309	5.0	µg/L
252-310-SK-34	Classroom sink, room 310	<1.0	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.