

## Manual High School (454)

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

### Phase I Sampled on 10/29/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
454-100-DF-01	Drinking fountain, lobby 100, next to south entrance	1.0		µg/L	
454-100-DF-02	Drinking fountain, lobby 100, between 100A and 100B, right bubbler	<1.0		µg/L	
454-100-DF-03	Drinking fountain, lobby 100, between 100A and 100B, left bubbler	<1.0		µg/L	
454-117-DF-04	Drinking fountain, cafeteria 117, northeast corner	<1.0		µg/L	
454-117-DF-05	Drinking fountain, cafeteria 117, southeast corner	1.0		µg/L	
454-105-DF-06	Drinking fountain, hallway 105, across from room 110	2.0		µg/L	
454-105-DF-07	Drinking fountain, hallway 105, next to stair D	<1.0		µg/L	
454-103-SK-08	Faculty lounge sink, room 103	<1.0		µg/L	
454-116-SK-09	Food prep sprayer, kitchen 116, east wall	1.0		µg/L	
454-116-SK-10	Food prep sink, kitchen 116, east wall	4.0		µg/L	
454-116-SK-11	Kettle fill, kitchen 116, west wall, next to steam kettle	>50.0 (6.0* <sup>1</sup> flush)	6.0	µg/L	Flush notice posted, filler replaced summer 2018
454-128-DF-12	Drinking fountain, auxiliary gymnasium 128, northwest corner	18.0	N/A	µg/L	Cut and cap 12/2018
454-128-DF-13	Drinking fountain, auxiliary gymnasium 128, northeast corner	13.0		µg/L	
454-142-DF-14	Drinking fountain hallway 142, next to stair J	8.0		µg/L	
454-129-DF-15	Drinking fountain, dance room 129, east wall	2.0		µg/L	
454-120-DF-16	Drinking fountain, hallway 120, across from room 139	<1.0		µg/L	
454-139-SK-17	Classroom sink, room 139	10.0		µg/L	
454-132-DF-18	Drinking fountain, hallway 132, next to room 136, left bubbler	<1.0		µg/L	
454-132-DF-19	Drinking fountain, hallway 132, next to room 136, right bubbler	<1.0		µg/L	
454-132-DF-20	Drinking fountain, hallway 132, next to girls locker room 134	<1.0		µg/L	
454-131-DF-21	Drinking fountain, gymnasium 131, northeast corner	<1.0		µg/L	
454-131-DF-22	Drinking fountain, gymnasium 131, southeast corner	1.0		µg/L	
454-137-DF-23	Drinking fountain, swim pool 137, east wall	<1.0		µg/L	
454-137-DF-24	Drinking fountain, swim pool 137, south wall	<1.0		µg/L	
454-216-SK-25	Faculty lounge sink, room 216	<1.0		µg/L	
454-205-DF-26	Drinking fountain, hallway 205, next to room 216	<1.0		µg/L	
454-218-SK-27	LMC/IMC sink, room 218	1.0		µg/L	
454-205-DF-28	Drinking fountain, hallway 205, next to room 206	<1.0		µg/L	

454-204-SK-29	Classroom sink, room 204	<1.0	µg/L	
454-201-DF-30	Drinking fountain, hallway 201, next to room 221	<1.0	µg/L	
454-200-DF-31	Drinking fountain, lobby 200, south end across from restrooms	<1.0	µg/L	
454-232-DF-32	Drinking fountain, room 232, east wall	3.0	µg/L	
454-306-DF-33	Drinking fountain, hallway 306, next to room 314	<1.0	µg/L	
454-306-DF-34	Drinking fountain, hallway 306, next to room 307	<1.0	µg/L	
454-300-DF-35	Drinking fountain, hallway 300, next to room 324	2.0	µg/L	
454-300-DF-36	Drinking fountain, hallway 300, next to mechanical room 300E	<1.0	µg/L	
<b>Phase II Sampled on 10/14/2017</b>				
454-010-SK-37	Custodial breakroom sink, room 010	1.6	µg/L	
454-111-SK-38	Science lab sink, room 111, north wall, left sink	1.5	µg/L	
454-111-SK-39	Science lab sink, room 111, north wall, right sink	0.8	µg/L	
454-112-SK-40	Science lab sink, room 112, south wall, left sink	0.7	µg/L	
454-112-SK-41	Science lab sink, room 112, south wall, right sink	1.2	µg/L	
454-112-SK-42	Science lab sink, room 112, east wall	0.6	µg/L	
454-228-SK-43	Art room sink, room 228	1.4	µg/L	
454-202-SK-44	Science room sink, room 202, demonstration sink, next to west wall	32.6	µg/L	Lab Sink – No Drinking Notice
454-202-SK-45	Science room sink, room 202, second island sink, left faucet	4.1	µg/L	
454-202-SK-46	Science room sink, room 202, second island sink, right faucet	4.3	µg/L	
454-202-SK-47	Science room sink, room 202, third island sink, left faucet	5.1	µg/L	
454-202-SK-48	Science room sink, room 202, third island sink, right faucet	1.2	µg/L	
454-202-SK-49	Science room sink, room 202, fourth island sink, left faucet	1.8	µg/L	
454-202-SK-50	Science room sink, room 202, fourth island sink, right faucet	1.5	µg/L	
454-202-SK-51	Science room sink, room 202, fifth island sink, left faucet	1.1	µg/L	
454-202-SK-52	Science room sink, room 202, fifth island sink, right faucet	0.6	µg/L	
454-202A-SK-53	Science prep room sink, room 202A	9.5	µg/L	
454-203-SK-54	Science room sink, room 203, first island next to east wall, left sink	7.5	µg/L	
454-203-SK-55	Science room sink, room 203, first island next to east wall, right sink	7.1	µg/L	
454-203-SK-56	Science room sink, room 203, second island, left sink	4.5	µg/L	
454-203-SK-57	Science room sink, room 203, second island, right sink	4.5	µg/L	
454-203-SK-58	Science room sink, room 203, third island, left sink	8.4	µg/L	
454-203-SK-59	Science room sink, room 203, third island, right sink	7.4	µg/L	
454-203-SK-60	Science room sink, room 203, fifth island sink	13.5	µg/L	
454-222-SK-61	Science room sink, room 222, south wall, far left sink	35.0	µg/L	Lab Sink – No Drinking Notice
454-222-SK-62	Science room sink, room 222, south wall, center left sink	4.8	µg/L	
454-222-SK-63	Science room sink, room 222, south wall, center right sink	4.8	µg/L	
454-222-SK-64	Science room sink, room 222, south wall, far right sink	14.3	µg/L	
454-221-SK-65	Science room sink, room 221, north wall, left sink	0.3	µg/L	
454-221-SK-66	Science room sink, room 221, north wall, center sink	0.6	µg/L	

454-221-SK-67	Science room sink, room 221, north wall, right sink	0.6	µg/L
454-221-SK-68	Science room sink, room 221, south wall, far left sink	0.8	µg/L
454-221-SK-69	Science room sink, room 221, south wall, center left sink	0.5	µg/L
454-221-SK-70	Science room sink, room, 221, south wall, center sink	0.5	µg/L
454-221-SK-71	Science room sink, room 221, south wall, center right sink	0.2	µg/L
454-221-SK-72	Science room sink, room 221, south wall, far right sink	0.2	µg/L
454-220-SK-73	Science room sink, room 220, east wall, left sink	3.3	µg/L
454-220-SK-74	Science room sink, room 220, east wall, right sink	0.2	µg/L
454-220-SK-75	Science room sink, room 220, west wall, far left sink	0.2	µg/L
454-220-SK-76	Science room sink, room 220, west wall, left center left	0.5	µg/L
454-220-SK-77	Science room sink, room 220, west wall, left center right	0.2	µg/L
454-220-SK-78	Science room sink, room 220, west wall, right center left	2.4	µg/L
454-220-SK-79	Science room sink, room 220, west wall, right center right	0.3	µg/L
454-220-SK-80	Science room sink, room 220, west wall, far right sink	0.2	µg/L
454-220A-SK-81	Science prep room sink, room 220A	0.4	µg/L
454-314-SK-82	Classroom sink, room 314	0.4	µg/L
454-123-SK-83	Classroom sink, room 123	0.5	µg/L
454-119N-SK-84	Nurse sink, room 119N	1.1	µg/L
454-119L-SK-85	Nurse sink, room 119L	1.1	µg/L
454-119H-SK-86	Nurse sink, room 119H	1.7	µg/L
454-119F-SK-87	Nurse sink, room, 119F	5.9	µg/L
<b>Post-Renovation Sampling 4/17/2018</b>			
454-201-DF-88	Drinking fountain and bottle fill, hallway 201, next to room 201	<1.0	µg/L
454-323-DF-89	Drinking fountain and bottle fill, hallway 300, next to room 323	<1.0	µg/L
454-324-SK-90	Science lab sink, room 324, north wall	6.0	µg/L
454-324-SK-91	Science lab sink, room 324, south wall, far left sink	4.0	µg/L
454-324-SK-92	Science lab sink, room 324, south wall, center left sink	4.0	µg/L
454-324-SK-93	Science lab sink, room 324, south wall, center sink	4.0	µg/L
454-324-SK-94	Science lab sink, room 324, south wall, center right sink	4.0	µg/L
454-324-SK-95	Science lab sink, room 324, south wall, far right sink	3.0	µg/L
454-324-SK-96	Science lab sink, room 324, west wall	2.0	µg/L
454-322-SK-97	Science lab sink, room 322, south wall, left sink	3.0	µg/L
454-322-SK-98	Science lab sink, room 322, south wall, right sink	3.0	µg/L
454-322-SK-99	Science lab sink, room 322, west wall, far left sink	3.0	µg/L
454-322-SK-100	Science lab sink, room 322, west wall, center left sink	5.0	µg/L
454-322-SK-101	Science lab sink, room 322, west wall, center right sink	4.0	µg/L
454-322-SK-102	Science lab sink, room 322, west wall, far right sink	4.0	µg/L
454-322B-SK-103	Science prep sink, room 322B	2.0	µg/L
454-305-SK-104	Art room sink, room 305	3.0	µg/L

\*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

\*1. Follow up sample tested with a Palintest SA1100 scanning analyzer.