

McGlone Academy (299 & 299A)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/28-29/2016					
Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
299-LUNCH-DF-01	Drinking fountain, cafeteria, next to kitchen, left bubbler	15.0	4.0	µg/L	Replaced 2/13/2018
299-LUNCH-DF-02	Drinking fountain, cafeteria, next to kitchen, right bubbler	21.0	3.0	µg/L	Replaced 2/13/2018
299-H170-DF-03	Drinking fountain, hallway H170, across from cafeteria	<1.0* ¹		µg/L	
299-KITCD-SK-04	Kitchen sink, room KITCD, left faucet	<1.0		µg/L	
299-KITCD-SK-05	Kitchen sink, room KITCD, right faucet	1.2		µg/L	
299-OFFK-SK-06	Nurse sink, main office, room OFFK	<1.0		µg/L	
299-OFFF-DF-07	Drinking fountain, hallway OFFF, main office	1.9		µg/L	
299-OFFE-SK-08	Main office sink, room OFFE	<1.0		µg/L	
299-H110-DF-09	Drinking fountain, hallway H110, next to room 130, left bubbler	<1.0		µg/L	
299-H110-DF-10	Drinking fountain, hallway H110, next to room 130, right bubbler	<1.0		µg/L	
299-H110-DF-11	Drinking fountain, hallway H110, next to room 133, left bubbler	<1.0		µg/L	
299-H110-DF-12	Drinking fountain, hallway H110, next to room 133, right bubbler	<1.0		µg/L	
299-H100-DF-13	Drinking fountain, hallway H100, next to room 119, left bubbler	<1.0		µg/L	
299-H100-DF-14	Drinking fountain, hallway H100, next to room 119, right bubbler	<1.0		µg/L	
299-H100-DF-15	Drinking fountain, hallway H100, next to room 114, left bubbler	<1.0		µg/L	
299-H100-DF-16	Drinking fountain, hallway H100, next to room 114, right bubbler	<1.0		µg/L	
299-H100F-SK-17	Staff lounge sink, room H100F	1.1		µg/L	
299-111-DF-18	Drinking fountain, room 111	1.8		µg/L	
299-110-DF-19	Drinking fountain, room 110	<1.0		µg/L	
299A-170-DF-01	Drinking fountain, cottage, hallway 170, across from all purpose room, left bubbler	<1.0		µg/L	
299A-170-DF-02	Drinking fountain, cottage, hallway 170, across from all purpose room, left bubbler	<1.0		µg/L	
299A-161D-SK-03	Workroom sink, cottage, room 161D	<1.0		µg/L	
299A-162-DF-04	Drinking fountain, cottage, room 162	<1.0		µg/L	
299A-163-DF-05	Drinking fountain, cottage, room 163	<1.0		µg/L	
299A-164-DF-06	Drinking fountain, cottage, room 164	<1.0		µg/L	
299A-165-DF-07	Drinking fountain, cottage, room 165	<1.0		µg/L	
299A-166-DF-08	Drinking fountain, cottage, room 166	<1.0		µg/L	
299A-167-DF-09	Drinking fountain, cottage, room 167	<1.0		µg/L	
299A-168-DF-10	Drinking fountain, cottage, room 168	<1.0		µg/L	
299A-169-DF-11	Drinking fountain, cottage, room 169	<1.0		µg/L	

Phase II Sampled on 4/12/2017

299A-166-SK-12	Classroom sink, cottage room 166, east wall	<1.0	µg/L
299A-166-SK-13	Classroom sink, cottage room 166, south wall	<1.0	µg/L
299A-167-SK-14	Classroom sink, cottage room 167, east wall	<1.0	µg/L
299A-167-SK-15	Classroom sink, cottage room 167, north wall	<1.0	µg/L
299A-165-SK-16	Classroom sink, cottage room 165, west wall	<1.0	µg/L
299A-165-SK-17	Classroom sink, cottage room 165, south wall	<1.0	µg/L
299A-164-SK-18	Classroom sink, cottage room 164, west wall	<1.0	µg/L
299A-164-SK-19	Classroom sink, cottage room 164, north wall	<1.0	µg/L
299A-163-SK-20	Classroom sink, cottage room 163, west wall	<1.0	µg/L
299A-163-SK-21	Classroom sink, cottage room 163, south wall	<1.0	µg/L
299A-162-SK-22	Classroom sink, cottage room 162, west wall	<1.0	µg/L
299A-162-SK-23	Classroom sink, cottage room 162, north wall	<1.0	µg/L
299A-168-SK-24	Classroom sink, cottage room 168, east wall	<1.0	µg/L
299A-168-SK-25	Classroom sink, cottage room 168, south wall	<1.0	µg/L
2991-169-SK-26	Classroom sink, cottage room 169, east wall	<1.0	µg/L
299A-169-SK-27	Classroom sink, cottage room 169, north wall	<1.0	µg/L
299A-171-SK-28	All purpose room sink, cottage room 171, north wall	<1.0	µg/L
299-121-SK-20	Classroom sink, room 121	2.0	µg/L
299-120-SK-21	Classroom sink, room 120	<1.0	µg/L
299-119-SK-22	Classroom sink, room 119	<1.0	µg/L
299-117-SK-23	Classroom sink, room 117	1.0	µg/L
299-118-SK-24	Classroom sink, room 118	2.0	µg/L
299-115-SK-25	Classroom sink, room 115	2.0	µg/L
299-116-SK-26	Classroom sink, room 116	<1.0	µg/L
299-122-SK-27	Classroom sink, room 122, on left	2.0	µg/L
299-122-SK-28	Classroom sink, room, 122, on right	2.0	µg/L
299-123-SK-29	Classroom sink, room 123, on right	2.0	µg/L
299-123-SK-30	Classroom sink, room 123, on left	9.0	µg/L
299-137-SK-31	Classroom sink, room 137	1.0	µg/L
299-136-SK-32	Classroom sink, room 136	2.0	µg/L
299-135-SK-33	Classroom sink, room 135	2.0	µg/L
299-134-SK-34	Classroom sink, room 134	1.0	µg/L
299-133-SK-35	Classroom sink, room 133	<1.0	µg/L
299-132-SK-36	Classroom sink, room 132	1.0	µg/L
299-131-SK-37	Classroom sink, room 131	1.0	µg/L
299-124-SK-38	Classroom sink, room 124	2.0	µg/L
299-H100F-SK-39	Faculty lounge sink, room H100F	<1.0	µg/L
299-130-SK-40	Classroom sink, room 130	1.0	µg/L
299-129-SK-41	Classroom sink, room 129	1.0	µg/L
299-128-SK-42	Classroom sink, room 128	3.0	µg/L
299-127-SK-43	Conference room sink, room 127	3.0	µg/L

299-H150A-DF-44	Drinking fountain, hallway H150A	<1.0	µg/L
299-126-SK-45	Staff office sink, room 126	4.0	µg/L
299-114-SK-46	Classroom sink, room 114	2.0	µg/L
299-113-SK-47	Classroom sink, room 113	1.0	µg/L
299-112-SK-48	Classroom sink, room 112	1.0	µg/L
299-IMCA-SK-49	LMC/IMC office sink, room IMCA	4.0	µg/L
299-110-SK-50	Classroom sink, room 110	<1.0	µg/L
299-111-SK-51	Classroom sink, room 111	1.0	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.