

Montbello High School (459)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 11/5/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
459-22F-DF-01	Drinking fountain, hallway 224, across from room 57	1.3		µg/L	
459-64-DF-02	Drinking fountain, hallway 64, across from room 71, left bubbler	0.1		µg/L	
459-64-DF-03	Drinking fountain, hallway 64, across from room 71, right bubbler	0.1		µg/L	
459-22E-DF-04	Drinking fountain, lobby 22E, next to restroom 22D, left bubbler	<0.1*		µg/L	
459-22E-DF-05	Drinking fountain, lobby 22E, next to restroom 22D, right bubbler	<0.1		µg/L	
459-22E-DF-06	Bottle fill, lobby 22E, next to restroom 22D	<0.1		µg/L	
459-42-SK-07	Faculty lounge sink, room 42	1.1		µg/L	
459-09-SK-08	Faculty lounge sink, room 09	1.9		µg/L	
459-01-DF-09	Drinking fountain, hallway 01, across from room 21G	<0.1		µg/L	
459-01-DF-10	Bottle fill, hallway 01, across from room 21G	<0.1		µg/L	
459-101J-SK-11	Workroom sink, admin office, room 101J	1.4		µg/L	
459-103-SK-12	Admin office sink, room 103	0.7		µg/L	
459-115-SK-13	Faculty lounge sink, room 1115	9.2		µg/L	
459-160-DF-14	Drinking fountain, hallway 100, across from room 109	1.8		µg/L	
459-114D-SK-15	Nurse sink, room 114D	5.6		µg/L	
459-114C-SK-16	Nurse sink, room 114C	4.8		µg/L	
459-121B-SK-17	Kettle fill, kitchen 121B, center of room	7.7		µg/L	
459-121B-SK-18	Food prep sprayer, kitchen 121B, next to room 121BB	1.5		µg/L	
459-121B-SK-19	Food prep sink, kitchen 121B, north wall	1.3		µg/L	
459-123-DF-20	Drinking fountain, room 123	5.6		µg/L	
459-122-DF-21	Drinking fountain, room 122	8.5		µg/L	
459-125-DF-22	Drinking fountain, room 125	4.7		µg/L	
459-120-DF-23	Drinking fountain, hallway 120, across from cafeteria 121	2.1		µg/L	
459-127-DF-24	Drinking fountain, gymnasium 127, northeast corner	0.9		µg/L	
459-127-DF-25	Drinking fountain, gymnasium 127, southeast corner	5.4		µg/L	
459-126-DF-26	Drinking fountain, hallway 126, next to girls locker room 128	7.4		µg/L	
459-137-DF-27	Drinking fountain, hallway 137, next to room 136EB, left bubbler	2.6		µg/L	
459-137-DF-28	Drinking fountain, hallway 137, next to room 136EB, right bubbler	3.3		µg/L	
459-136-DF-29	Drinking fountain, swim pool 136, east wall, left bubbler	4.9		µg/L	
459-136-DF-30	Drinking fountain, swim pool 136, east wall, right bubbler	6.4		µg/L	
459-136-DF-31	Drinking fountain, swim pool 136, west wall	1.9		µg/L	
459-129-DF-32	Drinking fountain, hallway 129, next to boys locker room 133	2.0		µg/L	
459-133-DF-33	Drinking fountain, boys locker room 133	2.0		µg/L	

459-128-DF-34	Drinking fountain, girls locker room 128, east end	>50.0	5.0	µg/L	Bubbler replaced 12/2018
459-128-DF-35	Drinking fountain, girls locker room 128, west end	12.2		µg/L	
459-141-DF-36	Drinking fountain, hallway 141, next to restroom 141F, left bubbler	<0.1		µg/L	
459-141-DF-37	Bottle fill, hallway 141, next to restroom 141F	<0.1		µg/L	
459-141-DF-38	Drinking fountain, hallway 141, next to restroom 141F, right bubbler	<0.1		µg/L	
459-147-DF-39	Drinking fountain, auxiliary gymnasium 147, east wall, left bubbler	0.1		µg/L	
459-147-DF-40	Drinking fountain, auxiliary gymnasium 147, east wall, right bubbler	<0.1		µg/L	
459-150-DF-41	Drinking fountain, hallway 150, next to room 154, left bubbler	<0.1		µg/L	
459-150-DF-42	Bottle fill, hallway 150, next to room 154	<0.1		µg/L	
459-150-DF-43	Drinking fountain, hallway 150, next to room 154, right bubbler	<0.1		µg/L	
Phase II Sampled 11/ 3 & 5 /2017					
459-152-SK-44	Science lab sink, room 152, southeast wall, left faucet	0.2		µg/L	
459-152-SK-45	Science lab sink, room 152, southeast wall, right faucet	0.4		µg/L	
459-152-SK-46	Science lab sink, room 152, southwest wall, left faucet	0.2		µg/L	
459-152-SK-47	Science lab sink, room 152, southwest wall, right faucet	1.1		µg/L	
459-154-SK-48	Science lab sink, room 154, southwest wall, left faucet	0.1		µg/L	
459-154-SK-49	Science lab sink, room 154, southwest wall, right faucet	0.4		µg/L	
459-154-SK-50	Science lab sink, room 154, northwest wall, left faucet	0.2		µg/L	
459-152A-SK-51	Science prep sink, room 152A	0.1		µg/L	
459-145-SK-52	Classroom sink, room 145	0.1		µg/L	
459-143-SK-53	Classroom sink, room 143	<0.1		µg/L	
459-144-SK-54	Workroom sink, room 144	0.1		µg/L	
459-102-SK-55	Community room sink, room 102	7.2		µg/L	
459-28-SK-56	Science lab sink, room 28, demonstration sink	2.8		µg/L	
459-28-SK-57	Science lab sink, room 28, west wall, left faucet	21.7		µg/L	Lab Sink – No Drinking Notice
459-28-SK-58	Science lab sink, room 28, west wall, right faucet	26.1		µg/L	Lab Sink – No Drinking Notice
459-28-SK-59	Science lab sink, room 28, north wall, far left faucet	40.5		µg/L	Lab Sink – No Drinking Notice
459-28-SK-60	Science lab sink, room 28, north wall, center left faucet	>50		µg/L	Lab Sink – No Drinking Notice
459-28-SK-61	Science lab sink, room 28, north wall, center right faucet	29.4		µg/L	Lab Sink – No Drinking Notice
459-28-SK-62	Science lab sink, room 28, north wall far right faucet	6.4		µg/L	
459-28-SK-63	Science lab sink, room 28, east wall	12.7		µg/L	
459-26A-SK-64	Science prep sink, room 26A	13.6		µg/L	
459-26-SK-65	Science lab sink, room 26, north wall, left faucet	9.6		µg/L	

459-26-SK-66	Science lab sink, room 26, north wall, center faucet	16.0	µg/L	Lab Sink – No Drinking Notice
459-26-SK-67	Science lab sink, room 26, north wall, right faucet	28.7	µg/L	Lab Sink – No Drinking Notice
459-26-SK-68	Science lab sink, room 26, south wall, left faucet	16.1	µg/L	Lab Sink – No Drinking Notice
459-26-SK-69	Science lab sink, room 26, south wall, center faucet	20.2	µg/L	Lab Sink – No Drinking Notice
459-26-SK-70	Science lab sink, room 26, south wall, right faucet	11.5	µg/L	
459-24-SK-71	Science lab sink, room 24, north wall, right faucet	5.8	µg/L	
459-23-SK-72	Classroom sink, room 23	1.6	µg/L	
459-33-SK-73	Science lab sink, room 33, demonstration sink	0.3	µg/L	
459-33-SK-74	Science lab sink, room 33, east wall, left faucet	40.7	µg/L	Lab Sink – No Drinking Notice
459-33-SK-75	Science lab sink, room 33, east wall, center faucet	0.7	µg/L	
459-33-SK-76	Science lab sink, room 33, east wall, right faucet	2.5	µg/L	
459-33-SK-77	Science lab sink, room 33, west wall, far left faucet	4.9	µg/L	
459-33-SK-78	Science lab sink, room 33, west wall, center left faucet	2.9	µg/L	
459-33-SK-79	Science lab sink, room 33, west wall, center right faucet	4.9	µg/L	
459-33-SK-80	Science lab sink, room 33, west wall, far right faucet	6.6	µg/L	
459-32-SK-81	Science prep sink, room 32	3.3	µg/L	
459-31-SK-82	Science lab sink, room 31, demonstration sink	2.5	µg/L	
459-31-SK-83	Science lab sink, room 31, north wall, far left faucet	3.5	µg/L	
459-31-SK-84	Science lab sink, room 31, north wall, center left faucet	3.3	µg/L	
459-31-SK-85	Science lab sink, room 31, north wall, center right faucet	2.7	µg/L	
459-31-SK-86	Science lab sink, room 31, north wall, far right faucet	6.7	µg/L	
459-31-SK-87	Science lab sink, room 31, south wall, left faucet	12.3	µg/L	
459-31-SK-88	Science lab sink, room 31, south wall, center faucet	5.2	µg/L	
459-31-SK-89	Science lab sink, room 31, south wall right faucet	15.0	µg/L	Lab Sink – No Drinking Notice
459-30-SK-90	Science lab sink, room 30, demonstration sink	6.6	µg/L	
459-30-SK-91	Science lab sink, room 30, east wall	10.6	µg/L	
459-30A-SK-92	Art room sink, room 30A, left faucet	0.3	µg/L	
459-30A-SK-93	Art room sink, room 30A, right faucet	0.3	µg/L	
459-29-SK-94	Science lab sink, room 29, demonstration sink	3.4	µg/L	
459-29-SK-95	Science lab sink, room 29, east wall, far left faucet	8	µg/L	
459-29-SK-96	Science lab sink, room 29, east wall, center left faucet	18.6	µg/L	Lab Sink – No Drinking Notice
459-29-SK-97	Science lab sink, room 29, east wall, center right faucet	5.1	µg/L	
459-29-SK-98	Science lab sink, room 29, east wall, far right faucet	4.2	µg/L	
459-29-SK-99	Science lab sink, room 29, west wall, far left faucet	9.1	µg/L	
459-29-SK-100	Science lab sink, room 29, west wall, center left faucet	14.6	µg/L	
459-21C-SK-101	LMC/IMC office sink, room 21C	14.3	µg/L	
459-21E-SK-102	LMC/IMC office sink, room 21E	5.4	µg/L	

459-60-SK-103	Art room sink, room 60, right faucet	4.5		µg/L	
459-61-SK-104	Art room sink, room 61, left faucet	10.7		µg/L	
459-61-SK-105	Art room sink, room 61, right faucet	6.3		µg/L	
459-62-SK-106	Art room sink, room 62, east wall, left faucet	10.6		µg/L	
459-62-SK-107	Art room sink, room 62, east wall, right faucet	14.6		µg/L	
459-62-SK-108	Art room sink, room 62, south wall, left faucet	6.2		µg/L	
459-62-SK-109	Art room sink, room 62, south wall, right faucet	4.9		µg/L	
459-62B-SK-110	Art prep room sink, room 62B	20.5	8.0	µg/L	Faucet replaced 5/2018
459-87-SK-111	Science lab sink, room 87, demonstration sink	1		µg/L	
459-87B-SK-112	Science prep room sink, room 87B	5.8		µg/L	

*Result less than 0.1 ppb which is the lowest level that can be reported by the lab.