

Montclair Elementary (257)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 8/31/2016					
Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
257-006-SK-01	Kitchen sink, left	2.0		µg/L	
257-006-SK-02	Kitchen sink, right	1.4		µg/L	
257-200-DF-03	Drinking fountain, hallway 200, next to 201A, left bubbler	2.9		µg/L	
257-200-DF-04	Drinking fountain, hallway 200, next to 201A, right bubbler	2.7		µg/L	
257-200-DF-05	Drinking fountain, hallway 200, next to 209, left bubbler	5.3		µg/L	
257-200-DF-06	Drinking fountain, hallway 200, next to 209, right bubbler	5.3		µg/L	
257-200-DF-07	Drinking fountain, hallway 200, next to 206, left bubbler	3.1		µg/L	
257-111B-DF-08	Drinking fountain, room 111B, gym office	>50.0	2.0	µg/L	Bubbler replaced 2/2018
257-100-DF-09	Drinking fountain, hallway 100, next to room 112, left bubbler	<1.0*		µg/L	
257-100-DF-10	Drinking fountain, hallway 100, next to room 112, right bubbler	<1.0		µg/L	
257-109B-DF-11	Drinking fountain, hallway 109B, between rooms 109 and 110, left bubbler	7.2		µg/L	
257-109B-DF-12	Drinking fountain, hallway 109B, between rooms 109 and 110, right bubbler	1.7		µg/L	
257-100-DF-13	Drinking fountain, hallway 100, next to room 107, left bubbler	2.0		µg/L	
257-100-DF-14	Drinking fountain, hallway 100, next to room 107, right bubbler	3.0		µg/L	
257-100-DF-15	Drinking fountain, hallway 100, next to room 105, left bubbler	1.2		µg/L	
257-100-DF-16	Drinking fountain, hallway 100, next to room 105, right bubbler	1.1		µg/L	
Phase II Sampled on 2/10/2017					
257-114C-SK-17	Nurse sink, room 114C	<1.0		µg/L	
257-111B-SK-18	Office sink, room 111B, next to drinking fountain	4.0		µg/L	
257-107-SK-19	Classroom sink, room 107	3.0		µg/L	
257-102-SK-20	Classroom sink, room 102	2.0		µg/L	
257-103-SK-21	Classroom sink, room 103	7.0		µg/L	
257-106-SK-22	Classroom sink, room 106	1.0		µg/L	
257-105-SK-23	Classroom sink, room 105	7.0		µg/L	
257-104-SK-24	Classroom sink, room 104	4.0		µg/L	
257-205-SK-25	Classroom sink, room 205	5.0		µg/L	
257-206-SK-26	Classroom sink, room 206	<1.0		µg/L	

257-207-SK-27	Classroom sink, room 207	2.0		μg/L	
257-208-SK-28	Classroom sink, room 208	<1.0		μg/L	
257-204-SK-29	Classroom sink, room 204	<1.0		μg/L	
257-203-SK-30	Classroom sink, room 203	<1.0		μg/L	
257-209-SK-31	Classroom sink, room 209	2.0		μg/L	
257-210-SK-32	Classroom sink, room 210	<1.0		μg/L	
257-211-SK-33	Classroom sink, room 211	<1.0		μg/L	
257-201-SK-34	Classroom sink, room 201	2.0		μg/L	
257-111D-SK-35	Faculty lounge sink, room 111D	20.0	2.0	μg/L	Faucet replaced 2/2018

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.