

Northeast Bus Terminal (855) – Sampled 10/18/2017

All results below 15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Sample ID	Sample Description	Lead Result	Units	Action
855-127-SK-01	Breakroom sink, room 127	<1.0*	µg/L	
855-129-SK-02	Custodial office sink, room 129	<1.0	µg/L	
855-H146B-DK-03	Drinking fountain, hallway H146B, left	<1.0	µg/L	
855-H146B-DK-04	Drinking fountain, hallway H146B, right	<1.0	µg/L	
855-112-SK-05	Breakroom sink, room 112	<1.0	µg/L	
855-137-DF-06	Shop drinking fountain, room 137	<1.0	µg/L	
855-H139-DF-07	Shop drinking fountain, hallway H139	<1.0	µg/L	
855-H220-DF-08	Drinking fountain, hallway H220	<1.0	µg/L	
855-218-SK-09	Breakroom sink, room 218	<1.0	µg/L	

*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.