

North High School (455)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/1/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
455A-A141A-SK-01	Kitchen prep sink, room A141A, east wall	<1.0*		µg/L	
455A-A143-DF-02	Drinking fountain, cafeteria A143, north wall	<1.0		µg/L	
455A-A143-DF-03	Drinking fountain, cafeteria A143, south wall	<1.0		µg/L	
455B-BG20-DF-04	Drinking fountain, hallway BG20, across from room BG22, left bubbler	1.5		µg/L	
455B-BG40-DF-05	Drinking fountain, hallway BG20, across from room BG22, right bubbler	<1.0		µg/L	
455B-BG40-DF-06	Drinking fountain, hallway BG40, across from room BG49, left bubbler	<1.0		µg/L	
455B-BG60-DF-07	Drinking fountain, hallway BG40, across from room BG49, right bubbler	<1.0		µg/L	
455B-BG60-DF-08	Drinking fountain, hallway BG60, across from room BG64, left bubbler	<1.0		µg/L	
455B-BG60-DF-09	Drinking fountain, hallway BG60, across from room BG64, right bubbler	<1.0		µg/L	
455B-B120-DF-10	Drinking fountain, hallway B120, across from room B122, left bubbler	<1.0		µg/L	
455B-B120-DF-11	Drinking fountain, hallway B120, across from room B122, right bubbler	<1.0		µg/L	
455B-B100-DF-12	Drinking fountain, hallway B100, across from room B102, left bubbler	<1.0		µg/L	
455B-B100-DF-13	Drinking fountain, hallway B100, across from room B102, right bubbler	<1.0		µg/L	
455B-B140-DF-14	Drinking fountain, hallway B140, across from room B151, left bubbler	<1.0		µg/L	
455B-B140-DF-15	Drinking fountain, hallway B140, across from room B151, right bubbler	<1.0		µg/L	
455B-B220-DF-16	Drinking fountain, hallway B220, across from room B225, left bubbler	<1.0		µg/L	
455B-B220-DF-17	Drinking fountain, hallway B220, across from room B225, right bubbler	<1.0		µg/L	
455B-B200-DF-18	Drinking fountain, hallway B200, across from room B201, left bubbler	<1.0		µg/L	
455B-B200-DF-19	Drinking fountain, hallway B200, across from room B201, right bubbler	<1.0		µg/L	

455B-B240-DF-20	Drinking fountain, hallway B240, across from room B244, left bubbler	<1.0		µg/L	
455B-B240-DF-21	Drinking fountain, hallway B240, across from room B244, right bubbler	<1.0		µg/L	
455B-B320-DF-22	Drinking fountain, hallway B320, across from room B324, left bubbler	<1.0		µg/L	
455B-B320-DF-23	Drinking fountain, hallway B320, across from room B324, right bubbler	<1.0		µg/L	
455B-B300-DF-24	Drinking fountain, hallway B300, across from room B301, left bubbler	<1.0		µg/L	
455B-B300-DF-25	Drinking fountain, hallway B300, across from room B301, right bubbler	<1.0		µg/L	
455B-B340-DF-26	Drinking fountain, hallway B340, across from room B345, left bubbler	<1.0		µg/L	
455B-B340-DF-27	Drinking fountain, hallway B340, across from room B345, right bubbler	<1.0		µg/L	
455A-A103F-SK-28	Faculty lounge sink, room A103F, east wall	<1.0		µg/L	
455A-A103F-DF-29	Bottle fill, faculty lounge, room A103F	<1.0		µg/L	
455A-A103-DF-30	Drinking fountain, A103 admin office hallway, across from room A103E	<1.0		µg/L	
455A-A180-DF-31	Drinking fountain, hallway A180, next to room A181	<1.0		µg/L	
455A-A182I-SK-32	Nurse sink, room A1821I	<1.0		µg/L	
455A-A182E-SK-33	Nurse sink, room A182E	3.1		µg/L	
455A-A182L-SK-34	Nurse sink, room A182L	22.3	3.0	µg/L	Faucet replaced 11/2018
455A-A102D-SK-35	Nurse sink, room A182D	1.6		µg/L	
455A-A182C-SK-36	Nurse sink, room A182C, on left	3.0		µg/L	
455A-A120-DF-38	Nurse sink, room A182C, on right	<1.0		µg/L	
455A-A182C-SK-37	Drinking fountain, hallway A120, next to room A127	1.2		µg/L	
455A-A220-DF-39	Drinking fountain, hallway A220, across from room A222	<1.0		µg/L	
455A-A220-DF-40	Drinking fountain, hallway A220, across from room A224	<1.0		µg/L	
455D-DB20-DF-41	Drinking fountain, swim pool DB20, next to room DB21	15.3		µg/L	Shut down – Replacement during 2019 renovation
455D-DB20-DF-42	Drinking fountain, swim pool DB20, next to stair DF	7.3		µg/L	
455D-DG01-DF-43	Drinking fountain, gymnasium DG01, next to room DG06, left bubbler	2.6		µg/L	
455D-DG01-DF-44	Drinking fountain, gymnasium DG01, next to room DG06, right bubbler	2.1		µg/L	
455D-DG41-DF-45	Drinking fountain, hallway DG41, across from room DG40, left bubbler	5.7		µg/L	
455D-DG41-DF-46	Drinking fountain, hallway DG41, across from room DG40, right bubbler	4.5		µg/L	
455D-DG41-DF-47	Drinking fountain, hallway DG41, across from room DG42, left bubbler	3.5		µg/L	

455D-DG41-DF-48	Drinking fountain, hallway DG41, across from room DG42, right bubbler	2.8	µg/L
455C-C63-DF-49	Bottle fill, admin office C163	<1.0	µg/L
455C-C160-DF-50	Drinking fountain, hallway C160, across from room C148, left bubbler	<1.0	µg/L
455C-C160-DF-51	Drinking fountain, hallway C160, across from room C148, right bubbler	<1.0	µg/L
455C-C145-SK-52	Faculty lounge sink, room C145	<1.0	µg/L
455C-C140-DF-53	Drinking fountain, hallway C140, next to room C129, left bubbler	<1.0	µg/L
455C-C140-DF-54	Drinking fountain, hallway C140, next to room C129, right bubbler	<1.0	µg/L
455C-C140-DF-55	Bottle fill, hallway C140, next to room C129	<1.0	µg/L
455C-C120-DF-56	Drinking fountain, hallway C120, across from room C128, left bubbler	<1.0	µg/L
455C-C120-DF-57	Drinking fountain, hallway C120, across from room C128, right bubbler	<1.0	µg/L
455E-E103-DF-58	Drinking fountain, welcome center room 103	<1.0	µg/L

Phase II Sampled on 9/30/2017

455-A126-SK-59	Classroom sink, room A126, next to room A126B	0.7	µg/L
455-A283-SK-60	Classroom sink, room A283	0.3	µg/L
455-B206-SK-61	Science lab sink, room B206, demonstration sink	0.8	µg/L
455-B206-SK-62	Science lab sink, room B206, southwest island, south sink, north faucet	2.4	µg/L
455-B206-SK-63	Science lab sink, room B206, southwest island, north sink, north faucet	0.7	µg/L
455-B206-SK-64	Science lab sink, room B206, northwest island, south sink, north faucet	0.9	µg/L
455-B206-SK-65	Science lab sink, room B206, northwest island, north sink, north faucet	0.5	µg/L
455-B206-SK-66	Science lab sink, room B206, southeast island, south sink, north faucet	3.4	µg/L
455-B206-SK-67	Science lab sink, room B206, southeast island, north sink, north faucet	1.9	µg/L
455-B206-SK-68	Science lab sink, room B206, northeast island, south sink, north faucet	1.3	µg/L
455-B206-SK-69	Science lab sink, room B206, northeast island, north sink, north faucet	0.9	µg/L
455-B206-SK-70	Science lab sink, room B206, east sink	0.5	µg/L
455-B206A-71	Science prep sink, room B206A	4.4	µg/L
455-B201-SK-72	Science lab sink, room B201, demonstration sink	2.7	µg/L
455-B201-SK-73	Science lab sink, room B201, southeast island, south sink, north faucet	1.4	µg/L
455-B201-SK-74	Science lab sink, room B201, southeast island, north sink, north faucet	1.4	µg/L

455-B201-SK-75	Science lab sink, room B201, northeast island, south sink, north faucet	1.0	µg/L	
455-B201-SK-76	Science lab sink, room B201, northeast island, north sink, north faucet	1.6	µg/L	
455-B201-SK-77	Science lab sink, room B201, southwest island, south sink, north faucet	0.9	µg/L	
455-B201-SK-78	Science lab sink, room B201, southwest island, north sink, north faucet	0.6	µg/L	
455-B201-SK-79	Science lab sink, room B201, northwest island, south sink, north faucet	1.1	µg/L	
455-B201-SK-80	Science lab sink, room B201, northwest island sink, north sink, north faucet	1.2	µg/L	
455-B201-SK-81	Science lab sink, room B201, west sink	0.2	µg/L	
455-B201A-SK-82	Science prep sink, room B201A	0.6	µg/L	
455-B244-SK-83	Science lab sink, room B244, north sink	0.6	µg/L	
455-B244-SK-84	Science lab sink, room B244, northeast island, east sink, east faucet	7.4	µg/L	
455-B244-SK-85	Science lab sink, room B244, northeast island, west sink, east faucet	4.6	µg/L	
455-B244-SK-86	Science lab sink, room B244, northwest island, east sink, east faucet	10.4	µg/L	
455-B244-SK-87	Science lab sink, room B244, northwest island, west sink, east faucet	7.4	µg/L	
455-B244-SK-88	Science lab sink, room B244, southeast island, east sink, east faucet	4.0	µg/L	
455-B244-SK-89	Science lab sink, room B244, southeast island, west sink, east faucet	4.5	µg/L	
455-B244-SK-90	Science lab sink, room B244, southwest island, east sink, east faucet	6.4	µg/L	
455-B244-SK-91	Science lab sink, room B244, southwest island, west sink, east faucet	4.8	µg/L	
455-B244A-SK-92	Science prep sink, room B244A	5.0	µg/L	
455-B244B-SK-93	Science lab sink, room B244B, demonstration sink	15.5	µg/L	Lab Sink – No Drinking Notice
455-B241-SK-94	Science lab sink, room B241, north sink	1.2	µg/L	
455-B241-SK-95	Science lab sink, room B241, northeast island, east sink, east faucet	1.8	µg/L	
455-B241-SK-96	Science lab sink, room B241, northeast island, west sink, east faucet	1.2	µg/L	
455-B241-SK-97	Science lab sink, room B241, northwest island, east sink, east faucet	3.8	µg/L	
455-B241-SK-98	Science lab sink, room B241, northwest island, west sink, east faucet	1.5	µg/L	
455-B241-SK-99	Science lab sink, room B241, southeast island, east sink, east faucet	1.4	µg/L	
455-B241-SK-100	Science lab sink, room B241, southeast island, west sink, east faucet	2.7	µg/L	

455-B241-SK-101	Science lab sink, room B241, southwest island, east sink, east faucet	2.7	µg/L	
455-B241-SK-102	Science lab sink, room B241, southwest island, west sink, east faucet	2.9	µg/L	
455-B241A-SK-103	Science prep sink, room B241A	13.9	µg/L	
455-B241B-SK-104	Science lab sink, room B241B, demonstration sink	1.3	µg/L	
455-B341-SK-105	Science lab sink, room B341, north wall, center sink	2.5	µg/L	
455-B341-SK-106	Science lab sink, room B341, northeast island, east sink	6.7	µg/L	
455-B341-SK-107	Science lab sink, room B341, northeast island, west sink	11.1	µg/L	
455-B341-SK-108	Science lab sink, room B341, northwest island, east sink	5.0	µg/L	
455-B341-SK-109	Science lab sink, room B341, northwest island, west sink	3.2	µg/L	
455-B341-SK-110	Science lab sink, room B341, southeast island, east sink	7.4	µg/L	
455-B341-SK-111	Science lab sink, room B341, southeast island, west sink	15.9	µg/L	Lab Sink – No Drinking Notice
455-B341-SK-112	Science lab sink, room B341, southwest island, east sink	3.1	µg/L	
455-B341-SK-113	Science lab sink, room B341, southwest island, west sink	4.0	µg/L	
455-B341A-SK-114	Science prep sink, room B341A	4.1	µg/L	
455-B341B-SK-115	Science lab sink, room B341B, demonstration sink	3.8	µg/L	
455-B345-SK-116	Science lab sink, room B345, north wall	0.6	µg/L	
455-B345-SK-117	Science lab sink, room B345, northeast island, east sink	0.9	µg/L	
455-B345-SK-118	Science lab sink, room B345, northeast island, west sink	0.8	µg/L	
455-B345-SK-119	Science lab sink, room B345, northwest island, east sink	1.9	µg/L	
455-B345-SK-120	Science lab sink, room B345, northwest island, west sink	2.2	µg/L	
455-B345-SK-121	Science lab sink, room B345, southeast island, east sink	1.1	µg/L	
455-B345-SK-122	Science lab sink, room B345, southeast island, west sink	1.0	µg/L	
455-B345-SK-123	Science lab sink, room B345, southwest island, east sink	1.6	µg/L	
455-B345-SK-124	Science lab sink, room B345, southwest island, west sink	1.0	µg/L	
455-B345A-SK-125	Science prep sink, room B345A	2.1	µg/L	
455-B345B-SK-126	Science lab sink, room B345B, demonstration sink	23.2	µg/L	Lab Sink – No Drinking Notice
455-B304-SK-127	Art room sink, room B304, east wall, far left sink	0.4	µg/L	
455-B304-SK-128	Art room sink, room B304, east wall, center left sink	0.3	µg/L	
455-B304-SK-129	Art room sink, room B304, east wall, center right sink	1.0	µg/L	
455-B304-SK-130	Art room sink, room B304, east wall, far right sink	0.4	µg/L	
455-B306-SK-131	Art room sink, room B306, west wall, left sink	1.7	µg/L	
455-B306-SK-132	Art room sink, room B306, west wall, right sink	1.3	µg/L	
455-B307-SK-133	Art room sink, room B307	0.7	µg/L	
455-C151-SK-134	Classroom sink, room C151, east wall	0.1	µg/L	
455-C148-SK-135	Classroom sink, room C148, east wall, far left sink	<0.1	µg/L	
455-C148-SK-136	Classroom sink, room C148, east wall, center left sink	0.1	µg/L	

455-C148-SK-137	Classroom sink, room C148, east wall, center right sink	<0.1	µg/L
455-C148-SK-138	Classroom sink, room C148, east wall, far right sink	0.2	µg/L
455-C147-SK-139	Classroom sink, room C147, west wall, far left sink	0.2	µg/L
455-C147-SK-140	Classroom sink, room C147, west wall, center left sink	0.4	µg/L
455-C147-SK-141	Classroom sink, room C147, west wall, center sink	0.1	µg/L
455-C147-SK-142	Classroom sink, room C147, west wall, center right sink	0.1	µg/L
455-C147-SK-143	Classroom sink, room C147, west wall, far right sink	0.3	µg/L
455-C126-SK-144	Classroom sink, room C126, north wall, left sink	0.2	µg/L
455-C126-SK-145	Classroom sink, room C126, north wall, right sink	0.2	µg/L

*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.