

Oakland Elementary (256)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/29/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
256-114-SK-01	Kitchen prep sink, north wall	<1.0* ¹		µg/L	
256-114C-SK-02	Kitchen prep sink, room 114C, east wall	1.0		µg/L	
256-112-SK-03	Sink, room 111, north wall	12.4		µg/L	
256-111-SK-04	Sink, room 112, north wall	9.2		µg/L	
256-105-DF-06	Drinking fountain, hallway 105, next to 105B, left bubbler	2.7		µg/L	
256-105-DF-07	Drinking fountain, hallway 105, next to 105B, right bubbler	8.2		µg/L	
256-115-DF-08	Drinking fountain, cafeteria, south wall, left bubbler	<1.0		µg/L	
256-115-DF-09	Drinking fountain, cafeteria, south wall, right bubbler	<1.0		µg/L	
256-102-SK-10	Classroom sink, room 102	2.2		µg/L	
256-103-SK-11	Classroom sink, room 103	<1.0		µg/L	
256-102/103-DF-12	Drinking fountain, between rooms 102 and 103	<1.0		µg/L	
256-117-DF-13	Drinking fountain, gymnasium	<1.0		µg/L	
256-116-DF-14	Drinking fountain, hallway 116, next to gym entrance	<1.0		µg/L	
256-118A-SK-15	Nurse sink, room 118A	1.3		µg/L	
256-101-DF-16	Drinking fountain, hallway 101, next to room 101A	<1.0		µg/L	
256-101-DF-17	Drinking fountain, hallway 101, next to room 101B	<1.0		µg/L	
256-101-DF-18	Drinking fountain, hallway 101, next to room 101C	<1.0		µg/L	

Phase II Sampled on 4/19/2017

256-103-SK-19	Classroom sink, room 103	<1.0		µg/L	
256-126-SK-20	Classroom sink, room 126	3.0		µg/L	
256-121-SK-21	Classroom sink, room 121	2.0		µg/L	
256-122-SK-22	Classroom sink, room 122	2.0		µg/L	
256-129-SK-23	Classroom sink, room 129	1.0		µg/L	
256-130-SK-24	Classroom sink, room 130	1.0		µg/L	
256-128-SK-25	Classroom sink, room 128	1.0		µg/L	
256-131-SK-26	Classroom sink, room 131	<1.0		µg/L	
256-127-SK-27	Classroom sink, room 127	2.0		µg/L	
256-132-SK-28	Classroom sink, room 132	2.0		µg/L	
256-133A-SK-29	LMC/IMC office sink, room 133A	4.0		µg/L	
256-143-SK-30	Classroom sink, room 143	17.0	3.0	µg/L	Faucet replaced 11/2018
256-136-SK-31	Classroom sink, room 136	2.0		µg/L	

256-142-SK-32	Classroom sink, room 142	3.0	µg/L
256-137-SK-33	Classroom sink, room 137	2.0	µg/L
256-138-SK-34	Classroom sink, room 138	2.0	µg/L
256-141-SK-35	Classroom sink, room 141	3.0	µg/L
256-139-SK-36	Classroom sink, room 139	1.0	µg/L
256-140-SK-37	Classroom sink, room 140	2.0	µg/L
256-149-SK-38	Classroom sink, room 149	3.0	µg/L
256-150-SK-39	Classroom sink, room 150	6.0	µg/L
256-148-SK-40	Classroom sink, room 148	3.0	µg/L
256-151-SK-41	Classroom sink, room 151	1.0	µg/L
256-147-SK-42	Classroom sink, room 147	13.0	µg/L
256-152-SK-43	Classroom sink, room 152	3.0	µg/L
256-146-SK-44	Classroom sink, room 146	10.0	µg/L
256-153-SK-45	Classroom sink, room 153	7.0	µg/L
256-154-SK-46	Classroom sink, room 154	6.0	µg/L
256-155-SK-47	Classroom sink, room 155	<1.0	µg/L
256-144-SK-48	Classroom sink, room 144	1.0	µg/L

*1. Result less than 1.0 ppb is the lowest level that can be reported by the lab.