

Odyssey School @ Philips Elementary (dba Odyssey) (265)

All results below 15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/9/16				
Sample ID	Sample Description	Lead Result	Units	Action
265-128-SK-01	Kitchen sink, left	2.8	µg/L	
265-128-SK-02	Kitchen sink, right	1.6	µg/L	
265-127-DF-03	Drinking fountain, gym, left	<1.0* ¹	µg/L	
265-127-DF-04	Drinking fountain, gym, right	<1.0	µg/L	
265-124-DF-05	Bottle filler, hall 124, across from 125	<1.0	µg/L	
265-124-DF-06	Drinking fountain, hall 124, across from 125, left bubbler	<1.0	µg/L	
265-124-DF-07	Drinking fountain, hall 124, across from 125, right bubbler	<1.0	µg/L	
265-123D-SK-08	Lounge sink, Room 123D	<1.0	µg/L	
265-105-DF-09	Bottle filler, hall 105, next to 106	<1.0	µg/L	
265-105-DF-10	Drinking fountain, hall 105, next to 106	<1.0	µg/L	
265-106-DF-11	Drinking fountain, room 106	<1.0	µg/L	
265-105-DF-12	Drinking fountain, hall 105, next to 112	<1.0	µg/L	
Phase II Sampled on 2/23/17				
265-102-SK-13	Classroom sink, room 102	<1.0	µg/L	
265-120-SK-14	Classroom sink, room 120	<1.0	µg/L	
265-103-SK-15	Classroom sink, room 103	<1.0	µg/L	
265-119-SK-16	Classroom sink, room 119	1.0	µg/L	
265-104-SK-17	Classroom sink, room 104	<1.0	µg/L	
265-106-SK-18	Classroom sink, room 106	<1.0	µg/L	
265-108B-SK-19	LMC/IMC office sink, room 108B	<1.0	µg/L	
265-117-SK-20	Classroom sink, room 117	<1.0	µg/L	
265-109-SK-21	Classroom sink, room 109	<1.0	µg/L	
265-110-SK-22	Classroom sink, room 110	<1.0	µg/L	
265-115-SK-23	Classroom sink, room 115	<1.0	µg/L	
265-114-SK-24	Classroom sink, room 114	2.0	µg/L	
265-111-SK-25	Classroom sink, room 111	<1.0	µg/L	
265-112-SK-26	Classroom sink, room 112	<1.0	µg/L	
265-113-SK-27	Classroom sink, room 113	<1.0	µg/L	
265-100-DF-28	Drinking fountain, hallway 100, next to room 101D	<1.0	µg/L	
265-100-DF-29	Bottle fill, hallway 100, next to room 101D	1.0	µg/L	

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.