

Park Hill Elementary (263)

Sample ID Key:

Building number – room number – fixture type (DF – drinking fountain, SK – sink) – consecutive sample number

Phase I Sampled on 8/25/2016					
Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
263-106-DF-01	Drinking fountain, cafeteria, east wall	<1.0*		µg/L	
263-106-DF-02	Drinking fountain, cafeteria, north wall	3.0		µg/L	
263-105-DF-03	Drinking fountain, hallway 105 next to cafeteria	5.5		µg/L	
263-100-DF-04	Drinking fountain, hallway 100 east of boiler room	1.5		µg/L	
263-100-DF-05	Drinking fountain, hallway 100 next to stairwell	<1.0		µg/L	
263-100-DF-06	Drinking fountain, hallway 100 next to room 125	<1.0		µg/L	
263-115-DF-07	Drinking fountain, hallway 115, left, next to elevator	<1.0		µg/L	
263-115-DF-08	Drinking fountain, hallway 115, right, next to elevator	<1.0		µg/L	
263-122-SK-09	Sink, room 122, next to door	5.2		µg/L	
263-118-SK-10	Sink, room 118	11.4		µg/L	
263-121-SK-11	Sink, room 121 next to north door	12.9		µg/L	
263-121-SK-12	Sink, room 121 next to south door	23.1	3.0	µg/L	Replaced 11/2017
263-120-SK-13	Sink, room 120 next to door	11.4		µg/L	
263-115-DF-14	Drinking fountain, hallway 115, left, next to room 118	8.4		µg/L	
263-115-DF-15	Drinking fountain, hallway 115, right, next to room 118	8.6		µg/L	
263-107-SK-16	Kitchen sink, left	3.7		µg/L	
263-107-SK-17	kitchen sink, right	2.1		µg/L	
263-200-DF-18	Drinking fountain, hallway 200, next to room 207	<1.0		µg/L	
263-201C-SK-19	Sink, office 201C	<1.0		µg/L	
263-200-DF-20	Drinking fountain, hallway 200, next to room 210	<1.0		µg/L	
263-200-DF-21	Drinking fountain, hallway 200, next to room 224	<1.0		µg/L	
263-215-DF-22	Drinking fountain, hallway 215, next to elevator	<1.0		µg/L	
263-2210-SK-23	Sink, staff lounge	5.3		µg/L	
263-215-DF-24	Drinking fountain, hallway 215, next to LMC	16.0	6.0	µg/L	Replaced 11/2017
263-300-DF-25	Drinking fountain, hallway 300, next to room 306	<1.0		µg/L	
263-305B-SK-26	Sink, room 305B	8.2		µg/L	
263-300-DF-27	Drinking fountain, hallway 300, next to room 304	<1.0		µg/L	
Phase II Sampled on 1/18/2017					
263-301-SK-28	Classroom sink, room 301	9.0		µg/L	
263-307-SK-29	Classroom sink, room 307	8.0		µg/L	
263-306-SK-30	Classroom sink, room 306	9.0		µg/L	
263-304-SK-31	Classroom sink, room 304	11.0		µg/L	
263-202-SK-32	Classroom sink, room 202	5.0		µg/L	

263-207-SK-33	Classroom sink, room 207	<1.0		µg/L	
263-208-SK-34	Classroom sink, room 208	3.0		µg/L	
263-225-SK-35	Classroom sink, room 225	2.0		µg/L	
263-210-SK-36	Classroom sink, room 210	<1.0		µg/L	
263-211-SK-37	Classroom sink, room 211	11.0		µg/L	
263-224-SK-38	Classroom sink, room 224	26.0	<1.0	µg/L	Replaced 11/2017
263-223-SK-39	Classroom sink, room 223	<1.0		µg/L	
263-212-SK-40	Classroom sink, room 212	1.0		µg/L	
263-216-SK-41	Classroom sink, room 216	19.0	9.0	µg/L	Replaced 11/2017
263-220B-SK-42	LMC/IMC office sink, room 220B	20.0	11.0	µg/L	Replaced 11/2017
263-218-SK-43	Classroom sink, room 218, right faucet	12.0		µg/L	
263-218-SK-44	Classroom sink, room 218, middle faucet	28.0	8.0	µg/L	Replaced 11/2017
263-218-SK-45	Classroom sink, room 218, left faucet	>50.0	7.0	µg/L	Replaced 11/2017
263-118-SK-46	Classroom sink, room 118	13.0		µg/L	
263-119-SK-47	Classroom sink, room 119, right faucet	14.0		µg/L	
263-119-SK-48	Classroom sink, room 119, middle faucet	17.0	13.0	µg/L	Replaced 11/2017
263-119-SK-49	Classroom sink, room 119, left faucet	16.0	4.0	µg/L	Replaced 11/2017
263-113-SK-50	Classroom sink, room 113	<1.0		µg/L	
263-124-SK-51	Classroom sink, room 124	1.0		µg/L	
263-125-SK-52	Classroom sink, room 125	2.0		µg/L	
263-112-SK-53	Classroom sink, room 112	5.0		µg/L	
263-126-SK-54	Classroom sink, room 126	<1.0		µg/L	
263-101-SK-55	Classroom sink, room 101	2.0		µg/L	

*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.