

## Polaris @ Ebert Elementary (229)

**Sample ID Key:**

Building number – room number – fixture type (DF – drinking fountain, SK – sink) – consecutive sample number

Phase I Sampled on 8/25/2016					
Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
229-118-DF-01	Drinking fountain, room 115	1.2		µg/L	
229-117-DF-02	Drinking fountain, room 117	1.6		µg/L	
229-116A-DF-03	Drinking fountain, room 116A	<1.0*1		µg/L	
229-119-DF-04	Drinking fountain, room 119	1.1		µg/L	
229-112-DF-05	Drinking fountain, hallway 112	<1.0		µg/L	
229-112-DF-06	Bottle fill, hallway 112	<1.0		µg/L	
229-115-DF-07	Drinking fountain, room 115	<1.0		µg/L	
229-114-DF-08	Drinking fountain, room 114	<1.0		µg/L	
229-113-DF-09	Drinking fountain, room 113	1.4		µg/L	
229-121-SK-10	Kitchen spray	1.4		µg/L	
229-121-SK-11	kitchen compartment sink, right	<1.0		µg/L	
229-121-SK-12	kitchen compartment sink, left	1.1		µg/L	
229-121-SK-13	Kitchen disposal faucet	<1.0		µg/L	
229-121-SK-14	Kitchen sink, left	1.6		µg/L	
229-121-SK-15	Kitchen disposal spray	1.0		µg/L	
229-101A-DF-17	Drinking fountain, room 101A, gym aux storage	14.9		µg/L	
229-100-DF-18	Drinking fountain, hallway 100	<1.0		µg/L	
229-100-DF-19	Bottle fill, hallway 100	<1.0		µg/L	
229-100-DF-20	Drinking fountain, hallway 100, by room 107	<1.0		µg/L	
229-111-SK-21	Nurse sink	<1.0		µg/L	
229-200-DF-22	Drinking fountain, hallway 200, by room 201	<1.0		µg/L	
229-200-DF-23	Drinking fountain, hallway 200, by room 205	<1.0		µg/L	
Phase II Sampled on 1/25/2017					
229-118-SK-24	Classroom sink, room 118	0.7		µg/L	
229-117-SK-25	Classroom sink, room 117	0.9		µg/L	
229-119-SK-26	Classroom sink, room 119	0.4		µg/L	
229-116-SK-27	Classroom sink, room 116	1.9		µg/L	
229-115-SK-28	Classroom sink, room 115	1.4		µg/L	
229-114-SK-29	Classroom sink, room 114	1.7		µg/L	
226-113-SK-30	Classroom sink, room 113	<0.1*2		µg/L	
229-109-SK-31	Classroom sink, room 109	<0.1		µg/L	
229-107-SK-32	Classroom sink, room 107	8.5		µg/L	
229-103-SK-33	Classroom sink, room 103, center of west wall	2.1		µg/L	
229-103-SK-34	Classroom sink, room 103, northwest corner	11.9		µg/L	

<b>229-100-DF-35</b>	Drinking fountain, hallway 100, next to room 102	<0.1		µg/L	
<b>229-100-DF-36</b>	Bottle fill station, hallway 100, next to room 102	<0.1		µg/L	
<b>229-102-SK-37</b>	Classroom sink, room 102	3.2		µg/L	
<b>229-211-SK-38</b>	Staff lounge sink, room 211	2.6		µg/L	
<b>229-208-SK-39</b>	Classroom sink, room 208, center of east wall	1.8		µg/L	
<b>229-208-SK-40</b>	Classroom sink, room 208, southeast corner	8.6		µg/L	
<b>229-207-SK-41</b>	Classroom sink, room 207	<0.1		µg/L	
<b>229-205-SK-42</b>	Classroom sink, room 205, south wall	37.7	7.0	µg/L	Faucet replaced 7/2017
<b>229-205-SK-43</b>	Classroom sink, room 205, northwest corner	>50.0	1.0	µg/L	Faucet replaced 7/2017
<b>229-203-SK-44</b>	Classroom sink, room 203, center of west wall	0.4		µg/L	
<b>229-203-SK-45</b>	Classroom sink, room 203, northwest corner	5.3		µg/L	
<b>229-201-SK-46</b>	Classroom sink, room 201	2.1		µg/L	
<b>229-122A-SK-47</b>	LMC/IMC office sink, room 122A	8.0		µg/L	
<b>229-111-SK-48</b>	Nurse sink, room 111	3.5		µg/L	
<b>229-111-SK-49</b>	RO system on nurse sink, room 111	3.5		µg/L	

\*1. Result is less than 1.0 ppb which is the lowest level that can be reported by the lab.

\*2. Result is less than 0.1 ppb which is the lowest level that can be reported by the external lab.