

STRIVE Prep – Sunnyside @ Remington Elementary (267)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled 9/13/2016, 9/15/16

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
267-115-DF-01	Drinking fountain, hallway 115, across from gym	<1.0*1		µg/L	
267-116A-SK-02	Kitchen sink, west wall	<1.0		µg/L	
267-113-DF-03	Drinking fountain, gym	7.8		µg/L	
267-100-DF-04	Drinking fountain, hallway 100, next to school office, left bubbler	3.3		µg/L	Fountain replaced with new DF/BF – sampled Jan. 2018, result less than 1.0
267-100-DF-03	Drinking fountain, hallway 100, next to school office, right bubbler	2.1		µg/L	
267-200-DF-06	Drinking fountain, hallway 200, outside of room 207, left bubbler	4.8		µg/L	
267-200-DF-07	Drinking fountain, hallway 200, outside of room 207, right bubbler	2.7		µg/L	
267-200-DF-08	Drinking fountain, hallway 200, outside of room 214, left bubbler	2.0		µg/L	Fountain replaced with new DF/BF – sampled Jan. 2018, result less than 1.0
267-200-DF-09	Drinking fountain, hallway 200, outside of room 214, right bubbler	2.4		µg/L	
267-108-df-10	Drinking fountain, room 108	15.3	N/A	µg/L	Removed
267-107-DF-11	Drinking fountain, room 107	>50.0	N/A	µg/L	Removed

Phase II Sampled 3/7/2017

267-120-SK-12	Classroom sink, room 120	3.0		µg/L	
267-101H-SK-13	Faculty lounge sink, room 101H	6.0		µg/L	
267-101F-SK-14	Office sink, room 101F	25.0	6.0	µg/L	Faucet replaced 11/2017
267-102-SK-15	Classroom sink, room 102	7.0		µg/L	
267-103-SK-16	Classroom sink, room 103	3.0		µg/L	
267-104-SK-17	Classroom sink, room 104	4.0		µg/L	
267-105-SK-18	Classroom sink, room 105	3.0		µg/L	
267-107-SK-19	Classroom sink, room 107	3.0		µg/L	
267-108-SK-20	Classroom sink, room 108	10.0		µg/L	
267-100AC-SK-21	Office sink, room 100AC	8.0		µg/L	
267-121-SK-22	Classroom sink, room 121	2.0		µg/L	
267-121A-SK-23	Office sink, room 121A	22.0	3.0	µg/L	Faucet replaced 11/2017
267-112A-SK-24	Office sink, room 112A	35.0	3.0	µg/L	Faucet replaced 11/2017
267-214-SK-25	Classroom sink, room 214	6.0		µg/L	
267-209-SK-26	Classroom sink, room 209	7.0		µg/L	
267-208-SK-27	Classroom sink, room 208	12.0		µg/L	
267-207-SK-28	Classroom sink, room 207	7.0		µg/L	

267-205-SK-29	Classroom sink, room 205	2.0		µg/L	
267-204-SK-30	Classroom sink, room 204	5.0		µg/L	
267-203-SK-31	Classroom sink, room 203	4.0		µg/L	
267-202-SK-32	Classroom sink, room 202	6.0		µg/L	
267-201-SK-33	Classroom sink, room 201	5.0		µg/L	
267-212-SK-34	Office sink, room 212	>50.0	7.0	µg/L	Faucet replaced 11/2017
267-100-DF-35	Drinking fountain room 105, left bubbler	2.0		µg/L	
267-100-DF-36	Drinking fountain room 105, right bubbler	3.0		µg/L	

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.