

Samuels Elementary (296)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/27/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
296-OUTSIDE-DF-01	Drinking fountain, outside, next to west entrance by gymnasium	8.0		µg/L	
296-105GYM-DF-02	Drinking fountain, gymnasium	<1.0* ¹		µg/L	
296-105-DF-03	Drinking fountain, hallway 105, across from room 143	1.4		µg/L	
296-143-DF-04	Drinking fountain, all purpose room 143, west wall	<1.0		µg/L	
296-143A-POT-05	Kitchen kettle faucet	>50	6.0	µg/L	Kettle replaced summer 2018
296-143A-SK-06	Kitchen sprayer	4.1		µg/L	
296-143A-SK-07	Kitchen sink, west wall, on left, next to room 143AA	1.6		µg/L	
296-146CB-SK-08	Custodial office sink, room 146CB	2.7		µg/L	
296-102-DF-09	Drinking fountain, hallway 102, across from room 145	<1.0		µg/L	
296-102-DF-10	Bottle fill station, hallway 102, across from room 145	<1.0		µg/L	
296-102-DF-11	Drinking fountain, hallway 102, across from room 108, left bubbler	<1.0		µg/L	
296-102-DF-12	Drinking fountain, hallway 102, across from room 108, right bubbler	<1.0		µg/L	
296-102-DF-13	Drinking fountain, hallway 102, across from room 119, left bubbler	<1.0		µg/L	
296-102-DF-14	Drinking fountain, hallway 102, across from room 119, right bubbler	<1.0		µg/L	
296-120-DF-15	Drinking fountain, hallway 120, next to room 123	<1.0		µg/L	
296-123-DF-16	Drinking fountain, room 123	<1.0		µg/L	
296-125-DF-17	Drinking fountain, room 125	<1.0		µg/L	
296-120-DF-18	Drinking fountain, hallway 120, next to room 126	1.3		µg/L	
296-129-DF-19	Drinking fountain, hallway 129, next to room 131, left bubbler	<1.0		µg/L	
296-129-DF-20	Drinking fountain, hallway 129, next to room 131, right bubbler	<1.0		µg/L	
296-129-DF-21	Drinking fountain, hallway 129, next to room 139, left bubbler	<1.0		µg/L	
296-129-DF-22	Drinking fountain, hallway 129, next to room 139, right bubbler	<1.0		µg/L	
296-101G-SK-23	Nurse sink, room 101G	1.2		µg/L	
296-144-SK-24	Staff lounge sink, room 144	2.0		µg/L	

Phase II Sampled on 4/7/2017

296-101D-SK-25	Staff office sink, room 101D	1.0		µg/L	
----------------	------------------------------	-----	--	------	--

296-106-SK-26	Classroom sink, room 106	<1.0	µg/L
296-109-SK-27	Classroom sink, room 109	<1.0	µg/L
296-108-SK-28	Classroom sink, room 108, left sink	<1.0	µg/L
296-108-SK-29	Classroom sink, room 108, middle sink	<1.0	µg/L
296-108-SK-30	Classroom sink, room 108, right sink	<1.0	µg/L
296-111-SK-31	Classroom sink, room 111	<1.0	µg/L
296-113-SK-32	Classroom sink, room 113	1.0	µg/L
296-114-SK-33	Classroom sink, room 114	<1.0	µg/L
296-116-SK-34	Classroom sink, room 116	<1.0	µg/L
296-118-SK-35	Classroom sink, room 118	<1.0	µg/L
296-119-SK-36	Classroom sink, room 119	<1.0	µg/L
296-121-SK-37	Classroom sink, room 121	<1.0	µg/L
296-122-SK-38	Classroom sink, room 122	2.0	µg/L
296-123-SK-39	Classroom sink, room 123	1.0	µg/L
296-124-SK-40	Classroom sink, room 124	4.0	µg/L
296-125-SK-41	Classroom sink, room 125	2.0	µg/L
296-126-SK-42	Classroom sink, room 126	1.0	µg/L
296-127-SK-43	Classroom sink, room 127, northeast corner	1.0	µg/L
296-127-SK-44	Classroom sink, room 127, northwest corner	2.0	µg/L
296-128-SK-45	Classroom sink, room 128	1.0	µg/L
296-131-SK-46	Classroom sink, room 131	<1.0	µg/L
296-130-SK-47	Classroom sink, room 130	<1.0	µg/L
296-133-SK-48	Classroom sink, room 133	<1.0	µg/L
296-135-SK-49	Classroom sink, room 135	1.0	µg/L
296-136-SK-50	Classroom sink, room 136	<1.0	µg/L
296-137-SK-51	Classroom sink, room 137	<1.0	µg/L
296-139-SK-52	Classroom sink, room 139	<1.0	µg/L
296-140-SK-53	Classroom sink, room 140	<1.0	µg/L
296-141-SK-54	Classroom sink, room 141	<1.0	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.