

McAuliffe International @ Smiley Middle School (417)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/21/2016					
Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
417-1-DF-01	Drinking fountain, music room 001	<1.0*		µg/L	
417-138-DF-02	Drinking fountain, north gymnasium 138, south wall	<1.0		µg/L	
417-109-DF-03	Drinking fountain, hallway 109, next to room 123A	<1.0		µg/L	
417-109-DF-04	Drinking fountain, hallway 109, next to room 101	<1.0		µg/L	
417-108C-SK-05	Faculty lounge sink, room 108C	<1.0		µg/L	
417-109-DF-06	Drinking fountain, hallway 109, across from room 106	<1.0		µg/L	
417-101G-SK-07	Nurse sink, room 101G	1.3		µg/L	
417-112-SK-08	Faculty lounge sink, room 112	<1.0		µg/L	
417-109-DF-09	Drinking fountain, hallway 109, next to room 113	<1.0		µg/L	
417-140-DF-10	Drinking fountain, hallway 140, next to room 121	<1.0		µg/L	
417-136-DF-11	Drinking fountain, east gymnasium 136	<1.0		µg/L	
417-10-DF-12	Drinking fountain, room 10	2.1		µg/L	
417-122-DF-13	Drinking fountain, room 122	3.4		µg/L	
417-121-SK-14	Classroom sink, room 121, east wall	7.2		µg/L	
417-121-SK-15	Classroom sink, room 121, southeast corner	5.7		µg/L	
417-121-SK-16	Classroom sink, room 121, to the right of 417-121-SK-15	12.1		µg/L	
417-220-DF-17	Drinking fountain, hallway 220, across from room 206	<1.0		µg/L	
417-221-DF-18	Drinking fountain, hallway 221, next to stair E	<1.0		µg/L	
417-217A-SK-19	Kitchen prep sink, room 217A, west wall	<1.0		µg/L	
417-217A-SK-20	Kitchen prep sink, room 217A, east wall, next to dish spray	<1.0		µg/L	
417-217-DF-21	Drinking fountain, cafeteria 217, west wall	<1.0		µg/L	
417-221-DF-22	Drinking fountain, hallway 221, next to stair F	2.1		µg/L	
417-221-DF-23	Drinking fountain, hallway 221, next to room 222E	<1.0		µg/L	
417-222-DF-24	Drinking fountain, hallway 222, next to room 213	<1.0		µg/L	
417-303-SK-25	Faculty lounge sink, room 303	<1.0		µg/L	
417-320-DF-26	Drinking fountain, hallway 320, across from room 306	1.7		µg/L	
417-320-DF-27	Drinking fountain, hallway 320, next to room 301	<1.0		µg/L	
417-320-DF-28	Drinking fountain, hallway 320, next to room 314	<1.0		µg/L	
417-310A-SK-29	Faculty lounge sink, room 310A	2.5		µg/L	
417-320-DF-30	Drinking fountain, hallway 320, next to room 311, left bubbler	1.7		µg/L	
417-320-DF-31	Drinking fountain, hallway 320, next to room 311, right bubbler	<1.0		µg/L	

Phase II Sampled on 9/14/2017

417-120-SK-32	Classroom sink, room 120	6.0		µg/L	
417-121-SK-33	Classroom sink, room 121, 3rd sink from west wall	12.0		µg/L	
417-121-SK-34	Classroom sink, room 121, 2nd sink from wall	8.0		µg/L	
417-121-SK-35	Classroom sink, room 121, 1st sink from wall	37.0	25.0	µg/L	Failed – no drinking notice; Faucet replaced 4/2018
417-111-SK-36	Classroom sink, room 111, west wall	<1.0		µg/L	
417-111-SK-37	Classroom sink, room 111, east wall	<1.0		µg/L	
417-117-SK-38	Office sink, room 117	<1.0		µg/L	
417-105-SK-39	Science lab sink, room 105, demonstration sink	<1.0		µg/L	
417-105-SK-40	Science lab sink, room 105, west wall, left sink	<1.0		µg/L	
417-105-SK-41	Science lab sink, room 105, west wall, right sink	<1.0		µg/L	
417-105-SK-42	Science lab sink, room 105, north wall, left sink	<1.0		µg/L	
417-105-SK-43	Science lab sink, room 105, north wall, right sink	1.0		µg/L	
417-210-SK-44	Classroom sink, room 210	1.0		µg/L	
417-201C-SK-45	LMC/IMC office sink, room 201C	<1.0		µg/L	
417-203-SK-46	Classroom sink, room 203	<1.0		µg/L	
417-205-SK-47	Science lab sink, room 205, demonstration sink	3.0		µg/L	
417-205-SK-48	Science lab sink, room 205, west wall, left sink	1.0		µg/L	
417-205-SK-49	Science lab sink, room 205, west wall, right sink	<1.0		µg/L	
417-205-SK-50	Science lab sink, room 205, north wall, left sink	<1.0		µg/L	
417-205-SK-51	Science lab sink, room 205, north wall, center sink	<1.0		µg/L	
417-205-SK-52	Science lab sink, room 205, north wall, right sink	<1.0		µg/L	
417-310-SK-53	Classroom sink, room 310, east wall, left sink	8.0		µg/L	
417-310-SK-54	Classroom sink, room 310, east wall, center sink	5.0		µg/L	
417-310-SK-55	Classroom sink, room 310, east wall, right sink	8.0		µg/L	
417-313-SK-56	Classroom sink, room 313, west wall, left sink	2.0		µg/L	
417-313-SK-57	Classroom sink, room 313, west wall, center sink	<1.0		µg/L	
417-313-SK-58	Classroom sink, room 313, west wall, right sink	<1.0		µg/L	
417-314B-SK-59	Storage room sink, room 314B	9.0		µg/L	
417-314-SK-60	Classroom sink, room 314, south wall	3.0		µg/L	
417-314-SK-61	Classroom sink, room 314, west wall, left sink	<1.0		µg/L	
417-314-SK-62	Classroom sink, room 314, west wall, center sink	1.0		µg/L	
417-314-SK-63	Classroom sink, room 314, west wall, right sink	<1.0		µg/L	
417-305-SK-64	Science lab sink, room 305 west wall, center sink	<1.0		µg/L	
417-305-SK-65	Science lab sink, room 305, west wall, right sink	3.0		µg/L	
417-305-SK-66	Science lab sink, room 305, west wall, demonstration sink	3.0		µg/L	
417-305A-SK-67	Science prep sink, room 305A	3.0		µg/L	
417-309-SK-68	Science lab sink, room 309, east wall, left sink	11.0		µg/L	
417-309-SK-69	Science lab sink, room 309, east wall, center sink	9.0		µg/L	
417-309-SK-70	Science lab sink, room 309, east wall, right sink	7.0		µg/L	

417-309-SK-71

Science lab sink, room 309, demonstration sink

8.0

µg/L

*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.