

South High School (456)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/22/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
456-060-DF-01	Drinking fountain, hallway 060, next to boys locker room, across from room 073	<1.0*		µg/L	
456-061-DF-02	Drinking fountain, boys locker room, room 061	1.0		µg/L	
456-064-DF-03	Drinking fountain, girls locker room, room 064	<1.0		µg/L	
456-160-DF-04	Drinking fountain, hallway 160, next to room 171	1.0		µg/L	
456-168-DF-05	Drinking fountain, lower gym 168, northwest corner	<1.0		µg/L	
456-168-DF-06	Drinking fountain, lower gym 168, northeast corner	<1.0		µg/L	
456-145-DF-07	Bottle fill, hallway 145, across from stair P	<1.0		µg/L	
456-145-DF-08	Drinking fountain, hallway 145, across from stair P	<1.0		µg/L	
456-151-DF-09	Drinking fountain, room 151, next to room 151A	<1.0		µg/L	
456-140-DF-10	Bottle fill, hallway 140, next to room 143	<1.0		µg/L	
456-140-DF-11	Drinking fountain, hallway 140, next to room 143	<1.0		µg/L	
456-144B-SK-12	Nurse sink, room 144B	1.0		µg/L	
456-144A-SK-13	Nurse sink, room 144A	1.0		µg/L	
456-143-SK-14	Nurse sink, room 143	<1.0		µg/L	
456-107-DF-15	Drinking fountain, hallway 107, next to room 111, left bubbler	1.0		µg/L	
456-107-DF-16	Drinking fountain, hallway 107, next to room 111, right bubbler	1.0		µg/L	
456-100-DF-17	Bottle fill, hallway 100, next to admin office 101	<1.0		µg/L	
456-100-DF-18	Drinking fountain, hallway 100, next to admin office 101	<1.0		µg/L	
456-100-DF-19	Bottle fill, hallway 100, next to room 127	<1.0		µg/L	
456-100-DF-20	Drinking fountain, hallway 100, next to room 127	<1.0		µg/L	
456-100-DF-21	Drinking fountain, hallway 100, next to room 119	<1.0		µg/L	
456-100-DF-22	Drinking fountain, hallway 100, across from room 121	<1.0		µg/L	
456-251-DF-23	Drinking fountain, wrestling room 251	<1.0		µg/L	
456-249-DF-24	Bottle fill, hallway 249, next to room 250	<1.0		µg/L	
456-249-DF-25	Drinking fountain, hallway 249, next to room 250, left bubbler	<1.0		µg/L	
456-249-DF-26	Drinking fountain, hallway 249, next to room 250, right bubbler	<1.0		µg/L	
456-254-DF-27	Drinking fountain, auxiliary gym 254	<1.0		µg/L	
456-240-DF-28	Bottle fill, hallway 240, next to room 241	<1.0		µg/L	
456-240-DF-29	Drinking fountain, hallway 240, next to room 241	<1.0		µg/L	
456-244-SK-30	Classroom sink, room 244, northwest corner	<1.0		µg/L	
456-244-SK-31	Classroom sink, room 244, third sink from south wall	2.0		µg/L	
456-244-SK-32	Classroom sink, room 244, first sink from south wall	6.0		µg/L	

456-200-DF-33	Bottle fill, hallway 200, next to room 202	<1.0		µg/L	
456-200-DF-34	Drinking fountain, hallway 200, next to room 202	<1.0		µg/L	
456-205-DF-35	Drinking fountain, hallway 205, across from room 208, left bubbler	<1.0		µg/L	
456-205-DF-36	Drinking fountain, hallway 205, across from room 208, right bubbler	<1.0		µg/L	
456-200-DF-37	Drinking fountain, hallway 200, next to room 227, left bubbler	<1.0		µg/L	
456-200-DF-38	Drinking fountain, hallway 200, next to room 227, right bubbler	<1.0		µg/L	
456-226-SK-39	Classroom sink, room 226	2.0		µg/L	
456-200-DF-40	Drinking fountain, hallway 200, next to room 221	<1.0		µg/L	
456-200-DF-41	Drinking fountain, hallway 200, south end of hall, next to stair D	<1.0		µg/L	
456-300-DF-42	Bottle fill, hallway 300, next to room 302	<1.0		µg/L	
456-300-DF-43	Drinking fountain, hallway 300, next to room 302	<1.0		µg/L	
456-300-DF-44	Drinking fountain, hallway 300, next to room 323, left bubbler	<1.0		µg/L	
456-300-DF-45	Drinking fountain, hallway 300, next to room 323, right bubbler	<1.0		µg/L	
456-412-SK-46	Kitchen kettle fill, room 412, next to 412C	22.0	13.0	µg/L	Kettle replaced summer 2018
456-412-SK-47	Three compartment kitchen sink, room 412, east wall, left faucet	2.0		µg/L	
456-412-SK-48	Three compartment kitchen sink, room 412, east wall, center faucet	1.0		µg/L	
456-412-SK-49	Three compartment kitchen sink, room 412, east wall, right faucet	2.0		µg/L	
456-401-DF-50	Bottle fill, cafeteria room 401, north wall	<1.0		µg/L	
456-401-DF-51	Drinking fountain, cafeteria room 401, north wall, left bubbler	<1.0		µg/L	
456-401-DF-52	Drinking fountain, cafeteria room 401, north wall, right bubbler	<1.0		µg/L	
456-401-DF-53	Drinking fountain, cafeteria room 401, south wall, left bubbler	<1.0		µg/L	
456-401-DF-54	Drinking fountain, cafeteria, room 401, south wall, right bubbler	<1.0		µg/L	
456-501-DF-55	Drinking fountain, community room 501, left bubbler	2.0		µg/L	
456-501-DF-56	Drinking fountain, community room 501, right bubbler	2.0		µg/L	
Phase II Sampled on 10/14/2017					
456-156-SK-57	Classroom sink, room 156	1.3		µg/L	
456-141-SK-58	Classroom sink, room 141	1.3		µg/L	
456-106A-SK-59	Office sink, room 106A	1.2		µg/L	
456-110-SK-60	Office sink, room 110	1.1		µg/L	
456-109-SK-61	Classroom sink, room 109	1.3		µg/L	
456-108-SK-62	Classroom sink, room 108	2.2		µg/L	
456-124-SK-63	Science lab sink, room 124, east wall	0.7		µg/L	
456-124-SK-64	Science lab sink, room 124, south wall	0.4		µg/L	
456-124-SK-65	Science lab sink, room 124, west wall, left sink	0.7		µg/L	
456-124-SK-66	Science lab sink, room 124, west wall, right sink	0.5		µg/L	
456-123A-SK-67	Science prep room sink, room 123A	2.3		µg/L	
456-123-SK-68	Science lab sink, room 123, south wall, left sink	0.6		µg/L	

456-123-SK-69	Science lab sink, room 123, south wall, right sink	0.3	µg/L
456-119-SK-70	Science lab sink, room 119, north wall	0.4	µg/L
456-119-SK-71	Science lab sink, room 119, south wall, left sink	0.5	µg/L
456-119-SK-72	Science lab sink, room 119, south wall, right sink	0.5	µg/L
456-119A-SK-73	Science prep room sink, room 119A	0.5	µg/L
456-118-SK-74	Science lab sink, room 118, west wall	0.5	µg/L
456-118-SK-75	Science lab sink, room 118, east wall, left sink	0.6	µg/L
456-118-SK-76	Science lab sink, room 118, east wall, right sink	0.5	µg/L
456-118-SK-77	Science lab sink, room 118, south wall	0.7	µg/L
456-243A-SK-78	Office sink, room 243A	0.5	µg/L
456-244-SK-79	Classroom sink, room 244, west wall	0.5	µg/L
456-244-SK-80	Classroom sink, room 244, north wall, right sink	3.5	µg/L
456-244-SK-81	Classroom sink, room 244, east wall, 1st from north wall	1.2	µg/L
456-244-SK-82	Classroom sink, room 244, east wall, 2nd from north wall	7.8	µg/L
456-244-SK-83	Classroom sink, room 244, east wall, 3rd from north wall	1.1	µg/L
456-244-SK-84	Classroom sink, room 244, east wall, 4th from north wall	1.7	µg/L
456-244-SK-85	Classroom sink, room 244, east wall, 6th from north wall	5.7	µg/L
456-246-SK-86	Classroom sink, room 246	8.1	µg/L
456-210-SK-87	Art room sink, room 210	0.2	µg/L
456-208-SK-88	Art room sink, room 208, left sink	0.6	µg/L
456-208-SK-89	Art room sink, room 208, right sink	0.5	µg/L
456-206-SK-90	Art room sink, room 206	1.4	µg/L
456-206C-SK-91	Prep room sink, room 206C	0.9	µg/L
456-225-SK-92	Science lab sink, room 225, east wall	0.4	µg/L
456-225-SK-93	Science lab sink, room 225, south wall	0.5	µg/L
456-225-SK-94	Science lab sink, room 225, west wall, left sink	0.5	µg/L
456-225-SK-95	Science lab sink, room 225, west wall, right sink	0.4	µg/L
456-224A-SK-96	Science prep room sink, room 224A	0.9	µg/L
456-224-SK-97	Science lab sink, room 224, north wall, left sink	0.8	µg/L
456-224-SK-98	Science lab sink, room 224, north wall, right sink	0.7	µg/L
456-224-SK-99	Science lab sink, room 224, south wall, left sink	0.4	µg/L
456-224-SK-100	Science lab sink, room 224, south wall, right sink	0.2	µg/L
456-220-SK-101	Science lab sink, room 220, north wall, left sink	0.3	µg/L
456-220-SK-102	Science lab sink, room 220, north wall, right sink	0.5	µg/L
456-220-SK-103	Science lab sink, room 220, south wall, left sink	0.3	µg/L
456-220-SK-104	Science lab sink, room 220, south wall, right sink	0.4	µg/L
456-220A-SK-105	Science prep room sink, room 220A	0.6	µg/L
456-216-SK-106	Science lab sink, room 216, west wall	0.5	µg/L
456-216-SK-107	Science lab sink, room 216, east wall, left sink	0.5	µg/L
456-216-SK-108	Science lab sink, room 216, east wall, right sink	0.5	µg/L
456-216-SK-109	Science lab sink, room 216, south wall	0.5	µg/L
456-302A-SK-110	Workroom restroom sink, room 302A	0.8	µg/L

*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.